

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No. F.6/DFS/MS/GH/2021/SZ/ 17

Dated: 19/01/2021

FIRE SAFETY CERTIFICATE

Certified that M/s Mughal Cuisine Foods Pvt. Ltd. located at D-23,24, Kalindi Kunj Road, Abul Fazal Enclave-I, Jamia Nagar, New Delhi-110025, running at Ground floor (seating capacity of 80 persons) of a building comprised of Basement, Ground plus three Upper floors was granted FSC by this department vide letter no F6/DFS/MS/EH/2017/SZ/401 dated 16/03/2017. The premises was re-inspected by the officers concerned of this department on 18/01/2021 in the presence of Mr. Anil Sharma (Manager) of the restaurant and observed that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the building/premises is fit for occupancy class "Assembly Building" (Restaurant) as above with effect from 19/01/2021 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 19/01/2021 at New Delhi by.



(Sunil Chawdhary)
Dy. Chief Fire Service
Delhi Fire Service

Copy to: -

1. The Joint Commissioner of Police,(LIC.), 1st floor P.S. Defence Colony, New Delhi 11004
2. The DHO (CZ), South MCD, Public Health Department, Lajpat Nagar, New Delhi-110024
3. The Director, M/s Mughal Cuisine Foods Pvt. Ltd., D-23, 24, Kalindi Kunj Road Abul Fazal Enclave-I, Jamia Nagar, New Delhi-110025

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

1	Name & Address of the Building	M/s Mughal Cuisine Foods Pvt. Ltd located at D-23 & 24, Kalindi Kunj Road, Abul Fazal Enclave-I, Jamia Nagar, New Delhi-110025		
2	Type of Occupancy	Assembly, "Group-D" (Restaurant)		
3	Building Comprised of	Basement, Ground + 03 upper floors.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/EH/2017/SZ/401 dated 16/03/2017		
6	Fire Safety Directives Letter No	DFS Act-2007 & Rules-2010		
7	Date of Inspection	18/01/2021		
8	Name of the Inspecting Officers	ADO Avtar Singh		
9	Name & Designation of Officers from the building side	Mr. Anil Sharma (Manager)		
10	Year of construction	2005 Restaurant running at ground floor of the building		
11	Applicant letter No.	Email dated 14/01/2021		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC 09/10/2013 Requirements	Provided at Site	Remarks NR/NMR
1	Access to Building.			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Required	9 m	MR
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	-N/A-	-N/A-	-N/A-
	➤ Basement floor.	02 nos	02 nos	MR
	b) Width of Staircase			
	➤ Upper floors	-N/A-	-N/A-	-N/A-
	➤ Basement floor	1.5 m	2.10 m × 2	MR
	c) Protection of exits			
	➤ Fire check door	-N/A-	-N/A-	-N/A-
	➤ Pressurization	-N/A-	-N/A-	-N/A-
	d) No. of continuous staircase to terrace	-N/A-	-N/A-	-N/A-
	e) Width of corridor	-N/A-	-N/A-	-N/A-
	f) Door size	Required	2.0 m & 1.50 m (final exit)	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door. Sealing of electrical shafts. Fire rating of shaft door. Water curtain Fire dampers. 	-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
4.	Smoke Management system.			
	<ul style="list-style-type: none"> Basement Upper floors 	Required	Exhaust Fan Provided	MR
		-N/A-	-N/A-	-N/A-
5.	Fire Extinguishers.			
	<ul style="list-style-type: none"> Total numbers Types ISI Marking 	ISI marked	12 Nos	MR
			ABC-09 & CO ₂ -03	MR
			Provided	MR
6.	First Aid Hose Reels.			
			02 Provided in Restt.	MR

		Hose Reel	30 m	MR
<ul style="list-style-type: none"> Length of hose-reel hose. Nozzle Diameter 			05 mm	MR
7	Automatic fire detection & alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> Location of Main Panel 	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> Location of Repeater Panel 	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> Alternate source of power 	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> Hooter's location 	-N/A-	-N/A-	-N/A-
8.	MOEFA	Required	Provided	MR
9.	Public Address System	-N/A-	-N/A-	-N/A-
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement. 	Required	Provided	MR
	<ul style="list-style-type: none"> Upper floors 	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	-NA-	-NA-	-NA-
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser / Down-comer 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Number of Hydrant per floor 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Hose box. 	-NA-	-NA-	-NA-
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. 	-N/A-	01 Provided	-N/A-
	<ul style="list-style-type: none"> Hose box. 	-N/A-	01 Provided	-N/A-
13.	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level 			
	Discharge of main pump.	-N/A-	-N/A-	-N/A-
	➤ Head of main pump.	-N/A-	-N/A-	-N/A-
	➤ Number of main pumps.	-N/A-	-N/A-	-N/A-
	➤ Jockey Pump output.	-N/A-	-N/A-	-N/A-
	➤ Jockey Pump head.	-N/A-	-N/A-	-N/A-
	➤ Standby Pump output.	-N/A-	-N/A-	-N/A-
	➤ Standby Pump head.	-N/A-	-N/A-	-N/A-
	➤ Auto Starting/Manual stopping.	-N/A-	-N/A-	-N/A-
	➤ Pump house access.	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> Terrace Level 			
	➤ Discharge of pump.	Required	900 LPM	MR
	➤ Head of pump.	Required	40 m	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14.	Captive water storage for firefighting.			
	<ul style="list-style-type: none"> Underground tank capacity. 	-N/A-	-N/A-	-N/A-
	➤ Draw-off connection.	-N/A-	-N/A-	-N/A-
	➤ Fire Service Inlet.	-N/A-	-N/A-	-N/A-
	➤ Access to tank.	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> Overhead tank capacity. 	Required	10,000 ltrs	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. 	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> Pressurization of lift lobby. 	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> Communication in lift car. 	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> Fireman's switch. 	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> Lift signage 	-N/A-	-N/A-	-N/A-

- N/2 -

17	Standby Power Supply	Required	Provided	MR
18.	Refuge Area			
	• Total area	-N/A-	-N/A-	-N/A-
	• Location	-N/A-	-N/A-	-N/A-
19.	Fire Control Room.			
	• Detector System Panel.	-N/A-	-N/A-	-N/A-
	• Flow Switch Panel.	-N/A-	-N/A-	-N/A-
	• PA system Panel.	-N/A-	-N/A-	-N/A-
	• Battery backup	-N/A-	-N/A-	-N/A-
	• Building floor plan	-N/A-	-N/A-	-N/A-
20.	Special Fire Protection System for the Protection of special Risk, if any.	Required	01 CO ₂ type fire extinguisher provided near electrical panel	MR

The Fire protection systems provided in the premises were checked / operated at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules, the FSC issued vide letter no. F6/DFS/MS/EH/2017/SZ/401 dated 16/03/2017, renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

(Signature)
18/01/2021

Signature of the Inspecting Officer
Name : Avtar Singh
Designation: ADO (MRd)

DO (SD)

CHL + D/off

F.I. please.

DCFO (SZ)

ADO (MR)

(Signature)
19/1

Fi letter is put up for sign please

DCFO (SZ)

(Signature)

(Signature)
2

M.S. *(Signature)*