

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001


No F 6 / DFS / MS / 2021 / 38

Dated 19 / 01 / 2021

FIRE SAFETY CERTIFICATE

Certified that the **Missionaries of Charity (Mother Teresa's)** on ground floor at **Magazine Road, Near Majnu Ka Tilla (Petrol Pump), Civil Line, Delhi-10054** comprised of **Basement, Ground and First floor** owned/ occupied by **Missionaries of Charity, Nirmal Hriday** was granted NOC by this department vide letter no. **F6/MS/DFS/MS/2014/805 dated 30.06.2014**. The premises was re-inspected by the officers concerned of this department on **18.01.2021** in the presence of **Sr. Nishaj MC** and found that the building/premise have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and the building/ premises is fit for **occupancy of Institutional Building for ground floor only** with effect from 19/01/2021 for a period of **03 (Three) years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 19/01/2021 at New Delhi by


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
Ph-011-25156707
ofc

Copy to:-

1. **Sr. Nishaj MC, Nirmal Hriday Home, Magazine Road, Near Majnu Ka Tilla (Petrol Pump), Civil Line, Delhi-110054.**

Conditions for the validity of Fire Safety Certificate:

- 1 All the means of escape/entry/exit shall be kept free from any obstruction.
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
- 3 All the staff members must know the correct method of operation of firefighting system.
- 4 The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doi/fire/FIRE/Home/Forms>.
- 5 This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
- 6 "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".
- 7 This Fire Safety Certificate is valid only Ground floor for institutional occupancy only. In case of any violation, this FSC will be treated as null & void.

INSPECTION REPORT

1. Name & address of the building : Nirmal Hriday Home, Magazine Road, Near Majnu Ka Tilla
(Petrol Pump), Civil Line, Delhi-110054.
2. Type of Occupancy : Institutional
3. Type of Case : Renewal B+ G+01 upper floor (Running at ground floor only)
4. Details of previous NOC : F6/DFS/MS/2014/805 Date: 30.06.2014
5. Fire Safety directives letter No : F6/DFS/MS/BP/2009/2127 dated 16.07.2009.
6. Date of inspection : 18.01.2021 **Basement- Vacant**
7. Name of the Inspecting Officers : ADO (RN) **Ground- Destitute**
8. Name and designation of officers **First floor- servant room**
from the building side : Sr. Nishaj MC
9. Year of Construction : 2009
10. Applicant's letter No. : Online E-Mail I.D dated: 25.09.2020

S. No	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06m	18m	MR
	• Gate width	4.5m	4.5m	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	NA	04 + 01 ramp	NA
	• Basements	NA	03	NA
	b. Width of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.0m	1.0m	MR
3	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA

	• Fire Dampers	Required	Provided	MR
4	Smoke Management System.			
	• Basements	30ACPH	Provided	MR
	• Upper floors	12ACPH	NA	NA
5	Fire Extinguishers			
	• Total numbers	16nos	18 nos	MR
	• Types	ABC/CO2	ABC-12 /CO2-06	MR
	• IS marking	Required	Provided	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	02	02	MR
	• Length of hose reel hose	30m	30m	MR
	• Nozzle diameter	6mm	6mm	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	04''	Provided	MR
	• Number of hydrants per floor	02	Provided	MR
	• Hose Box	02	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	➤ Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	180lpm	Provided	MR
	➤ Jockey pump head	40m	Provided	MR
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual	NA	NA	NA
		NA	NA	NA

	stopping	NA	NA	NA
	➤ Pump House Access			
	• Terrace level	900lpm	900lpm	MR
	➤ Discharge of pump	40m	Provided	MR
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump			
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	20,000 ltrs	20,000 ltr.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	Required	Provided DG Set	MR
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in NBC Part-IV the FSC issued vide letter of even no 805 dated 30.06.2014 renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

DO (VWD)

19/01/2021

Signature of the Inspecting Officer
Name: - C.L. Meena