

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No. F.6/DFS/MS/Assembly/SZ/2021/ 35

Dated: 18/01/2021

FIRE SAFETY CERTIFICATE

Certified that **Okhla Vihar Metro Station of Line 8 (Janak Puri West to Kalindi Kunj Section)**, comprising of four levels (Ground, First, Concourse & Platforms) was granted Fire Safety Certificate vide letter no. F6/DFS/MS/2017/Metro/800 dated 06/06/2017. The said metro station was re-inspected by the officer concerned of this department on 09/01/2021 in the presence of Mr. Pankaj Kumar (Fire Inspector) & Mr. Amit Kumar (ASE) and found that the metro station building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy **Class D (Assembly Building)** with effect from18/01/2021.... for a period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued 18/01/2021 at New Delhi by



(Sunil Chawdhary)
Dy. Chief Fire Officer
Delhi Fire Service



Copy to: -

1. The Executive Engineer (Bldg), SDMC, Jal Vihar, Lajpat Nagar, New Delhi-110024
2. Mr. Bhirgu Fukan Assistant Manager (Fire), Merto Bhawan, Fire Brigade Lane, Barakhamba Road, New Delhi.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

1	Name & Address of the Building	Okhla Vihar Metro Station (having 1 st floor and First floor below concourse} of Line 8 (Janak Puri West to Kalindi Kunj Section)		
2	Type of Occupancy	Assembly Group- D		
3	Building Comprised of	Ground + First + Concourse + Platforms		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/Assembly/SZ/2017/800 dated 06/06/2017		
6	Fire Safety Directives Letter No	F6/DFS/MS/BP/2013/357 dated 23/01/2013 7 even no/ 2017/1373 dated 24/05/2017		
7	Date of Inspection	09/01/2021		
8	Name of the Inspecting Officers	ADO Avtar Singh		
9	Name & Designation of Officers from the building side	Mr. Pankaj Kumar (Fire Inspector) & Mr. Amit Kumar (ASE)		
10	Year of construction	2017		
11	Applicant letter No.	Email dated 03/11/2020		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	BBL/NBC Requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	12 m	Provided	MR
	• Gate width	-N/A-	-N/A-	-N/A-
	• Width of internal road	-N/A-	-N/A-	-N/A-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors	GF to 1 st floor(for Police Station)- 2 nos GF to Concourse- 3nos & Concourse to Platform- 4 nos	Provided	MR
	➤ Basement floor	-N/A-	-N/A-	-N/A-
	b) Width of Staircase			
	➤ Upper floors	1.5 m & 1.35 m (for Police Station)	1.5 m & 1.35 m	MR
	➤ Basement floor	2 m -N/A-	GF to Concourse- 3nos of 2.2m & Concourse to Platform- 2nos of 3.2 m -N/A-	-N/A-
	c) Protection of exits			
	➤ Fire check door	-N/A-	-N/A-	-N/A-
	➤ Pressurization	-N/A-	-N/A-	-N/A-
	d) No. of continuous staircase to terrace	-N/A-	-N/A-	-N/A-
	e) Width of corridor	1.5 m	Provided	MR
	f) Door size	2 m	Provided	MR
3	Compartmentation.			
	• Fire check door.	Required in Technical Rooms	Provided	MR
	• Sealing of electrical shafts.	Required	Provided	MR
	• Fire rating of shaft door.	-N/A-	-N/A-	-N/A-
	• Water curtain	-N/A-	-N/A-	-N/A-
	• Fire dampers.	-N/A-	-N/A-	-N/A-
4.	Smoke Management system.			

	• Upper floors	-N/A-	-N/A-	-N/A-
5.	Fire Extinguishers.			
	• Total numbers	36 nos	Provided	MR
	• Types	CO ₂ /W.CO ₂ /	18/18	MR
	• ISI Marking	ISI Marked	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor	3 nos at concourse & 2 nos of each platform	Provided	MR
	• Length of hose-reel hose.	45 m	45 m	MR
	• Nozzle Diameter	5 mm	5 mm	MR
7	Automatic fire detection & alarming system.			
	• Type of detectors	Smoke & Heat	Provided	MR
	• Location of Main Panel	Station Control Room	Provided	MR
	• Location of Repeater Panel	-N/A-	Near ASS	-N/A-
	• Alternate source of power	Required	Provided	MR
	• Hooter's location	All Area	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	-N/A-	Provided	-N/A-
10.	Automatic Sprinkler System			
	• Basement.	-N/A-	-N/A-	-N/A-
	• Upper floors	-N/A-	-N/A-	-N/A-
	• Sprinkler above false ceiling	-N/A-	-N/A-	-N/A-
11.	Internal Hydrants.			
	• Size of Riser / Down-comer	100 mm	Provided	MR
	• Number of Hydrant per floor	3 nos at concourse & 2 nos of each platform	Provided	MR
	• Hose box.	3 nos at concourse & 2 nos of each platform	Provided	MR
12.	Yard Hydrants.			
	• Total number of hydrants.	02 nos	Provided	MR
	• Hose box.	02 nos	Provided	MR
13.	Pumping arrangements.			
	• Ground Level			
	➤ Discharge of main pump.	1800 LPM	Provided	MR
	➤ Head of main pump.	70 m	Provided	MR
	➤ Number of main pumps.	One	Provided	MR
	➤ Jockey Pump output.	180 LPM	Provided	MR
	➤ Jockey Pump head.	70 m	Provided	MR
	➤ Standby Pump output.	1800 LPM (Electric)	Provided	MR
	➤ Standby Pump head.	70 m	Provided	MR
	➤ Auto Starting/Manual Stopping.	Required	Provided	MR
	➤ Pump house access.	Required	Provided	MR
	• Terrace Level			
	➤ Discharge of pump.	-N/A-	-N/A-	-N/A-
	➤ Head of pump.	-N/A-	N/A	-N/A-
	➤ Power supply.	-N/A-	N/A	-N/A-
	➤ Auto starting of pump.	-N/A-	N/A	-N/A-
14.	Captive water storage for firefighting.			
	• Underground tank capacity.	50,000 ltrs	Provided	MR

	<ul style="list-style-type: none"> ➤ Draw-off connection. ➤ Fire Service Inlet. ➤ Access to tank. • Overhead tank capacity. 	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		-N/A-	10,000 ltrs	-N/A-
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of lift shaft. • Pressurization of lift lobby. • Communication in lift car. • Fireman's switch. • Lift signage. 	-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	Provided	MR
		-N/A-	Provided	MR
		-N/A-	Provided	MR
17	Standby Power Supply	Required	Provided	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> • Total area • Location 	-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
19.	Fire Control Room.			
	<ul style="list-style-type: none"> • Detector System Panel. • Flow Switch Panel. • PA system Panel. • Battery backup • Building floor plan 	-N/A-	Provided	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	Provided	-N/A-
		-N/A-	Provided	-N/A-
		-N/A-	Provided	-N/A-
20.	Special Fire Protection System for the Protection of special Risk, if any.	Gas flooding in HT, LT panel, LT distribution board and essential power panels and other such major panels.		MR
			Provided	

The Fire protection systems provided in the premises were checked / operated at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. F.6/DFS/MS/Assembly/SZ/2017/800 dated 06/06/2017 renewal under rule 37 of the Delhi Fire Service rule 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

(Signature)
11/01/2021

Signature of the Inspecting Officer
Name : Avtar Singh
Designation: ADO (M.Rd)

DO (SD)

(Signature)
12/01

Defo/SZ

F.F. + lease -

(Signature)

(Signature) ADO (M.Rd)

FI letter is put up for signature

(Signature)