

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6/DFS/MS/School/SZ/2020/ 50

Dated: 20/01/2021

**FIRE SAFETY CERTIFICATE**

Certified that **Bal Bharti Public School located at Ganga Ram Hospital Marg, New Delhi- 110060**, having two wings namely Senior Wing, Primary & Middle Wing. Both wings are comprised of basement, ground plus three upper floors each was issued FSC by this department vide letter No. F.6/DFS/MS/School/SZ/2017/1135 dated 31.07.2017. The school building was re-inspected by the officer concerned of Delhi Fire Service on 24.12.2020 in the presence of Sh. Akhilesh Kashyap (Estate Officer) of the school and found that the School management have complied with the fire prevention and fire safety requirements in accordance with the Directorate of Education circular No.F.6/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 and that the school building is fit for occupancy class "Educational" with effect from 20/01/2021 for a period of 03 years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions printed overleaf under rule 38 of Delhi Fire Service Rules- 2010.

Issued on 20/01/2021 at New Delhi by.

(Sunil Chaudhary)

Dy. Chief Fire Officer (SZ)  
Delhi Fire Service

O/C

Copy to: -

1. The Principal,  
Bal Bharti Public School,  
Ganga Ram Hospital Marg,  
New Delhi- 110060
2. The Directorate of Education,  
Govt. of NCT of Delhi, Old Secretariat,  
New Delhi- 110054.

### Conditions for the Validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional of fire safety measures shall be at the risk & responsibility of the management.
3. The trained firefighting staffs should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. Basement used only for storage purpose as per BBL.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [ sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
9. All the means of escapes /exits shall not be locked/blocked at any time for safe evacuation of the occupants in case of emergency.



**INSPECTION REPORT**

1. Name & address of the building : Bal Bharti Public School, Ganga Ram Hospital Marg, New Delhi- 110060
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/School/SZ/2017/1135 dated 31.07.2017
5. Fire Safety directives letter No : N/A
6. Date of inspection : 24.12.2020
7. Name of the Inspecting Officers : Sunil Chaudhary, DCFO, (SZ), P.V Rathee, ADO (SRD)
8. Name and designation of officers from the building side : Sh. Akhilesh Kashyap (Estate Officer)
9. Year of Construction : Before 1980
10. Applicant's letter No. : Ref. No. 571/BB/2020-21 dated 09.12.2020

Bal Bharti Public School having two wings namely Senior Wing, Primary & Middle Wing. Both wings are comprised of basement, ground plus three upper floors each

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/ BBL Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	06 mts 4.5 mts N/A	Provided Provided N/A	MR MR N/A
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	-----	-----	-----
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	02 Nos. each wing 01 No.	03 Nos. each wing 01 No.	MR MR being old case
	b. Width of staircases	-----	-----	-----
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	1.5 mts or less & 0.75 mt -----	Sr. wing- 1.70, 1.43, 1.30 P&M wing- 1.30, 1.30, 1.20 mts. 1.20 mts	MR MR (small basement, area is less than 200 Sq. mt.) being old case
	c. Protection of exits	-----	-----	-----
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	N/A N/A	N/A N/A	N/A N/A
	e. No. of continuous staircases to terrace	02 at each wing	02 at each wing	MR
	g. Width of Corridor	1.5 mts	Provided	MR
	h. Door Size	1.0 mt.	Provided	MR
3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	30 a/c per hour 12 a/c per hour	Exhaust fan provided Natural ventilation provided	MR MR









14	<b>Captive Water Storage for fire fighting</b>			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	Provided	----
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	02 x 10,000 lts	Provided	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>	<b>Not Applicable</b>		
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	<b>Standby power supply</b>	N/A	N/A	N/A
18	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required 02 ABC type fire extinguishers near elect. panel	Provided	MR

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F.6/DFS/MS/School/SZ/2017 dated 31.07.2017, renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

DFA is put up for approval & signature please.

  
Signature of the Inspecting Officer  
(Sunil Chaudhary)  
Dy. Chief Fire Officer (SZ)

  
Signature of the Inspecting Officer  
(P.V Rathee)  
Asstt. Divisional Officer, (SRD)

F.I. please.

A N O S. R. N.