

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**


No. F6/DFS/MS/School/SZ/2021/ 51

Dated: 20/01/2021

FIRE SAFETY CERTIFICATE

Certified that **S.K.R. Public School located at Borianwala Tahlla, Inderpuri, New Delhi- 110012**, comprised of basement/lower ground, ground plus three upper floor, was granted Fire Safety Certificate vide letter No. F.6/DFS/MS/School/SZ/2017/1174 dated 08.08.2017. The school building was re-inspected by the officer concerned of this department on 11.01.2021 in the presence of Smt. Uma Dwivedi, principal of the school and found that the School management have complied with the fire prevention and fire safety requirements in accordance with the Directorate of Education circular No. F.6/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 and that the school building is fit for occupancy class "Educational" with effect from 20/01/2021 for a period of 03 years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions printed overleaf under rule 38 of Delhi Fire Service Rules- 2010.

Issued on 20/01/2021 at New Delhi by.



(Sunil Chaudhary)
Dy. Chief Fire Officer (SZ)
o/c Delhi Fire Service

Copy to: -

1. The Principal, S.K.R. Public School, Borianwala Tahlla, Inderpuri, New Delhi- 12.
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi- 110054.

Conditions for the Validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional of fire safety measures shall be at the risk & responsibility of the management.
3. The trained firefighting staffs should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. Basement used only for storage purpose as per BBL.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.
9. All the means of escapes /exits shall not be locked/blocked at any time for safe evacuation of the occupants in case of emergency.

1. Name & address of the building : S.K.R. Public School, Bohrianwala Thalla, Inderpuri, New Delhi- 110012.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/School/SZ/2017/1174 dated 08.08.2017
5. Fire Safety directives letter No : N/A
6. Date of inspection : 11.01.2021
7. Name of the Inspecting Officers : P.V Rathee, Asstt. Div. Officer (SRD)
8. Name and designation of officers from the building side : Smt. Uma Dwivedi, Principal
9. Year of Construction : 1990
10. Applicant's letter No. : nil dated 01.12.2021

S.K.R. Public School is comprised of basement/lower ground, ground plus three upper floors.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/ BBL Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	06 mts	Provided	MR
		Old case	3.45 mts.	MR being old case
		N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-----	-----	-----
	<ul style="list-style-type: none"> • Upper Floors • Basements 	03 Nos.	03 Nos.	MR
		02 Nos.	02 Nos.	MR
	b. Width of staircases	-----	-----	-----
	<ul style="list-style-type: none"> • Upper Floors • Basements 	1.5 mts or less & 0.75 mt	1.64, 0.85 mts & 0.80 - 1.20 mts	MR being old case
		1.5 mts or less & 0.75 mt	1.90, 1.0 mts	MR
	c. Protection of exits	-----	-----	-----
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A	N/A	N/A
		N/A	N/A	N/A
	e. No. of continuous staircases to terrace	01	01	MR
	g. Width of Corridor	1.5 mts	Provided	MR
	h. Door Size	1.0 mt.	Provided (0.91 - 1.09 mts)	MR being old case
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour	Exhaust fan provided	MR
		12 a/c per hour	Natural ventilation provided	MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	26 nos.	Provided	MR
		ABC, CO ₂ type	Provided	MR
		ISI marked	Provided	MR

15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.	Not Applicable		
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	MR
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required 02 ABC type fire extinguishers near elect. panel	Provided	MR

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Note: - all the shortcomings pointed out by this department vide letters No. F.6/DFS/MS/School/2020/731 dated 11.11.2020 have complied and school management also given a undertaking to certify that lower ground floor(Hall) is used only for storage & there is no medical services such as Dental Clinic etc are running in the school premises. These are run by the society beyond the boundaries of the school premises.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F.6/DFS/MS/School//SZ/2017/1174 dated 08.08.2017, renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

DFA is put up for approval & signature please.

[Handwritten Signature]
12/1/21

Signature of the Inspecting Officer
(P.V Rathee)
Asstt. Divisional Officer, (SRD)

[Handwritten Signature]
13/01/2021
[Handwritten Signature]

[Handwritten Signature]
F.F. please