

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2020/ Dnd / 59

Dated: 22/01/2021


FIRE SAFETY CERTIFICATE

Certified that the M/s Fashion Cosmetics, located at M-138, Sec-3, Bawana, Industrial Area, Delhi-110039 comprised of Basement+Ground+Two upper floors owned/occupied by M/s Fashion Cosmetics was issued fire safety certificate vide Letter No. DFS/MS/F6/2017/Cos/1722 dated 30/11/2017 have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of fire service on 07/12/2020 in the presence of Sh. Ravish Arora (Owner) and found that the building premise is fit for occupancy under "Class Industrial Building G-2(ii)" with effect from 22/01/2021... for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

Conditions for the validity of Fire Safety Certificate:

1. Means of escape shall not be kept locked or bolted from outside and shall be easily open able at the time of emergency.
2. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
3. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 22/01/2021 at New Delhi


(Dharampal Bhardwaj)
Dy.Chief Fire Officer
WEST ZONE

Copy to :-

1. M/s Fashion Cosmetics , M-138, Sector-3, Bawana Industrial Area, Bawana, Delhi-39.
2. Dy. Drug controller /licensing authority Govt. of NCT. Of Delhi, Drug Controller Department, F-17, Karkardooma, Delhi-110032.

INSPECTION REPORT

1. Name & address of the building: M/s Fashion Cosmetic , M-138, Sector-3 , Bawana Industrial Area , Delhi-39
2. Type of Occupancy : Industrial G-2(ii) (B+Gr.+1+2nd floor)
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/2017/Cos/1722 Dated-30/11/2017
5. Fire Safety directives letter No : DFS Act 2007 & Rule 2010/NBC Part IV
6. Date of inspection : 07.12.2020
7. Name of the Inspecting Officers : ADO (BW)
8. Name and designation of officers from the building side : Sh. Ravish Arora(Owner)
9. Year of Construction :2017
10. Applicant's letter No. : Nil Dated-23/11/2020

S. No	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	09m	Provided	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	02	02	MR
	b. Width of staircases			
	• Upper Floors	1.25m & 0.75m	Provided	MR
	• Basements	1.25m & 0.75m	Provided	MR
	c. Protection of exits			
	• Fire check door	NA	NA	MR
	• Pressurization	NA	NA	MR
	d. No. of continuous staircases to terrace			
		01	Provided	MR
		NA	NA	NA

Arora

	e. Width of Corridor			
	f. Door Size	1.00m	Provided	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basements	30a/c per hour	Exhaust Fan	MR
	• Upper floors	12a/c per hour	Natural Ventilated	MR
5	Fire Extinguishers			
	• Total numbers	07nos	17 nos	MR
	• Types	ABC	ABC	MR
	• IS marking	Required	Yes	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• Upper Floor	Required	Provided	MR

Handwritten signature

	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	NA	NA	NA
	<ul style="list-style-type: none"> • Number of hydrants per floor 	NA	NA	NA
	<ul style="list-style-type: none"> • Hose Box 	NA	NA	NA
12	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> • Hose Box 	NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> ➤ Ground Level 			NA
	<ul style="list-style-type: none"> ➤ Discharge of main Pump 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Head of Main pump 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Number of main pumps 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Jockey Pump out put 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Jockey pump head 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Standby Pump out put 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Standby Pump Head 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Auto Starting/ Manual stopping 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Pump House Access 	NA	NA	NA
	<ul style="list-style-type: none"> • Terrace level 			
	<ul style="list-style-type: none"> ➤ Discharge of pump 	900 LPM	Provided	MR
	<ul style="list-style-type: none"> ➤ Head of the pump 	40 M	Provided	MR
	<ul style="list-style-type: none"> ➤ Power Supply 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Auto Starting of pump 	NA	NA	NA
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Draw-off connection 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Fire service inlet 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Access to tank 	NA	NA	NA
	<ul style="list-style-type: none"> • Overhead Tank capacity 	10,000 ltrs	10,000 ltrs	MR
15	Exit Signage.	Required	Provided	MR

Prish

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested/ checked randomly and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standard on fire prevention and fire safety required under the rules, the FSC issued vide letter no. F6/DFS/MS/2017/Cos/1722 dated 30/11/2017, it is recommended for renewal of Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010

15/12/2020
Signature of the Inspecting Officer
Name: - Rajeev Kumar Sinha

Designation- ADO/BW

DO (NW)

15/12/2020
By ADO (NW)

Inspection for this premises should be done along with DO.

ADO (NW)

15/01/2021

4/1/2021