

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/School/2020/NDZ158

Dated: 21/01/2021

FIRE SAFETY CERTIFICATE

Certified that the Greenway Modern School located at between pocked A & D, Dilshad Garden, Delhi-110095, comprised of basement, ground plus four upper floors only owned/occupied by Greenway Modern School was issued FSC vide letter No-F6/DFS/MS/School/2017/NDZ/787 dated 01/06/2017. The school building was re-inspected by the officer concerned of this department in the presence of Mr. Deepak, LDC of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with rules 33 of the Delhi Fire Service Rules, 2010 and observed that the school building is fit for occupancy class "B" 'Educational Building' with effect from 21/01/2021 for a period of **three** years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on 21/01/2021 at New Delhi by.



(Dr. S.K. Tomar)
Dy. Chief Fire Officer

To,
The Manager
Greenway Modern School
Between pocked A & D, Dilshad Garden,
Delhi-110095

Copy:-
The Dy. Director of Education,
B-Block, Yamuna Vihar,
Delhi-110053

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form `J` [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

1. Name & address of the building : Greenway Modern School,
Between Pocket A & D, Dilshad Garden, Delhi -95
2. Building is comprised of : Basement, Ground plus four upper floors
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC letter : F6/DFS/MS/School/2013/NDZ/787 dt 01/06/2017
6. Fire Safety directive letter No. : F.6/DFS/MS/BP/2010/3019 dated 27/10/2010
7. Date of Inspection : 01/12/2020
8. Name of the Inspecting officers : ADO Mehmood
9. Name and designation of Officer
from the building side : Mr. Deepak, LDC
10. Year of Construction : 2005 & 2010
11. Applicant's letter No : GMS/Fire-Cert/2020/1153, Dated- 25/11/2020

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	NBC Part IV Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building.			
	• Road width	06 mtr.	15 mtr.	MR
	• Gate width	4.5 mtrs	06 mtrs	MR
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	• Upper floor	05 nos..	05 nos.	MR
	• Basement	02 nos.	02 nos.	MR
	b. Width of Staircases			
	• Upper floor	1.50 mtrs.	1.50 mtrs. each	MR
	• Basement	1.50 mtrs.	1.50 m each. 01 Ramp (04 mtrs)	MR
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	02 nos.	02 nos.	MR
	e. Width of Corridor	1.50 mtr.	1.80 mtr.	MR
	f. Door Size	01 mtr.	01 mtr.	MR
	g. No. of door in class room	02 nos.	01 & 02 nos.	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	Required	Exhaust fans	MR
	• Upper floor	N/A	N/A	N/A
05.	Fire Extinguishers.			
	• Total numbers	22 nos.	25nos.	MR
	• Types	ABC /CO ₂	ABC /CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR


06	First-Aid-Hose Reels.			
	• Total numbers on each floor	02 No.	02 No.	MR
	• Length of hose reel hose	30 mtr.	30 mtr.	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
08	MOEFA	Required	Provided	MR
09	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	02 nos.	02 nos.	MR
	• Hose box	02 nos.	02 nos.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of Main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump head	N/A	N/A	N/A
	• Auto Starting /Manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	900 lpm	900 lpm x 2	MR
	• Head of the pump	40 M	40 M	MR
	• Power supply	Required	Provided	MR
	• Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	Required	Provided	MR
	• Access to tank	Required	Provided	MR
	• Overhead tank capacity	25,000 ltrs	25,000 ltrs	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	Required	Provided	MR
	• Firemen's grounding switch	Required	Provided	MR
	• Lift signage	Required	Provided	MR


21/23

		Required	Provided	MR
17	Standby Power Supply			
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room /Reception			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection. The shortcoming issued vide letter no. F.6/DFS/MS/School/2020/NDZ/737 dated 18/11/20 have been rectified now.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the NBC Part IV, it is recommended to issue Fire Safety Certificate.



 Signature of the Inspecting Officer
 Name :- Mehmood
 Designation :- A.D.O. (Tahirpur)

DO/ED

 11/12

DY. CFO/NDZ.

Recd on 16/12/20

Pl. Speak about width of staircase in basement?


 16/12/2020

A.D.O.(T.P.) Rung on mlc up to 28/11/20.

Necessary corrects has been done in-ndz
 width of staircase in basement in Performer.

Submitted for approval plz.

DY. CFO/NDZ


 21/11/21

Recd on 21/11/21


 28/11