

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No.F6/DFS/MS/School/2021/ 61

Dated: 27/01/2021

FIRE SAFETY CERTIFICATE

Certified that the Government Girls Sr. Sec. School located at X Block, Brahmpuri, Delhi-110053, comprised of ground plus three floors & ground plus one upper floor, owned/occupied by Government Girls Sr. Sec. School was issued FSC vide letter No. F6/DFS/MS/School/2017/NDZ/1864 dated 27/12/2017. The school building was re-inspected by the officer concerned of this department in the presence of Mr. Ombir Singh, Estate Manager and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with rules 33 of the Delhi Fire Service Rules, 2010 and observed that the school building is fit for occupancy class "B" 'Educational Building' with effect from 27/01/2021 for a period of **three** years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on..... 27/01/2021 at New Delhi by



(Dr. Sanjay Tomar)
Dy. Chief Fire Officer

dl fo

To,

The Principal
Government Girls Sr. Sec. School
X Block, Brahmpuri,
Delhi-110053

Copy to:-

The Dy. Director of Education
B-Block, Yamuna Vihar
Delhi-110053

Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

21/18

1. Name & address of the building : Govt. Girls Senior Secondary School, X-Block, Brahmpuri, Delhi-110053
2. Building is comprised of : Ground plus three block & ground plus one upper floor (two separate blocks)
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC letter : F6/DFS/MS/School/2017/NDZ/1864 dt 27/12/2017 (G+3)
F6/DFS/MS/School/ 2017/ NDZ/1190 dt 09/08/17 (G+1)
6. Fire Safety direction letter No : NBC Part IV
7. Date of Inspection : 02/12/2020
8. Name of the Inspecting officers : ADO Mehmood
9. Name and designation of Officer from the building side : Mr. Ombir Singh, Estate Manager
10. Year of Construction : 2017 & 2004
11. Applicant's letter No : GGSSS/X-BLK/BP/2020-21 Dated-02/12/2020

Sr. No.	Minimum Standards on fire prevention and fire safety U/R33	NBC Part Iv Requirement	Provided at Site	Remarks MR/NMR
01	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	06 mtr. N/A N/A	06 mtr. N/A N/A	MR N/A N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"> • Upper Floor (G+1) • Upper Floor (G+3) • Basement 	04 nos. 01 nos. N/A	04 nos. 01 nos. N/A	MR MR N/A
	B. Width of Staircases			
	<ul style="list-style-type: none"> • Upper Floor (G+1) • Upper Floor (G+3) • Basement 	1.50 mtr 1.50 mtr. 	1.50 mtr each 1.82 mtr.	MR MR
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A N/A 02 nos.	N/A N/A 04 nos.	N/A N/A MR
	d. No. of continuous staircases to terrace			
	e. Width of Corridor	1.50 mtr.	02 mtr.(G+1) & 1.76 mtr (G+3)	MR
	f. Door Size	01 mtr.	01 mtr .(G+1) & 1.10 mtr(G+3)	MR
03	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
04	Smoke Management System.			
	<ul style="list-style-type: none"> • Basement • Upper floor 	N/A N/A	N/A N/A	N/A N/A

N/19

05.	Fire Extinguishers			
	• Total numbers	18 nos.	20 nos.	MR
	• types	ABC /CO ₂	ABC /CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR
06	First-aid-Hose Reels.			
	Total numbers on each floor (G+3)	01 nos	01 nos	MR
	• Length of hose reel hose	30 mtr	30 mtr	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
08	MOEFA	N/A	N/A	N/A
09	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements. for (G+3)			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level	N/A	N/A	N/A
	➤ Discharge of pump	450 lpm	450 lpm	MR
	➤ Head of the Pump	40 M	40 M	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR

N/20

14	Captive Water Storage for Fire Fighting.	N/A	N/A	N/A
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000 ltr Required	10,000 ltr Provided	MR MR
15	Exit Signage.			
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required as per NBC Part IV, it is recommended to renew Fire Safety Certificate.

Mehmood
3/12/2020

Signature of the Inspecting Officer
Name - Mehmood
Designation - ADO (TP)

DO (ED)
[Signature]
7/1/2

DY. CFO/MD-2

Pl. appear, Pl amend as discussed over phone on 8/12/20

Mehmood
8/12/2020

DO (ED) Need fed done.

DY. CFO/MD-2

[Signature]
9/1/2