

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No.F.6/DFS/MS/School/SZ/2021/ 59

Dated: 25/01/2021

**FIRE SAFETY CERTIFICATE**

Certified that the Kendriya Vidyalaya located at Pragati Vihar, Lodhi Road, New Delhi-110003 comprised of Ground & Two Upper Floors only, owned / occupied by Kendriya Vidyalaya Sanghathan, has already been issued Fire Safety Certificate Vide letter No. F6/DFS/MS/2016/School/276 dated 19/02/2016. The premises was re-inspected by the officer concerned of Fire Service on 19.01.2021 in the presence of Smt. Mamta Sharma (Principal) observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with Rule 33 of Delhi Fire Service Rules 2010 and that the building / premises is fit for occupancy class "Educational" (Group-B) with effect from 25 / 01 / 2021 for a period of three years subject to the conditions printed below.

**Issued on 25/01/2021 at New Delhi by.**



(SUNIL CHAWDHARY)  
DY. CHIEF FIRE OFFICER (S.Z.)



Copy to :-

1. The Principal, Kendriya Vidyalaya, Pragati Vihar, Lodhi Road, New Delhi-110003.
2. The Director of Education, Old Secretariat, Delhi-110054.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
7. There shall not be more than 45 students in class rooms in any case.

201-18  
**INSPECTION REPORT**

1. Name & address of the building: **Kendriya Vidyalaya, Pragati Vihar, Lodhi Road, New Delhi-110003.**
2. Type of Occupancy : **Educational [G+2]**
3. Type of Case : **Renewal**
4. Details of previous NOC : **F6/DFS/MS/2016/School/276 dated 19/02/2016**
5. Fire Safety directives Letter No. : **F6/DFS/MS/BP/99/2563 dated 15/01/1999**
6. Date of inspection : **19/01/2021**
7. Name of the Inspecting Officer : **A.D.O. (S.J.)**
8. Name and designation of Officer from the building side : **Smt. Mamta Sharma (Principal)**
9. Year of Construction : **2003**
10. Applicant's letter No. : **KVPV/2020-21/ dated 19/01/2021**

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6m	12m	MR
	• Gate width	Required	5m	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	3	3	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	1.5m(Each)	1.5m (Each)	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	1	1	MR
	e. Width Of Corridor	1.5m	1.5m	MR
	f. Door Size	1.00 mtr	1.00 mtr	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	13	13	MR
	• Types	ABC/CO <sub>2</sub>	Provided	MR
	• ISI marking	Required	Provided	MR

*[Handwritten Signature]*



NF-19

6.	First – Aid Hose Reels			
	• Total numbers on each floor	3 nos.	3 nos.	MR ✓
	• Length of hose reel hose	30m	30m	MR ✓
	• Nozzle diameter	5mm	5mm	MR ✓
7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A	100mm	N/A
	• Number of hydrants per floor	N/A	3 nos.	N/A ✓
	• Hose Box	N/A	3 nos.	N/A ✓
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level	N/A		
	• Discharge of main pump	N/A	N/A	N/A
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Staring/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 LPM	450 LPM X 2	MR ✓
	➤ Head of the pump	40 m	40 m	MR ✓
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank	5,000 ltr	10,000 ltr	MR ✓

NF-20

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A.	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Batter backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

Note:- 1. Shortcomings issued by this department vide letter No. F6/DFS/MS/School/2019/SZ/4902 dated 13/08/2019 have been complied.

2. General requirements for schools as per Director of Education circular dated 01/03/2011.

1. Escape route .....Clear.....
2. LPG cylinders in laboratories .....Nil.....
3. Electric wiring ...Conduit Wiring..... MCB and ELCB .....  
Electric circuit .....
4. Electric meter board ..... Not under the staircase.....
5. Basement use as per BBL 1983 .....NA.....
6. Emergency telephone no. board .....Displayed.....
7. Generator set .....Nil.....

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. **F6/DFS/MS/2016/School/276 dated 19/02/2016** renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

*Ashok Kumar Jaiswal*  
20/1/2021

Signature of the Inspecting Officer  
Name : Ashok Kumar Jaiswal  
Designation : A.D.O. (S.J.)

*D.O. (S.D.)*

*limy*  
21/01

*Defo/22*

*F-1 b... ..*