

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/SH/SZ/2021/c1wb/49

Dated: 22/01/2021

FIRE SAFETY CERTIFICATE

Certified that the M/s. Naraina Vihar Club (West Delhi), 'C' Park, Naraina Vihar, New Delhi- 110028, comprised of basement, ground plus four upper floors owned/occupier by Naraina Vihar Club have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of fire service on 08.01.2021 in the presence of Sh. P.P.S Gulati (Vice President) and that the building/premises is fit for occupancy class assembly (Club) with effect from 22/01/2021 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on 22/01/2021 at New Delhi by.

(Atul Garg)
Director

Delhi Fire Service

Copy to:-

1. The President,
M/s. Naraina Vihar Club, 'C' Park, Naraina Vihar, New Delhi- 110028.
2. The Deputy Health Officer, North Delhi Municipal Corporation, Karol Bagh Zone,
New Delhi- 110005.
3. The Joint Commissioner of Police (Lic), 1st Floor, Police Station Defence Colony,
New Delhi- 110024.

CONDITIONS

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional of fire safety measures shall be at the risk & responsibility of the management.
3. The trained firefighting staffs should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. All the means of escapes /exits shall not be locked/bolted/blocked at any time for safe evacuation of the occupants in case of any emergency.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in

1. Name & address of the building : M/s. Naraina Vihar Club, 'C' Park, Naraina Vihar, New Delhi- 110028.
2. Type of Occupancy : Assembly
3. Type of Case : New Case
4. Details of previous NOC : N/A
5. Fire Safety directives letter No : F.6/DFS/MS/BP/2011/1155 dated 12.07.2011
6. Date of inspection : 08.01.2021
7. Name of the Inspecting Officers : D.B Mukharjee, DO (SW) & P.V Rathee, ADO (SRD)
8. Name and designation of officers from the building side : Sh. P.P.S Gulati (Vice President)
9. Year of Construction : 2014-15
10. Applicant's letter No. : Email ID narainaviharclub@rediffmail.com dated 14.12.2020

The said Building is comprised of basement, ground plus four upper floors.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as UBBL / NBC-IV	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mts	Provided	MR
	• Gate width	4.5 mts	5.50 mts	MR
	• Width of internal road	06 mts	06 mts	MR
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-	-	-
	• Upper Floors	02	02	MR
	• Basements	01+ 01 ramp	01+01 ramp	MR
	b. Width of staircases	-	-	-
	• Upper Floors	02 mts	02 & 1.50 mts	MR
	• Basements	02 mts	Staircase- 02 mts Ramp- 3.10 mts	MR
	c. Protection of exits	-	-	-
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	e. No. of continuous staircases to terrace	01	02	MR
	g. Width of Corridor	02 mts	Provided	MR
	h. Door Size	2.0 mts.	02 mts	MR
3	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Sealed	MR
	• Fire Rating of shaft door	02 hrs	02 hrs	MR
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basements	30 a/c per hour	Exhaust fans are provided	MR
	• ground floor	12 a/c per hour	Natural ventilation	MR
5	Fire Extinguishers			
	• Total numbers	06	Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR

	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Required	Smoke/ Heat	MR
		At ground floor near reception	Provided	MR
		N/A	N/A	N/A
		Required	Provided	MR
		Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Entire Restaurant Sprinkler above false ceiling 	Required	Provided	MR
		Required	Provided	MR
		N/A	N/A	N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	100 mm	Provided	MR
		01	Provided	MR
		01	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	Required	Provided	MR
		01	02	MR
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	---	---	---
		2280 LPM	Provided	MR
		70 mm	Provided	MR
		Two	Provided	MR
		180 LPM	Provided	MR
		70 M	Provided	MR
		2280 LPM	Provided	MR
		70 Mts	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		-----	-----	-----
		N/A	N/A	N/A
		N/A	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet 	75000 Its	Provided	MR
		Required	Provided	MR
		Required	Provided	MR

15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	Required	Provided	MR
	• Pressurization of Lift lobby	Required	Provided	MR
	• Communication In lift Car	Required	Provided	MR
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

Keeping in view the compliance of the minimum standards of fire prevention and fire safety measures as required under the Rule 33 of the Delhi Fire Service Rules 2010, Fire Safety Certificate is recommended.

DFA is put up for approval & signature please.

[Signature]
13/11/2021
D.B Mukharjee
Divisional Officer (South West)

[Signature]
13/11/2021
P.V Rathee
Assistant Divisional Officer (SRD)

[Signature]
16/11

[Signature]
C.F.O

[Signature]
19/11

[Signature]
19/11/2021

FI PS

