

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/CGHS/NDZ/2021/ 62

Dated : 25.01.2021

**FIRE SAFETY CERTIFICATE**

Certified that the **M/s S.K. East End Party Hall at Plot No. 1 A, at grade level in Star city mall Mayur Vihar-1, Delhi-92** comprises of **Basement + Ground + 02 Upper floor (S.K East End Party Hall running at ground floor only)** respectively owned/occupied by M/s Eastend Party hall was granted FSC by this department vide letter No.F6/DFS/MS/GH/2017/NDZ/1565 dated 03/11/17. The premises was inspected by the D.O(ED) & ADO(LN) of this department on 19/01/2021 in the presence of Mr. Satish Kumar (Owner) & Mr. Nadeem (Manager) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy "**Assembly Building**" with effect from ~~-----~~ 25/10/2021 for period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on ~~-----~~ 25/01/2021 at New Delhi by.

  
25/1/21

**(Dr. S.K Tomar)**  
Dy. Chief Fire Officer  
Delhi Fire Service

Copy to:-

1. The Dy. Health Officer,  
EDMC(Health Deptt.),  
Shadhra Zone,  
Karkardooma, Shadhra, Delhi.
2. Sh. Satish Kapoor,  
M/s S.K Eastend Party Hall,  
Star city Mall, Mayur Vihar-1, Delhi-92.

**Condition for the validity of fire safety certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".



31/21

**INSPECTION REPORT**

1. Name & address of the building M/s S.K. East End Party Hall, Plt No. 1 A, Grade Level, Star City Mall, Mayur Vihar- 1, Delhi – 110092.
2. Type of occupancy:- Assembly Building (Community Hall) (Ground floor Only)
3. Type of case:- Renewal
4. Details of previous FSC:- F6/DFS/MS/GH/NDZ/2017/1565 dated 03/11/17
5. Fire safety directives No.- F6/DFS/MS/2011/2167 dated 06/09/11
6. Date of inspection:- 19/01/2020
7. Name of the inspecting officer:- Sh. Francis Brown (DO/ED) & Sh. Manoj Kumar Sharma (ADO/LN)
8. Name & designation of officer  
From the building side:- Mr. Nadeem (Manager)
9. Year of construction:- 2006
10. Applicant's letter No:- Email dated 13/01/2021

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement NBC Part-IV/ BBL	Provided at site	Remarks MR/NMR
1.	<b>Access to Building</b>			
	1) Road width	06 mtr.	06 mtr.	MR
	2) Gate width	N/A	06 mtr.	MR
	3) Width of internal road	N/A	N/A	N/A
2.	<b>Number, Width Type &amp; Arrangement of Exits</b>			
	<b>A. Number of staircases</b>			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	<b>B. Width of staircase</b>			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	<b>C. Protection of exits</b>			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	N/A	N/A	N/A
	E. Width of corridor	02 mtr.	02 mtr.	MR
	F. Door size	02 mtr.	02 mtr.	MR
3.	<b>Compartmentation</b>			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	Required	sealed	MR
	3) Fire rating of shaft door	2 hrs.	2 hrs.	MR
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	Required	Provided	MR
4.	<b>Smoke Management System</b>			
	1) Basements	30 ACPH	Provided	MR
	2) Upper floors	12 ACPH	Provided	MR
5.	<b>Fire Extinguishers</b>			
	1) Total numbers	06 Nos.	08 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR



<b>6.</b>	<b>First-Aid Hose Reel</b>			
	1) Total number of each floor	01	01	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	20 mm	20 mm	MR
<b>7.</b>	<b>Automatic Fire Detection &amp; Alarming System</b>			
	1) Type of detectors	Heat/Smoke	Provided	MR
	2) Location of main panel	Control Room	Provided	MR
	3) Location of repeater panel	Security Room	Provided	MR
	4) Alternate source of power	Battery & DG room	Provided	MR
	5) Hooter's Location	Different location	Different location	MR
<b>8.</b>	<b>MOEFA</b>	Required	Provided	MR
<b>9.</b>	<b>Public Address System</b>	Required	Provided	MR
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	1) Basement	Required	Provided in entire basement	MR
	2) Upper floors	Required	Provided	MR
	3) Sprinkler above false ceiling	Required	Provided	MR
<b>11.</b>	<b>Internal Hydrants</b>			
	1) Size of riser/down-comer	150 mm	150 mm	MR
	2) Number of hydrants per floor	01	01	MR
	3) Hose box	01	01	MR
<b>12.</b>	<b>Yard Hydrants</b>			
	1) Total number of hydrants	01	02	MR
	2) Hose box	01	02	MR
<b>13.</b>	<b>Pumping Arrangement</b>	Provided for entire star city mall building		
	1) Ground level	Required	Provided	MR
	a) Discharge of main pump	2850 LPM	2850 LPM	MR
	b) Head of main pump	70 mtrs.	70 mtrs.	MR
	c) Number of main pump	02	02	MR
	d) Jockey pump out put	180 LPM	180 LPM	MR
	e) Jockey pump head	70 mtrs.	70 mtrs.	MR
	f) Stand by pump output	2850 LPM	2850 LPM	MR
	g) Stand by pump head	70 mtrs.	70 mtrs.	MR
	h) Auto starting/Manual stopping	Required	Provided	MR
	2) Terrace level			
	a) Discharge of pump	450 LPM	450 LPM	MR
	b) Head of pump	39 mtr.	39 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
<b>14.</b>	<b>Captive Water Storage for Fire Fighting</b>			
	1) Under ground tank capacity	2,00,000 ltr.	2,00,000 ltr.	MR
	a) Draw-off connection	Required	Provided	MR
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	2,50,000 ltr.	2,50,000 ltrs.	MR
<b>15.</b>	<b>Exit Signage.</b>	Required	Provided	MR



09/23

16.	<b>Provision of Lifts.</b>			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	<b>Stand by Power Supply</b>	Required	1000 KVS	MR
18.	<b>Refuge Area</b>	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	<b>Fire Control Room</b>			
	a) Detector system panel	Required	Provided	MR
	b) Flow switch panel	Required	Provided	MR
	c) PA system panel	Required	Provided	MR
	d) Battery backup	Required	Provided	MR
	e) Building floor plan	Required	Provided	MR
20.	<b>Special Fire Protection System for Protection of special Risk, if any:</b>			NA

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

Shortcomings communicated vide letter No. F6/DFS/MS/NDZ/2021/BNQT/13 dated 04/01/2021 have been rectified.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, grant of fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended please.

Signature of the Inspecting Officer

Name :- Francis Brown  
Designation :- DO (ED) 2011

DY. CPO/NDZ

Signature of the Inspecting Officer

Name :- M.K. Sharma  
Designation :- ADO (LN)

Has short coming point no. 6. complied ?

Alomr  
2011/21

DOCEB Yes Sir, owner has completed the short-coming

In-2-of Point No-6.

DY. CPO/NDZ

Alomr  
2011