

C/70

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SCHOOL/SZ/2021/ 63

Dated: 25/01/2021

FIRE SAFETY CERTIFICATE

Certified that the building Shri Banarsidas Chandiwala Sewa Samarak Trust Society, Located at Opp Metro Station Sector-11 Dwarka new delhi 110075 comprised of Basement+ Ground + 03 Upper Floors was issued FSC vide Letter No. F6/DFS/MS/School/SZ/2017/1791 Dated 12/12/2017. The premises was re inspected by the officers concerned of this department on 12/01/2021 in the presence of Dr. Aparna Mishra (Director) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class-B "Educational" with effect from 25/01/2021 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 25/01/2021... at New Delhi by.


(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. Dr. Aparna Mishra (Director) Shri Banarsidas Chandiwala Sewa Samarak Trust Society, Located at Opp Metro station sector-11 Dwarka new delhi-110075.
2. Directorate Of Education Old Secretariat Delhi – 110054

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used strictly as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. www.dfs.delhigovt.nic.in.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: Shri Banarsidas Chandiwala Sewa Samarak Trust Society, Located at Opp Metro station sector-11 Dwarka new delhi
2. Type of Occupancy : Educational 3 Blocks (Basement +Ground + 3 Upper Floors)
3. Type of Case :Renewal
4. Details of previous NOC : F6/DFS/MS/School/SZ/2017/1791 Dated 12/12/2017
5. Fire Safety directives Letter No : F6/DFS/MS/2004/BP/243 dated 29/01/2004
6. Date of inspection : 12/01/2021
7. Name of the Inspecting Officer : DO/SW & ADO (WP)
8. Name and designation of Officer
from the building side : Dr. Aparna Mishra (Director)
9. Year of Construction : 2006
10. Applicant's letter No. : BCIPS/ADNIB/F.No.164/20-21/075 dated 11/12/2020

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirement/letter dated 15/10/2007	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	20 mtrs	Provided	MR
	• Gate width	06 mtrs	provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	3 Provided	MR
	• Basements	2+1 ramp	Provided	MR
	b. Width of staircases			
	• Upper floors	1.5m at each	1.5m each	MR
	• Basements	1.5 m	3 nos 150cm & 1 no. 120cm(Old Case)	MR(Being old case)
	c. Protection of exits			
	• Fire check door	Required in basement	Provided	MR
	• Pressurization	Required	Provided	MR
	d. No of continuous staircase to terrace	03 nos	03 nos	MR
	e. Width Of Corridor	1.5 m	Provided	MR
	f. Door Size	1 m to 1.5 m	1 m to 1.5 m(Including door frame)	MR(Old case)

3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	Required	Exhaust fans Provided	MR
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	30 nos. ABC & CO ₂ ISI marked	Provided	MR
	• Types		Provided	MR
	• IS marking		Provided	MR
6.	First - Aid Hose Reels			
	• Total numbers on each floor	3nos	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Smoke	Provided(In labs only)	MR
	• Location of Main Panel	Ground Floor	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Near Stairs	Provided	MR
8.	MOEFA	NA	NA	NA
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	3Nos.	3Nos.	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA

13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> • Ground Level • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		900 lpm & 180 lpm	900 lpm & 180 lpm	MR
		40 m	40 m	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	50000 ltr	50000 ltr	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		10000 litres at each block	10000 ltrs	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 	NA	NA	NA
		NA	NA	NA
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
17.	Standby power supply	Required	DG Set	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> ➤ Total area ➤ Location 	NA	NA	NA
		NA	NA	NA
19.	Fire control room			
	<ul style="list-style-type: none"> ➤ Detector system panel ➤ Flow Switch Panel ➤ PA System Panel ➤ Battery backup ➤ Building Floor Plans 	Required	Provided	MR
		NA	NA	NA
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR

11/20

20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	CO2 Fire Extinguisher Provided near electric panel	MR
-----	--	----	--	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no F6/DFS/MS/School/SZ/2017/1791 Dated 12/12/2017 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

[Signature]
12/01/2021

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name Uday Vir Singh
Designation ADO/DWA

Name
Designation

DO/SW

[Signature]
12/01/2021

By cfo (s2)

F.T. please.

[Signature]
A DO/DWA

Dear Sir letter is sent up for signature

Dy cfo/s2

[Signature]
23/11

[Signature]
12/01/2021

[Signature]

M.S. 4/11