


**FIRE SAFETY CERTIFICATE**

Certified that **Hahnemann Pharmaceuticals Pvt. Ltd., A-7, Naraina Industrial Area, Phase-1, New Delhi- 110028**, running in 7 rooms and one hall in a building comprised of Basement, Ground, mezzanine & two upper floors was granted NOC vide this department letter No. F.5/(3)/DFS/93/346 dated 27.09.1993. The building was re-inspected by the officer concerned of this department on 08.01.2021 in presence of Smt. Neeru Narula (Owner/Occupier) and found that the management of M/s. Hahnemann Pharmaceuticals Pvt. Ltd. have deemed complied with the fire prevention and fire safety requirements in accordance with rule as per Previous NOC No. F.5/(3)/DFS/93/346 dated 27.09.1993 and that the said building is fit for occupancy class "Industrial" with effect from 21/01/2021 for a period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 printed below.

Issued on 21/01/2021 at New Delhi by.

  
(Sunil Chaudhary)  
Dy. Chief Fire Officer (SZ)  
Delhi Fire Service

Copy to: -

1. The Manager, M/s. Hahnemann Pharmaceuticals Pvt. Ltd., A-7, Naraina Industrial Area, Phase-1, Delhi- 28.
2. The Executive Engineer(Building),North DMC, Karol Bagh Zone, Anand Parbat, New Delhi

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. Basement shall be used as per UBBL. Stilt floor shall only be used for parking.
7. All comments / directions of licensing department shall always be permitted and followed.
8. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
9. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

**INSPECTION REPORT**

1. Name & address of the building : Hahnemann Pharmaceuticals Pvt. Ltd., A- 7, Naraina  
Industrial Area Phase-1. New Delhi- 110028
2. Type of Occupancy : Business
3. Type of Case : Renewal
4. Details of previous NOC : F.5/(3)/DFS/93/346 dated 27.09.1993
5. Fire Safety directives letter No : Nil
6. Date of inspection : 08.1.2021
7. Name of the Inspecting Officers : D.B Mukharjee, DO (SW) & P.V Rathee, ADO (SRD)
8. Name and designation of officers from the building side : Smt. Neeru Narula
9. Year of Construction : Before 1993
10. Applicant's letter No. : Email ID [hahnemann99@gmail.com](mailto:hahnemann99@gmail.com) dated 27.11.2020

The building is comprised of Basement, ground, Mezzanine & two upper floors


/	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per NOC dt. 27.09.1993	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	06 mts	Provided	MR
	• Gate width	N/A	Accessible from main road	MR
	• Width of internal road	N/A	N/A	N/A
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	-	-	-
	• Upper Floors	01	01	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases	-	-	-
	• Upper Floors	N/A	0.88 to 1.18 mts	MR being old case
	• Basements	N/A	N/A	N/A
	c. Protection of exits	-	-	-
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	N/A	0.85 mts	MR
3	<b>Compartmentation.</b>			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	<b>Smoke Management System.</b>			
	• Basements	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5	<b>Fire Extinguishers</b>			
	• Total numbers	8	Provided	MR
	• Types	ABC & CO <sub>2</sub> type	Water CO <sub>2</sub> , CO <sub>2</sub> & Foam type	MR
	• IS marking	ISI marked	Provided	MR




16	<b>Provision of Lifts. Provided but not commissioned</b>			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	<b>Standby power supply</b>	N/A	N/A	N/A
18	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F.5/(3)/DFS/93 /346 dated 27.09.1993, renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended. DFA is put up for approval & signature please.

  
 D.B Mukharjee  
 Divisional Officer (SW)

  
 P.V. Rathee  
 Asstt. Div. Officer (SRD)

Dy CFO (SW)

Pl. speak an addition of floor.

A D O (S R D)