

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No.F6/DFS/MS/School/2021/52/70

Dated: 29/01/2021


FIRE SAFETY CERTIFICATE

Certified that the Building Prudence School, Located at Dwarka, Phase-II, HAF Pocket-A, Sector-16B, New Delhi-110075. comprised of Basement + Stilt/ Ground + 4 Upper Floor was issued FSC vide Letter No. F6/DFS/MS/School/2016/SZ/367 Dated 08/03/2016 (**Issued for Basement + Stilt + 5 Upper Floor**). The premises was re inspected by the officers concerned of this department on 25-01-2021 in the presence of Mr. Anil Banbah (School Representative) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class-B "Educational" with effect from 29/01/2021 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 29/01/2021 at New Delhi by.


(Atul Garg)
Director

Delhi Fire Service.


28/1/2021

Copy to:

1. The Assistant Director(Building)DDA,Vikas SadanINA, Delhi-23
2. The Commissioner, North Delhi Municipal Corporation, Civic Centre, Minto Road, New Delhi -110002
3. The Principal, Prudence School, Dwarka, Phase-II, HAF Pocket-A, Sector-16B, New Delhi-110075.
4. Directorate of Education Old Secretariat Delhi – 110054

Following fire safety directives must be adhered to:-

- 1 **The lift shall run from ground floor to upper floors.**
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 3 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 4 The trained staff should be available round the clock.
- 5 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 6 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 7 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
- 8 Basement shall be used strictly as per building bye laws.
- 9 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

Re inspection to see the compliance of shortcomings communicated vide letter no. F6/DFS/MS/School/SZ/2019/7057 dated 26/11/2019 are complied

INSPECTION REPORT

1. Name & address of the building: Prudence School, located at Dwarka, Phase-II, HAF Pocket-A, Sector-16B, New Delhi-110075.
2. Type of Occupancy : Educational (Basement + Stilt / Ground+ 4 Upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2016/SZ/367 Dated 08/03/2016(Issued for Basement + Stilt + 5 Upper Floor issued to Presidium School)
5. Fire Safety directives Letter No. : F6/DFS/MS/BP/2008/1088 Dated 15/04/2008
6. Date of inspection : 25-01-2021
7. Name of the Inspecting Officer :Udai vir singh, ADO (DWK)
8. Name and designation of Officer
from the building side : Mr. Anil Banbah (School Representative)
9. Year of Construction : 2007
10. Applicant's letter No. : Email Dated 25/01/2021

No. of Students=1276
No. of class rooms=36
Plot area=3999 m²
Covered area=2358m²

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/13	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	18 mtr	Provided	MR (being old case)
	• Gate width	05 mtr	Provided	MR (being old case)
	• Width of internal road	06 mtr	Provided (being old case)	MR (being old case)
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2 Nos.	2 Nos.	MR
	• Basements	2 Nos.	2 Nos.	MR
	b. Width of staircases			
	• Upper floors	142 cm	142 cm(including railing & skirting)	MR (being old case)
	• Basements	158 cms & Ramp	142 cms & 132cm & Ramp	MR (being old case)
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	02 Nos.	02 Nos.	MR
	e. Width Of Corridor	1.5m	Provided	MR
	f. Door Size	109 X 205 cm	109 X 205 cm	MR

3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door 	Required	Provided	MR
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	Required	Provided	MR
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	NA	NA	NA
	<ul style="list-style-type: none"> • Water Curtain 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Dampers 	NA	NA	NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements 	30 a/c charge	Exhaust fans provided	MR
	<ul style="list-style-type: none"> • Upper floors 	12 a/c charge	Natural ventilation	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	25 nos.	28 Nos. Provided	MR
	<ul style="list-style-type: none"> • Types 	ABC, CO ₂ & WCO ₂	ABC, CO ₂ & WCO ₂	MR
	<ul style="list-style-type: none"> • IS marking 	ISI marked	ISI marked	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor 	02	Provided	MR
		30	Provided	MR
	<ul style="list-style-type: none"> • Length of hose reel hose 	05 mm	Provided	MR
	<ul style="list-style-type: none"> • Nozzle diameter 			
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors 	NA	NA	NA
	<ul style="list-style-type: none"> • Location of Main Panel 	NA	Near Reception	NA
	<ul style="list-style-type: none"> • Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Alternate source of power 	Required	Provided	MR
	<ul style="list-style-type: none"> • Hooters' Location 	Appropriate place	Near Staircase	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basements 	Required	Provided	MR
	<ul style="list-style-type: none"> • Upper Floor 	NA	NA	NA
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	NA	NA	NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	100 mm	NA	NA
	<ul style="list-style-type: none"> • Number of hydrants per floor 	01	NA	NA
	<ul style="list-style-type: none"> • Hose Box 	Required	Provided	MR

12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto starting/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	900 lpm & 180 lpm	900 lpm & 180 lpm	MR
	➤ Head of the pump	30 mtr	NA	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	50000 ltrs	Provided	MR
	➤ Draw off connection	NA	Provided	MR
	➤ Fire service inlet	NA	Provided	MR
	➤ Access to tank	NA	Provided	MR
	• Overhead Tank capacity	50000 ltrs	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts (Lift Shall run from Ground to Upper Floors)			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	DG set 125 & 62.5 KVA	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR

12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto starting/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	900 lpm & 180 lpm	900 lpm & 180 lpm	MR
	➤ Head of the pump	30 mtr	NA	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	50000 ltrs	Provided	MR
	➤ Draw off connection	NA	Provided	MR
	➤ Fire service inlet	NA	Provided	MR
	➤ Access to tank	NA	Provided	MR
	• Overhead Tank capacity	50000 ltrs	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts (Lift Shall run from Ground to Upper Floors)			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	DG set 125 & 62.5 KVA	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR