

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2021/ 83

Dated: 1/2/21

FIRE SAFETY CERTIFICATE

Certified that the Divya Public School, F-1/48, Budh Vihar, Delhi-110086 comprised of Ground + Two Upper Floors owned/ occupied by Divya Public School have complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education letter no 3298-3398 dated 01.03.2011 and verified by the officer concerned of Fire Service on 21.12.2020 in the presence of **Smt. Indu Sharma (Principal)** and that the building/ premise is fit for occupancy Group B Educational with effect from ...1/2/21..... for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on 1/2/21 at New Delhi by



(Atul Garg)
DIRECTOR

Ph; 011-23414000

OLC
OK

Copy to:

1. The Principal, Divya Public School, F-1/48, Budh Vihar, Delhi-110086.
2. The Director of Education, Old Secretariat, Delhi

Conditions for validity of Fire Safety Certificate;

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form "K" is available on http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

INSPECTION REPORT

Gr.+Two upper floors

1. Name & address of the building ; Divya Public School, F-1/48, Budh Vihar, ,Delhi-110086
2. Type of Occupancy : Educational
3. Type of Case : New Case **(Gr.+Two upper floors)**
4. Details of Previous NOC : NA
5. Fire Safety directives letter No : Direction of Education dated 01/03/2011
6. Date of inspection : 21.12.2020
7. Name of Inspecting Officer : ADO (Rohini)
8. Name and designation of officers
From the building side : Smt. Indu Sharma (Principal)
9. Year of Construction : 1997
10. Applicant's letter No. : Online mail dated 09.12.2020

Plot area:200 yards

No. of class rooms-17

School is functional since 1997 proof placed at C-6

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	DOE Circular 2011	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	06 mtr	MR
	• Gate width	Accessible	Accessible	M.R
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	d. Number of staircases	NA	NA	NA
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	e. Width of staircases			
	• Upper Floor	Required	0.75 & 0.89 mtr	MR
	• Basements	NA	NA	NA
	f. Protection of exits	NA	NA	NA
	Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	01	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1 mtr	1 mtr	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural Ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	6 No's	06	MR

	<ul style="list-style-type: none"> Types IS marking 	ABC/CO2 ISI Marked	ABC Yes	MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01 30 m 5 mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA NA NA NA NA	NA NA NA NA NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground & Upper Floors Sprinkler above false ceiling 	NA NA NA	NA NA NA	NA NA NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA NA NA	NA NA NA	NA NA NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA NA	NA NA	NA NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	NA NA NA NA NA NA NA NA NA 450 LPM 40 m NA NA	NA NA NA NA NA NA NA NA NA 450 LPM 40 m NA NA	NA NA NA NA NA NA NA NA NA MR MR NA NA
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	NA NA NA NA 10000 ltr	NA NA NA NA 10000 ltr	NA NA NA NA MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car 	NA NA NA	NA NA NA	NA NA NA

	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:			

The fire protection systems provided in the building were test checked and found functional at the time of inspection.


Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

[Signature]
19/11/2021

Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO(Rohini)

DO(NW)

[Signature]
19/11/2021



[Signature]
Dy cfo (w2)

[Signature]
20/11/2021

[Signature]
cfo

[Signature]
21/11

[Signature]
21/11/2021

[Signature]

[Signature]
DU/wh

Pl. put up F.T. letter

[Signature]
25/11/2021

ADD (R)

ET letter is sent with kind personal