

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE NEW DELHI-110001**

No. F6/DFS/MS/2021/School/WZ/77

Dated: 01/02/2021

FIRE SAFETY CERTIFICATE

Certified that the Building situated at **Himalaya Public Sr. Sec. School, D-12, Sec-7, Rohini, Delhi-110085**, comprised of **Ground + Three upper floors** owned/occupied by **Himalaya Public Sr. Sec. School**, has already been issued FSC by this department vide letter No. **F6/DFS/MS/School/2017/WZ/1288 dated 28.08.2017**. The premises was re-inspected by the officer concerned of this department on **29.12.2020** in the presence of **Smt. Radha Rathnam (Administrator)** and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition. The premises have therefore deemed complied with the requirements under Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy under Educational "Group B" with effect from **01/02/2021** for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on **01/02/2021** at New Delhi by


(Atul Garg)
DIRECTOR

Ph; 011-23414000

Copy to :-

1. The Principal, Himalaya Public Sr. Sec. School, D-12, Sec-7, Rohini, Delhi-110085.
2. The Director of Education, Old Secretariat, Delhi

Conditions for validity of Fire Safety Certificate;

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form "K" is available on

http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/
http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Forms

1. Name & address of the building : Himalaya Public Sr. Sec. School, D-12, Sec-7, Rohini, Delhi-85.
2. Type of Occupancy : Educational
3. Type of Case : Renewal (**G+03 upper floors**)
4. Details of previous NOC : F6/DFS/MS/School/2017/WZ/1288 dated 28.08.2017
5. Fire Safety directives letter No : Direct. Of education circular 2005.
6. Date of inspection : 29.12.2020
7. Name of the Inspecting Officers : ADO (Rohini)
8. Name and designation of officers
from the building side : Smt. Radha Rathnam (Administrator)
9. Year of Construction : 2002
10. Applicant's letter No. : Online mail dated 02.12.2020

	Minimum Standards on fire prevention and fire safety U/R 33	Direct. Of education (2005)	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	24 m	MR
	• Gate width	Accessible	4.5m	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	03	03	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50 m	1.50m each	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	02	MR
	e. Width of Corridor	NA	NA	NA
f. Door Size	1.0m	1.2m	MR	
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	30 a/c per hour	No basement	NA
	• Upper floors	12 a/c per hour	Natural Ventilation	MR
5	Fire Extinguishers			
	• Total numbers	17nos	20 nos	MR

	<ul style="list-style-type: none"> Types ISI marking 	Yes	Yes	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor 	02	02	MR
	<ul style="list-style-type: none"> Length of hose reel hose 	30m	30m	MR
	<ul style="list-style-type: none"> Nozzle diameter 	5mm	5mm	MR
7	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors 	NA	NA	NA
	<ul style="list-style-type: none"> Location of Main Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Alternate source of power 	NA	NA	NA
	<ul style="list-style-type: none"> Hooters' Location 	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement 	NA	NA	NA
	<ul style="list-style-type: none"> Upper Floor 	NA	NA	NA
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	100mm	100mm	MR
	<ul style="list-style-type: none"> Number of hydrants per floor 	02	Provided	MR
	<ul style="list-style-type: none"> Hose Box 	02	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	<ul style="list-style-type: none"> Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	450lpm	450lpm	MR
		40m	40m	MR
		N/A	N/A	N/A
		N/A	N/A	N/A


14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	5,000ltrs	5,000ltrs	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the FSC issued vide letter no F6/DFS/MS/School/2017/WZ/1288 dated 28.08.2017 is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

Note:- the addition/alternation in the building as claimed with documentary evidence are since inspection may kindly be accepted under Rule 35(6) of 2010 by the competent authority.

Signature of the Inspecting Officer



Name:- Ajay Kumar Sharma