

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2021/ School/WZ/ 90

Dated: 2/2/21

FIRE SAFETY CERTIFICATE

Certified that **Jain Bharati Mrigavati Vidyalaya** located at , **G.T.Karnal Road Delhi-110036** comprised of Basement+Ground+02 upper floors owned/occupied by **Jain Bharati Mrigavati Vidyalaya** was issued fire safety certificate vide letter no. **F-6/DFS/MS/2018/School/167 Dated-25/01/2018**. The premises was re-inspected by the officer concerned of this department and found that the building have deemed complied with fire prevention and fire safety requirements in accordance with rule 27 of Delhi Fire Service Rule, 2010 and verified by the officer concerned of fire service on **22/12/2020** in presence of **Sh. Yogesh Kumar (Senior Incharge)** and that the building / premises is fit for occupancy **Group B (Educational)** with effect from 22/21 for a period of **three years**, in accordance with rule 36 unless under rule 37 or sooner cancelled under rule 40 subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.DelhiGovt.nic.in

Issued on ... 2/2/21 at New Delhi

(Dharampal Bhardwaj)
Dy. Chief Fire Officer
West Zone

Copy to : -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Principal , Jain Bharati Mrigavatai Vidyalaya , G.T.Karnal Road Delhi-110036.

INSPECTION REPORT

1. Name & address of the building : Jain Bharati Mrigavati Vidyalaya , G.T. Kamal Road, Delhi-110036
2. Type of Occupancy : Educational (B+Gr. + Two upper floors)
3. Type of Case : Renewal
4. Details of Previous NOC : Letter No. F.6/DFS/MS/2018/SCHOOL/167 Dated-25/01/2018
5. Fire Safety directives letter No : NBC Part-IV
6. Date of inspection : 22 /12/2020
7. Name of Inspecting Officer : ADO (BW)
8. Name and designation of officers : Sh. Yogesh Kumar (Senior Incharge)
- From the building side : 2007
9. Year of Construction : 2007
10. Applicant's letter No. : JVM/2020-21/525 , Dated-02/12/2020

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL	Provided at site	Remarks MR/NMR
1.	Access to building			MR
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	6.0 m	6.0 m	MR
		4.5 m	4 m	MR(Old case)
		NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	NA	NA	NA
	<ul style="list-style-type: none"> • Upper Floors • Basements(small basement) 	03	03	MR
		02	02	MR
	b. Width of staircases	NA	NA	NA
	<ul style="list-style-type: none"> • Upper Floor 	1.50 m	1.50 m	MR
		1.50 m	1.30m & 1.50m	MR(Old case)
	c. Protection of exits	NA	NA	NA
		NA	NA	NA
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	NA	NA	NA
		NA	NA	NA
	d. No. of continuous staircases to terrace	Required	Provided	MR
		Required	Provided	MR
	e. Width of Corridor			
		1.00 m	Provided	MR
	f. Door Size			
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
	<ul style="list-style-type: none"> • Fire Dampers 	NA	NA	NA
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements 	30 a/c per hour	Exhaust Fan	MR

	<ul style="list-style-type: none"> Upper floors 	12 a/c per hour	Natural Ventilated	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers 	25 nos	50 nos	MR
	<ul style="list-style-type: none"> Types 	ABC	ABC	MR
	<ul style="list-style-type: none"> IS marking 	Yes	Yes	MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor 	03	03	MR
	<ul style="list-style-type: none"> Length of hose reel hose 	30 m	Provided	MR
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors 	NA	NA	NA
	<ul style="list-style-type: none"> Location of Main Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Alternate source of power 	NA	NA	NA
	<ul style="list-style-type: none"> Hooters' Location 	NA	NA	NA
8.	MOEFA			
		NA	NA	NA
9.	Public Address System			
		NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement 	Required	Provided	MR
	<ul style="list-style-type: none"> Ground Floor 	NA	NA	NA
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	NA	NA	NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	100 mm	Provided	MR
	<ul style="list-style-type: none"> Number of hydrants per floor 	01	Provided	MR
	<ul style="list-style-type: none"> Hose Box 	01	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 	NA	02	NA
	<ul style="list-style-type: none"> Hose Box 	NA	02	NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> ➤ Discharge of main Pump 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Head of Main pump 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Number of main pumps 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Jockey Pump out put 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Jockey pump head 	180 lpm	180 lpm	MR
	<ul style="list-style-type: none"> ➤ Standby Pump out put 	40 m	40 m	MR
	<ul style="list-style-type: none"> ➤ Standby Pump Head 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Auto Starting/Manual Stopping 	NA	NA	NA
		NA	NA	NA

	➤ Pump House Access	NA	NA	NA
	• Terrace level	-	-	-
	➤ Discharge of pump	450 lpm	450 lpm × 02	MR
	➤ Head of the pump	40 m	40 m	MR
	➤ Power Supply	Required	Provided	MR
		-	-	-
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10000 ltrs	10000 ltrs	MR
		Required	Provided	MR
15.	Exit Signage.			
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

--	--	--	--	--

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the above deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, it is recommended for renewal of Fire Safety Certificate issued vide letter no.F6/DFS/MS/2018/School/167 , under rule 27 of the Delhi Fire Service Rules 2010.

DO (N.W)
 Rajeev
 06/01/2021
Dy CBO (W2)

Dinku ADO/B.W
 05/11/2021

Signature of Inspecting Officer

Name : Rajeev Kumar Sinha

Designation : ADO/B.W.

Put up D.F.A
 according to circular.

[Signature]
 11/11/2021

DO (N.W)
 Sir this bldg. is covered under Rule-27, therefore the D.F.A. is correct and need not ^{require} any changes.

[Signature]
 13/01/2021

Dy CBO (W2)

If it is covered under Rule-27 then check D.F.A according to NBC

[Signature]