

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE NEW DELHI-110001**


No. F6/DFS/MS/School/WZ/2021/ 96

Dated: 2/2/21

FIRE SAFETY CERTIFICATE

Certified that Certified **M. C. D. Pry. Girls/Boys School, J-Block, Mangol Puri, Delhi - 83**, comprised of **Ground + One Upper floor** owned/occupied by **M. C. D. Pry. Girls/Boys School** was issued fire safety certificate by this department vide letter no **F6/DFS/2017/School/WZ/302 dated 03.03.2017**. The premises was re-inspected by the officer concerned of this department on **06.01.2021** in the presence of **Smt. Laxmi Sharma (Principal)** and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition. The premise have deemed complied with the requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy **class "B" Educational Buildings** with effect from **2 / 2 /2021** for a period of **three years**, subject to compliance of the conditions mentioned below.

Issued on **2/2/21** at New Delhi by


(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel;-01123414250

o/c
ny

Copy to:

1. The Principal, M. C. D. Pry. Girls/Boys School, J-Block, Mangol Puri, Delhi – 83.
2. The Director of Education, GNCT of Delhi Old Secretariat, Delhi-110054.

Conditions for validity of Fire Safety Certificate;

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form']' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form "K" is available on http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

1. Name & address of the building : M. C. D. Pry. Girls/Boys School, J-Block, Mangol Puri,
Delhi - 83
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of Previous NOC : F6/DFS/2017/School/WZ/302 dated 03.03.2017
5. Fire Safety directives letter No : Direction of Education dated 01/03/2011
6. Date of inspection : 06.01.2021
7. Name of Inspecting Officer : A.K.Sharma ADO (Rohini)
8. Name and designation of officers
From the building side : Smt. Laxmi Sharma (Principal)
9. Year of Construction : 1991
10. Applicant's letter No. : Online mail dated 31.12.2020

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	DOE requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	6.0 mtr	6.0 mtr	MR
	• Gate width	4.5 mtr	3.0 mtr(old Case)	M/R
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	M.R
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	1.50 mtr	1.6 & 1.4 mtr	M.R
	• Basements	NA	NA	NA
	c. Protection of exits			
	Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	Required	2.04 mtr	M.R
	f. Door Size	1 mtr	1.12 mtr	M/R
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural ventilated	MR
5.	Fire Extinguishers			
	• Total numbers	6 No's	06 No's	MR
	• Types	ABC/CO2	ABC-6	MR

		ISI Marked	Yes	MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor 	NA	NA	NA
	<ul style="list-style-type: none"> Length of hose reel hose 	NA	NA	NA
	<ul style="list-style-type: none"> Nozzle diameter 	NA	NA	NA
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors 	NA	NA	NA
	<ul style="list-style-type: none"> Location of Main Panel 		NA	NA
	<ul style="list-style-type: none"> Location of Repeater Panel 		NA	NA
	<ul style="list-style-type: none"> Alternate source of power 		NA	NA
	<ul style="list-style-type: none"> Hooters' Location 		NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement 	NA	NA	NA
	<ul style="list-style-type: none"> Ground & Upper Floors 	NA	NA	NA
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	NA	NA	NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	NA	NA	NA
	<ul style="list-style-type: none"> Number of hydrants per floor 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hose Box 	N/A	N/A	N/A
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/Manual Stopping ➤ Pump House Access 	NA	NA	NA
	<ul style="list-style-type: none"> Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	NA	NA	MR
		NA	NA	MR
		NA	NA	MR
		NA	NA	NA
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
15.	Exit Signage.	NA	NA	NA
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft 	NA	NA	NA
	<ul style="list-style-type: none"> Pressurization of Lift lobby 	NA	NA	NA
	<ul style="list-style-type: none"> Communication In lift Car 	NA	NA	NA
	<ul style="list-style-type: none"> Fireman's Grounding Switch 	NA	NA	NA
	<ul style="list-style-type: none"> Lift Signage 	NA	NA	NA

17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:			

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F6/DFS/2017/School/WZ/302 dated 03.03.2017 is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

[Signature]
11/11/2021

Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO(Rohini)

~~DO(NW)~~ Pl. prepare DFA as per
DoE Circular

[Signature]
11/10/2021

Asst(R)

Amended DFA is put up for kind perusal and
approval please.

[Signature]
18/11/2021

~~DO(NW)~~

[Signature]
19/10/2021

~~Asst(R)~~

[Signature]
20/11/2021

Asst(Rohini)

FT letter is put up for kind
perusal and signature please