

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No. F.6/DFS/MS/Indl./2021/SZ/

79

Dated:

01/02/2021

FIRE SAFETY CERTIFICATE

Certified that M/s Munna Lal Ram Dayal, Plot no. A-188 Okhla Industrial Area, Phase-I, New Delhi-110020 comprised of Basement, Ground plus two upper floors owned/occupied by M/s Munna Lal Ram Dayal, was granted FSC by this department vide letter No. F6/DFS/MS/Indl./2016/SZ/142 dated 20/01/2016. The premises was re-inspected by officer concerned of this department on 25/01/2021 in the presence of Mr. Virender Singh Negi (Authorize Signatory) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules Act-2007 & Rules- 2010 and that premises/building is fit for occupancy class "Industrial" effect from 01/02/2021 for a period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued 01/02/2021 at New Delhi by

(Sunil Chawdhary)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Authorized Signatory, Sh. Virendra Singh Negi , A-188 Okhla Industrial Area Phase-I, New Delhi-110020.
2. The executive Engineer (Bldg.)-I, SDMC, 8th floor, Civic Centre, Minto Road, New Delhi-110002.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & Address of the Building	M/s Munna Lal Ram Dayal, Plot no. A-188, Okhla Industrial Area, Phase-I, New Delhi-110020		
2	Type of Occupancy	Industrial "Group-G"		
3	Building Comprised of	Basement + Ground + 2 Upper Floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/Indl/2016/SZ/142 dated 20/01/2016		
6	Fire Safety Directives Letter No	F.6/DFS/MS/BP/2010/1038 dated 12/04/2010		
7	Date of Inspection	25/01/2021		
8	Name of the Inspecting Officers	ADO Avtar Singh		
9	Name & Designation of Officers from the building side	Mr. Virender Singh Negi (Authorize Signatory)		
10	Year of construction	2010		
11	Applicant letter No.	Email dated 19/01/2021		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	As Per Old NOC	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	09 m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	-N/A-	-N/A-	-N/A-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors	02 nos	Provided	MR
	➤ Basement floors	02 nos	Provided	MR
	b) Width of Staircase			
	➤ Upper floors	1.5 m	Provided	MR
	➤ Basement floors	1.5 m	Provided	MR
	c) Protection of exits			
	➤ Fire check door	Required	Provided	MR
	➤ Pressurization	-N/A-	-N/A-	-N/A-
	d) No. of continuous staircase to terrace	02 nos	Provided	MR
	e) Width of corridor	-N/A-	-N/A-	-N/A-
	f) Door size	1 m	1 mtr	MR
3	Compartmentation.			
	• Fire check door.	Required	Provided	MR
	• Sealing of electrical shafts.	Required	Provided	MR
	• Fire rating of shaft door.	-N/A-	-N/A-	-N/A-
	• Water curtain	-N/A-	-N/A-	-N/A-
	• Fire dampers.	Required	Provided	MR
4.	Smoke Management system.			
	• Basement	30 ACPH	Provided	MR
	• Upper floors	12 ACPH	Provided	MR
5.	Fire Extinguishers.			
	• Total numbers	IS:2190	15 nos	MR
	• Types	ABC / CO ₂ / W.CO ₂	10/3/2	MR
	• ISI Marking	ISI Marked	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor	1 nos	Provided	MR
	• Length of hose-reel hose.	30 m	Provided	MR

7	Automatic fire detection & alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	Smoke & Heat	Provided	MR
		Ground Floor	Ground Floor	MR
		-N/A-	-N/A-	-N/A-
		Required	Provided	MR
		All Area	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	-N/A-	-N/A-	-N/A-
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement. Upper floors Sprinkler above false ceiling 	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser / Down-comer Number of Hydrant per floor Hose box. 	100mm	Provided	MR
		1 nos	Provided	MR
		1 nos	Provided	MR
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	Required	2 nos	MR
		Required	2 nos	MR
13.	Pumping arrangements.			
	• Ground Level			
	➤ Discharge of main pump.	2280 LPM	Provided	MR
	➤ Head of main pump	70 m	Provided	MR
	➤ Number of main pumps	1 Nos	Provided	MR
	➤ Jockey Pump output.	180 LPM	Provided	MR
	➤ Jockey Pump head.	70 m	Provided	MR
	➤ Standby Pump output.	2280 LPM	Provided	MR
	➤ Standby Pump head.	70 m	Provided	MR
	➤ Auto Starting/Manual stopping	Required	Provided	MR
	➤ Pump house access. Auto	Required	Provided	MR
	• Terrace Level			
	➤ Discharge of pump.	900 LPM	Provided	MR
	➤ Head of pump.	40 m	Provided	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14.	Captive water storage for firefighting.			
	<ul style="list-style-type: none"> Underground tank capacity. <ul style="list-style-type: none"> ➤ Draw-off connection. ➤ Fire Service Inlet. ➤ Access to tank. 	1,00,000 ltrs	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
	<ul style="list-style-type: none"> Overhead tank capacity. 	20,000 ltrs	20,000 ltrs	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-

17	Standby Power Supply	Required	Provided	MR
18.	Refuge Area			
	• Total area	-N/A-	-N/A-	-N/A-
	• Location	-N/A-	-N/A-	-N/A-
19.	Fire Control Room.			
	• Detector System Panel.	-N/A-	-N/A-	-N/A-
	• Flow Switch Panel.	-N/A-	-N/A-	-N/A-
	• PA system Panel.	-N/A-	-N/A-	-N/A-
	• Battery backup	-N/A-	-N/A-	-N/A-
	• Building floor plan	-N/A-	-N/A-	-N/A-
20.	Special Fire Protection System for the Protection of special Risk, if any.			-N/A-

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

The shortcoming communicated vide letter no. F6/DFS/MS/SZ/2021/68 dated 11/01/2021 found complied.

Keeping in view of the substantial compliance of the minimum standards of fire prevention and fire safety measures as required under the rules of NOC issued vide letter no. F.6/DFS/MS/Indl/2016/SZ/142 dated 20/01/2016, renewal under rule 37 of the Delhi Fire Service rule 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

(Signature)
29/01/2021

Signature of the Inspecting Officer
Name : Avtar Singh
Designation: ADO (MR)

~~DO (SD)~~

(Signature)
30/01/21

Fit. please

Dy. C.F.O. (S2)

(Signature)

FT letter is put up for sign please

(Signature)
30/01/2021

Dy. C.F.O. (S2)

(Signature)