

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/School/WZ/2020/ 94

Dated: 2 /02/2020

FIRE SAFETY CERTIFICATE

Certified that the **Rukmini Devi Public School**, Located at **CD-Block, Pitampura, Delhi-110034**, comprised of **Basement + Ground + 02 Upper Floors** was issued FSC by this department Vide Letter No. **F6/DFS/MS/SCHOOL/2017/WZ/1600 Dated 09-11-2017**. The said premise was re inspected by the officer concerned of this department on 31.12.2020 in the presence of **Ms. Anajli Kotnala (Principal)**, and found that the premises / building have deemed complied with the fire prevention and fire safety requirements in accordance D.O.E Cir. No. 262-362 dated 17-01-2005 and found that the premises/building is fit for occupancy class "Educational" Group B with effect from 2/2/21 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on 2/2/21..... at New Delhi by.

DL

(DharampalBhardwaj)
Dy. Chief Fire Officer
(West Zone)

Copy to: -

1. The Director, Directorate of Education Old Secretariat Delhi – 110054.
2. The Principal, Rukmini Devi Public School, CD-Block, Pitampura, Delhi-110034.

1. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
3. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye laws.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules-2010. The form is available on www.dfs.delhigovt.nic.in
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in
7. Extra constriction if any, not removed fully the Fire Safety Certificate shall be null and void.

4/24
INSPECTION REPORT

1. Name & address of the building: **Rukmini Devi Public School, CD Block, Pitampura, Delhi – 110034.**
2. Type of Occupancy : Educational (Basement + Ground + 2 Upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC:F6/DFS/MS/SCHOOL/2017/WZ/1600 Dated 09-11-2017
5. Fire Safety directives Letter No. : D.O.E Cir. 262-362 dated 17-01-2005
6. Date of inspection : 31.12.2020
7. Name of the Inspecting Officer : S.P. Bhardwaj ADO (WP)
8. Name and designation of Officer
from the building side : Ms. Anajli Kotnala (Principal)
9. Year of Construction : 1988
10. Applicant's letter No. : 20/12/RDPS/103 Dated 19-12-2020

S No	Minimum standards on fire prevention and fire safety U/R 33	D.O.E. Cir.No.262-362 dated 17-01-2005	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	380cm Provided	MR (Old Case)
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	6 Provided	MR
	• Basements	2	3 Provided	MR
	b. Width of staircases			
	• Upper floors	1.5m	2x166cm, 2x136cm, 1x197cm, 1x90cm	MR
	• Basements	1.5m	1x137cm, 1x144cm, 1x122cm	MR (Old Case)
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	1	Provided	MR
	e. Width Of Corridor	1.5m	253cm	MR
	f. Door Size	1m	110cm	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA



M/25

4.	Smoke managements System			
	<ul style="list-style-type: none"> Basements Upper floors 	Required	Exhaust Fans Provided	MR
		NA	NA	NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	38 nos. ABC & CO ₂ ISI marked	Provided Provided Provided	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	Required 30m 5mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Required in Auditorium & Lecture room Required NA Required Required	Provided Provided at GF NA Provided Provided at Strategic location	MR MR NA MR MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	Required NA NA	Provided NA NA	MR NA NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	100 mm Required Required	Provided Provided Provided	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA NA	Provided Provided	NA NA
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	NA NA NA NA NA NA NA NA NA NA 2x450 lpm&2x180 lpm 40Mtr Required Required	NA NA NA NA NA NA NA NA NA NA Provided Provided Provided Provided	NA NA NA NA NA NA NA NA NA NA MR MR MR MR

[Signature]

4/26

14.	Captive water Storage for firefighting:			
	• Underground tank capacity	NA	50,000 ltrs	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	Provided	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	5,000Ltr	15,000 ltrs	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection. Shortcomings vide letter no. F6/DFS/MS/WZ/2020/683 dated 15/01/2020 found rectified.

In view of the deemed compliance of minimum standards of fire prevention and fire safety requirements as per D.O.E. Cir 262-362 dated 17-01-2005 renewal of Fire Safety Certificate issued vide letter no.F6/DFS/MS/SCHOOL/2017/WZ/1600 Dated 09-11-2017 under rule 36 of the Delhi Fire Service Rules 2010 under the DFS Act 2007 is recommended.

[Signature]
 Signature of the Inspecting Officer
 Name: S.P. Bhardwaj
 Designation: ADO (WP)
 11/1/2021

~~DO1 West~~
[Signature]
 04/01/2021

~~DO1 (WZ)~~

Is extra construction is fully removed

[Signature]
 13/1/2021

~~DO1 West~~

[Signature]
 14/1/2021

54,
 (WEST)/13
 ED. 04/01/20
 14/01/2021