

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001


No. F.6/DFS/MS/School/2021/SZ/ 82

Dated: ...1/2/21

FIRE SAFETY CERTIFICATE

Certified that the **S.D.M.C Primary Co-Ed., School, Masihgarh (Central Zone) New Delhi** comprised of **Ground plus one upper floor only** was granted FSC by this department vide letter No. F.6/DFS/MS/School/2017/SZ/210 dated 10/02/2017. The premises was re-inspected by officer concerned of this department on 28/01/2021 in the presence of Mrs. Fozia Malik (Principal) of the school and found that said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by Director of Education Govt. of NCT of Delhi, and that the school building is fit for occupancy class "**Education Building**", **Group-B** as above with effect from ...1/2/21..... for a period of **Three Years** in accordance with rule 36 unless renewed under rule37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule38 of the Delhi Fire Service Rules, 2010.

Issued on 1/2/21 at New Delhi by


Sunil Chawdhary
Dy. Chief Fire Officer
Delhi Fire Service



Copy to: -

1. The Principal, S.D.M.C Primary Co-Ed., School, Masihgarh (Central Zone) New Delhi.
2. Directorate of Education, South MCD, Civic Centre, Minto Road, New Delhi-110002.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This Certificate cannot be treated as regularization of unauthorized construction, if any.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in.
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & Address of the Building	S.D.M.C Primary Co-Ed., School, Masihgarh, New Delhi-110025		
2	Type of Occupancy	Educational Building "Group-B" (School)		
3	Building Comprised of	Ground + 01 upper floor		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/School/2017/SZ/210 dated 10/02/2017		
6	Fire Safety Directives Letter No	F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011		
7	Date of Inspection	28/01/2021		
8	Name of the Inspecting Officers	ADO Avtar Singh		
9	Name & Designation of Officers from the building side	Mrs. Fozia Malik (Principal)		
10	Year of construction	2012		
11	Applicant letter No.	Email dated 27/01/2021		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old FSC Dt. 31/05/2012 Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<ul style="list-style-type: none"> Accessible NA NA 	<ul style="list-style-type: none"> 9 mtr NA N/A 	<ul style="list-style-type: none"> MR NA NA
2	Number, width, type & arrangement of exits			
	a) Number of Staircase			
	➤ Upper floors	One	Two	MR
	➤ Basement floor	N/A	N/A	N/A
	b) Width of Staircase			
	➤ Upper floors	1.50 m	1.55 m each	MR
	➤ Basement floor	N/A	N/A	N/A
	c) Protection of exits			
	➤ Fire check door	N/A	N/A	N/A
	➤ Pressurization	N/A	N/A	N/A
	d) No. of continuous staircase to terrace	N/A	N/A	N/A
	e) Width of corridor	N/A	N/A	N/A
	f) Door size	1 mtr	1 mtr	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door. • Sealing of electrical shafts. • Fire rating of shaft door. • Water curtain • Fire dampers. 	<ul style="list-style-type: none"> N/A N/A N/A N/A NA 	<ul style="list-style-type: none"> N/A N/A N/A N/A NA 	<ul style="list-style-type: none"> N/A N/A N/A N/A NA
4.	Smoke Management system.			
	<ul style="list-style-type: none"> • Basement • Upper floors 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA Natural Ventilation 	<ul style="list-style-type: none"> N/A N/A
5.	Fire Extinguishers.			
	<ul style="list-style-type: none"> • Total numbers • Types • ISI Marking 	<ul style="list-style-type: none"> 06 no's Fire Extinguisher's ISI marked 	<ul style="list-style-type: none"> 06 nos ABC-06 Provided 	<ul style="list-style-type: none"> MR MR MR
6.	First Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor. 	<ul style="list-style-type: none"> N/A N/A 	<ul style="list-style-type: none"> N/A N/A 	<ul style="list-style-type: none"> N/A N/A


	<ul style="list-style-type: none"> Length of hose-reel hose. Nozzle Diameter 	N/A	N/A	N/A
7	Automatic fire detection & alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	N/A	N/A	N/A
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box. 	N/A	N/A	N/A
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	N/A	N/A	N/A
13.	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main pump. Head of main pump. Number of main pumps. Jockey Pump output. Jockey Pump head. Standby Pump output. Standby pump head. Auto Starting/Manual Stopping. Terrace Level <ul style="list-style-type: none"> Discharge of pump. Head of pump. Power supply. Auto starting of pump. 	N/A	N/A	N/A
14.	Captive water storage for Fire Fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. <ul style="list-style-type: none"> Draw-off connection. Fire Service Inlet. Access to tank. Overhead tank capacity. 	N/A	N/A	N/A
15.	Exit Signage.	N/A	N/A	N/A
16.	Provisions of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	N/A	N/A	N/A
17	Standby Power Supply	N/A	N/A	N/A
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	N/A	N/A	N/A
19.	Fire Control Room.			

	• Detector System Panel.	N/A	N/A	N/A
	• Flow Switch Panel.	N/A	N/A	N/A
	• PA system Panel.	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for the Protection of special Risk, if any.	N/A	N/A	N/A

The Fire protection systems provided in the premises were checked / operated at random and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the DOE circular dated 01/03/2011, FSC issued vide letter No. F.6/DFS/MS/School/2017/SZ/210 dated 10/02/2017, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.



29/01/2021

Signature of the Inspecting Officer
Name : Avtar Singh
Designation: ADO (M.RD)

DO (SD)

Handwritten notes:
F.T. P. Letter
29/01
D.F.O. (S2)
A DO (MAD)

Handwritten note: F.T. letter is put up for signature please


30/01/2021

Handwritten notes:
D.F.O. (S2)
M.S.