

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[See sub-rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No.F.6/DFS/MS/School/SZ/2021/ 97

Dated: 03/02/2021

FIRE SAFETY CERTIFICATE

Certified that the Springdales School located at Benito Juarez Marg, Dhaula Kuan, New Delhi-110021, comprised of Basement (Storage only), Ground & Three Upper Floors only owned / occupied by Springdales School, has already been issued Fire Safety Certificate Vide letter No. F6/DFS/MS/2017/SZ/1464 dated 06/10/2017. The premises was re-inspected by the officer concerned of Fire Service on 23.01.2021 in the presence of Smt. Ritu Madan (Principal) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with Directorate of Education, Circular No. 262-362 dated 17.01.2005 and that the building / premises is fit for occupancy class-B Educational with effect from 03 / 02 /2021 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on 03/02/2021 **at New Delhi by.**


(SUNIL CHAWDHARY),
DY. CHIEF FIRE OFFICER (SZ).


Copy to :-

1. The Principal, Springdales School located at Benito Juarez Marg, Dhaula Kuan, New Delhi-21.
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi-110054.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

1. Name & address of the building: **Springdales School, Dhaula Pura Marg, Dhaula Pura, New Delhi-110021.**
2. Type of Occupancy : **Educational**
3. Type of Case : **Renewal**
4. Details of previous NOC : **F6/DFS/MS/2017/SZ/1464 dated 06/10/2017**
5. Fire Safety directives Letter No.: **DOE circular dated 17/01/2005**
6. Date of inspection : **23/01/2021**
7. Name of the Inspecting Officer : **A.D.O.(S.J.)**
8. Name and designation of Officer from the building side : **Smt. Ritu Madan (Principal)**
9. Year of Construction : **2006**
10. Applicant's letter No. : **1335/20 dated 16/12/2020**

Basement + Ground + Three
Upper Floors (Two Blocks) Only

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE circular dated 17/01/2005 Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Required	12m	MR
	• Gate width	Required	5 mtr	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	Required	1 in 1 st Block 3 in 2 nd Block	MR (Old Case)
	• Basements	Required	1 (each Basement)	MR (Old Case)
	b. Width of staircases			
	• Upper floors	1.50 mtr & 75 cm	1.35m(1 st Blk) 1.75m, 1.30m & 1.50m (2 nd Blk)	MR (Old Case)
	• Basements	1.50 mtr & 75 cm	80cm (1 st Blk) 1.40m (2 nd Blk)	MR (Old Case)
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	Required	1 in 1 st Block 2 in 2 nd Block	MR
	e. Width Of Corridor	N/A	N/A	N/A
	f. Door Size	1.00 mtr	1.00 mtr	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers			
4.	Smoke managements System			
	• Basements	Required	Exhaust Fan	MR
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	40	40	M/R
	• Types	ISI marked ABC/CO ₂	Provided	M/R
	• IS marking	Required	Provided	M/R

	<ul style="list-style-type: none"> Total numbers on each floor 	1 in 1 st Block 2 in 2 nd Block	1 in 1 st Block 2 in 2 nd Block	MR
	<ul style="list-style-type: none"> Length of hose reel hose 	30 Mtr.	30 Mtr.	MR
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm	5 mm	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detector 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location of Main Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location of Repeater Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Alternate source of power 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hooters' Location 	N/A	N/A	N/A
8.	MOEFA	N/A	Provided	N/A
9.	Public Address System	N/A	Provided	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements 	Required	Provided	M/R
	<ul style="list-style-type: none"> Upper Floor 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	N/A	N/A	N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	N/A	100mm	N/A
	<ul style="list-style-type: none"> Number of hydrants per floor 	N/A	1 in 1 st Block & 2 in 2 nd Block	N/A
	<ul style="list-style-type: none"> Hose Box 	N/A	1 in 1 st Block & 2 in 2 nd Block	N/A
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hose Box 	N/A	N/A	N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level 	N/A		
	<ul style="list-style-type: none"> Discharge of main pump 	N/A	N/A	
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Staring/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	<ul style="list-style-type: none"> Terrace level 			
	➤ Discharge of pump	450 LPM (each) x 2	450 LPM (each) x 3	MR
	➤ Head of the pump	40 mtr (Each)	40 mtr (each)	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity 	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	Required	Provided	M/R
	➤ Access to tank	N/A	N/A	N/A

N/15

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

Note:-General requirements for schools as per Director of Education circular dated 17/01/2005.

1. Escape routeClear.....
2. LPG cylinders in laboratoriesNil.....
3. Electric wiring ...Conduit Wiring..... MCB and ELCB
4. Electric meter boardNot under the staircase.....
5. Basement use as per BBL 1983NA.....
6. Emergency telephone no. boardDisplayed.....
7. Generator setNil.....

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. **F6/DFS/MS/2017/SZ/1464 dated 06/10/2017** renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

~~DO(SD)~~

Imp
27/01

D40(2)

[Handwritten signature]

F.T. please

[Signature]
25/01/2021
Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : A.D.O. (S.J.)

F.T. is added pl.