

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001


No. F.6/DFS/MS/School/2021/SZ/ 78

Dated: 1/2/2021

FIRE SAFETY CERTIFICATE

Certified that **St. Giri Public School** located at **Between Block- A & B, Pocket-B, Sarita Vihar, New Delhi-110044** comprised of **Ground plus three upper floors** was granted FSC by this department vide letter No. F.6/DFS/MS/School/2017/SZ/1546 dated 27/10/2017. The premises was re-inspected by officer concern of this department on 18/01/2021 in the presence of Mr. Kuldeep Singh of the school and found that said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular. 262-362 dated 17/01/2005 and that the building/premises is fit for occupancy class "**Educational Building**" Group-B, as above with effect from ...1.../2.../21..... for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 1/2/21 at New Delhi by


(Sunil Chawdhary)
Dy. Chief Fire Officer
Delhi Fire Service



Copy to: -

1. The Principal, St. Giri Public School located at Between Block- A & B, Pocket-B, Sarita Vihar, New Delhi-110044
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This Certificate cannot be treated as regularization of unauthorized construction, if any.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in.
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

| | | | | |
|----|-------------------------------------------------------|---------------------------------------------------------------------------------------|--|--|
| 1 | Name & Address of the Building | St. Giri Public School, Between A & B Block, Pocket-B, Sarita Vihar, New Delhi-110044 | | |
| 2 | Type of Occupancy | Group-B, "Educational Building" (School) | | |
| 3 | Building Comprised of | Ground plus three upper floors | | |
| 4 | Type of Case | Renewal | | |
| 5 | Details of Previous NOC | F.6/DFS/MS/School/2017/SZ/1546 dated 27/10/2017 | | |
| 6 | Fire Safety Directives Letter No | DOE Circular no. 262-362 dated 17/01/2005 | | |
| 7 | Date of Inspection | 18/01/2021 | | |
| 8 | Name of the Inspecting Officers | ADO Avtar Singh | | |
| 9 | Name & Designation of Officers from the building side | Mr. Kuldeep Singh | | |
| 10 | Year of construction | 2004 | | |
| 11 | Applicant letter No. | Outdoor Diary no. 9794 dated 11/12/2020 | | |

| S. No | Minimum standards on Fire Prevention and Fire Safety U/R 33 | Old NOC Requirements | Provided at Site | Remarks MR/NMR |
|-------|-------------------------------------------------------------|----------------------|------------------|----------------|
|-------|-------------------------------------------------------------|----------------------|------------------|----------------|

| | | | | |
|----------|------------------------------------------------------------------------------------------------------------------------|--------------|----------|-------|
| 1 | Access to Building. | | | |
| | <ul style="list-style-type: none"> • Road width • Gate width • Width of internal road | Approachable | 6 m | MR |
| | | 5 m | Provided | MR |
| | | -N/A- | -N/A- | -N/A- |

2 Number, width, type & arrangement of exits.

| | | | | |
|-----------|-----------------------------------------------|-----------------|---------------|---------------|
| a) | Number of Staircase | | | |
| | ➤ Upper floors | 02 nos | 02 nos | MR |
| | ➤ Basement floor | -N/A- | -N/A- | -N/A- |
| b) | Width of Staircase | | | |
| | ➤ Upper floors | 1.50 m / 0.75 m | 1.25 & 1.27 m | MR (Old case) |
| | ➤ Basement floor | -N/A- | -N/A- | -N/A- |
| c) | Protection of exits | | | |
| | ➤ Fire check door | -N/A- | -N/A- | -N/A- |
| | ➤ Pressurization | -N/A- | -N/A- | -N/A- |
| d) | No. of continuous staircase to terrace | Required | 02 nos | MR |
| e) | Width of corridor | -N/A- | -N/A- | -N/A- |
| f) | Door size | -N/A- | -N/A- | -N/A- |

3 Compartmentation.

| | | | | |
|--|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------|-------|-------|
| | <ul style="list-style-type: none"> • Fire check door. • Sealing of electrical shafts. • Fire rating of shaft door. • Water curtain • Fire dampers. | -N/A- | -N/A- | -N/A- |
| | | -N/A- | -N/A- | -N/A- |
| | | -N/A- | -N/A- | -N/A- |
| | | -N/A- | -N/A- | -N/A- |
| | | -N/A- | -N/A- | -N/A- |

4. Smoke Management system.

| | | | | |
|--|--------------------------------------------------------------------------------------|---------|----------|-------|
| | <ul style="list-style-type: none"> • Basement • Upper floors | 30 ACPH | -N/A- | -N/A- |
| | | 12 ACPH | Provided | MR |

5. Fire Extinguishers.

| | | | | |
|--|-----------------------------------------------------------------------------------------------------------|-----------------------|------------------------------|----|
| | <ul style="list-style-type: none"> • Total numbers • Types • ISI Marking | 10 nos | 10 nos | MR |
| | | ABC / CO ₂ | ABC-08 , CO ₂ -02 | MR |
| | | ISI Marked | Provided | MR |

6. First Aid Hose Reels.

| | | | | |
|--|----------------------------------------------------------------------------------|-----|----------|----|
| | <ul style="list-style-type: none"> • Total numbers on each floor. | Two | Provided | MR |
|--|----------------------------------------------------------------------------------|-----|----------|----|

| | | | | |
|-----|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------|-------------|-------|
| | <ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location | -N/A- | -N/A- | -N/A- |
| | | -N/A- | -N/A- | -N/A- |
| | | -N/A- | -N/A- | -N/A- |
| | | -N/A- | -N/A- | -N/A- |
| | | -N/A- | -N/A- | -N/A- |
| 8. | MOEFA | -N/A- | -N/A- | -N/A- |
| 9. | Public Address System | Required | Provided | MR |
| 10. | Automatic Sprinkler System | | | |
| | <ul style="list-style-type: none"> Basement. Upper floors Sprinkler above false ceiling | -N/A- | -N/A- | -N/A- |
| | | -N/A- | Two | -N/A- |
| | | -N/A- | -N/A- | -N/A- |
| 11. | Internal Hydrants. | | | |
| | <ul style="list-style-type: none"> Size of Riser / Down-comer Number of Hydrant per floor Hose box. | 100 mm | Provided | MR |
| | | One | Provided | MR |
| | | One | Provided | MR |
| 12. | Yard Hydrants. | | | |
| | <ul style="list-style-type: none"> Total number of hydrants. Hose box. | -N/A- | -N/A- | -N/A- |
| | | -N/A- | -N/A- | -N/A- |
| 13. | Pumping arrangements. | | | |
| | <ul style="list-style-type: none"> Ground Level | | | |
| | Discharge of main pump. | -N/A- | -N/A- | -N/A- |
| | ➤ Head of main pump. | -N/A- | -N/A- | -N/A- |
| | ➤ Number of main pumps. | -N/A- | -N/A- | -N/A- |
| | ➤ Jockey Pump output. | -N/A- | -N/A- | -N/A- |
| | ➤ Jockey Pump head. | -N/A- | -N/A- | -N/A- |
| | ➤ Standby Pump output. | -N/A- | -N/A- | -N/A- |
| | ➤ Standby Pump head. | -N/A- | -N/A- | -N/A- |
| | Auto Starting/Manual stopping. | -N/A- | -N/A- | -N/A- |
| | ➤ Pump house access. | -N/A- | -N/A- | -N/A- |
| | <ul style="list-style-type: none"> Terrace Level | | | |
| | ➤ Discharge of pump. | 450 LPM | 450 LPM | MR |
| | ➤ Head of pump. | 40 m | 40 m | MR |
| | ➤ Power supply. | Required | Provided | MR |
| | ➤ Auto starting of pump. | Required | Provided | MR |
| 14. | Captive water storage for firefighting. | | | |
| | <ul style="list-style-type: none"> Underground tank capacity. ➤ Draw-off connection. ➤ Fire Service Inlet. ➤ Access to tank. Overhead tank capacity. | 50,000 ltrs | 50,000 ltrs | MR |
| | | Required | Provided | MR |
| | | Required | Provided | MR |
| | | Required | Provided | MR |
| | | 10,000 ltrs | 10,000 ltrs | MR |
| 15. | Exit Signage. | Required | Provided | MR |
| 16. | Provision of Lifts. | | | |
| | <ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. | -N/A- | -N/A- | -N/A- |
| | | -N/A- | -N/A- | -N/A- |
| | | -N/A- | -N/A- | -N/A- |
| | | -N/A- | -N/A- | -N/A- |
| | | -N/A- | -N/A- | -N/A- |
| | | Required | Provided | MR |

| | | | | |
|-----|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------|-------|-------|
| | <ul style="list-style-type: none"> Total area Location | -N/A- | -N/A- | -N/A- |
| 19. | Fire Control Room. | | | |
| | <ul style="list-style-type: none"> Detector System Panel. Flow Switch Panel. PA system Panel. Battery backup Building floor plan | -N/A- | -N/A- | -N/A- |
| 20. | Special Fire Protection System for the Protection of special Risk, if any. | -N/A- | -N/A- | -N/A- |

The fire protection system provided in the building was test checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rule, FSC issued vide letter No F.6/DFS/MS/School/2017/SZ/1546 dated 27/10/2017, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

[Signature]
28/01/2021

Signature of the Inspecting Officer
Name : Avtar Singh
Designation: ADO (MR)

DO (SD)

[Signature]
28/01
F. f. p case

DeFO (S2)
[Signature]
25/1

[Signature]
A D O (M R)

[Signature]

F1 letter is put up for sign please

[Signature]
28/01/2021

DCFO (S2)
[Signature]

[Signature]
M.S. Ull