

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No. F.6/DFS/MS/Indl./2021/SZ/ 81

Dated: 01/02/2021

FIRE SAFETY CERTIFICATE

Certified that the M/s T & T Motors Pvt. Limited situated at GA-2, Block B-1 Extension MCIE, Mathura Road, New Delhi-110044 comprised of 2 tier Basement + Ground + 2 Upper floors has already issued FSC by this department vide letter No F.6/DFS/MS/Industrial/SZ/2018/239 dated 12/02/2018. The premises was re-inspected by officer concerned of this department on 25/01/2021 in the presence of Mr. Harinder Singh (Maintenance Incharge) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules Act-2007 & Rules- 2010 and that premises/building is fit for occupancy class "Industrial" effect from 01/02/2021 for a period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued 01/02/2021 at New Delhi by



(Sunil Chawdhary)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to: -

1. M/s T & T Motors Pvt. Limited situated at GA-2, Block B-1 Extension MCIE, Mathura Road, New Delhi-110044
2. The executive Engineer (Bldg.)-I, SDMC, 8th floor, Civic Centre, Minto Road, New Delhi-110002.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

1	Name & Address of the Building	T & T Motors Pvt. Limited , GA-2, Block B-1 Extension MCIE, Mathura Road, New Delhi-110044
2	Type of Occupancy	Group-G (Industrial)
3	Building Comprised of	2 tier Basement + Ground + 2 Upper floors
4	Type of Case	Renewal
5	Details of Previous NOC	F.6/DFS/MS/Industrial/SZ/2018/239 dated 12/02/2018
6	Fire Safety Directives Letter No	F6/DFS/MS/BP/2009/696 dated 09/06/2009
7	Date of Inspection	25/01/2021
8	Name of the Inspecting Officers	ADO Avtar Singh
9	Name & Designation of Officers from the building side	Mr. Harinder Singh (Maintenance Incharge)
10	Year of construction	2006-07
11	Applicant letter No.	Email dated 23/01/2021

S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	BBL/NBC Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	➤ Road width	9 m	Provided	MR
	➤ Gate width	5 m	Provided	MR
	➤ Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	Three	Provided	MR
	➤ Basement floor.	Three	Two	MR (point 2 of N/5)
	b) Width of Staircase			
	➤ Upper floors	1.2 m	1.5 m, 1.37 m, 1.35 m	MR
	➤ Basement floor	1.2 m	1.35 m & 1.37 m	MR
	c) Protection of exits			
	➤ Fire check door	Required	Provided	MR
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	Three	Provided	MR
	e) Width of corridor	1.5 m	Provided	MR
	f) Door size	1 m	1 m (Final exit)	MR
3	Compartmentation.			
	• Fire check door.	Required	Provided	MR
	• Sealing of electrical shafts.	Required	Provided	MR
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	Required	Not Provided	MR(old case)
	• Fire dampers.	Required	Provided	MR
4.	Smoke Management system.			
	• Basement	30 ACPH	M.V Provided	MR
	• Upper floors	12 ACPH	Natural ventilation	MR
5.	Fire Extinguishers.			
	• Total numbers	16 Nos	20 nos ✓	MR
	• Types	ABC/W.CO ₂ /CO ₂	8/8/4	MR
	• ISI Marking	ISI marked	CO ₂ -10Nos	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor	Two	Provided ✓	MR
	• Length of hose reel hose	30m	Provided	MR

7	Automatic fire detection & alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	Smoke & Heat Entrance Lobby -NA- Required Every floor	Provided Provided -NA- Provided Provided	MR MR -NA- MR MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	-NA-	NA-	-NA-
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement. Ground & Above floors Sprinkler above false ceiling 	Required Required -NA-	Provided Provided -NA-	MR MR -NA-
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser / Down-comer Number of Hydrant per floor Hose box. 	100 mm Two Two	100mm Provided Provided	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose box 	Required Required	04 nos 04 nos	MR MR
13.	Pumping arrangements.			
	• Ground Level			
	<ul style="list-style-type: none"> ➤ Discharge of main pump. ➤ Head of main pump. ➤ Number of main pumps. ➤ Jockey Pump output. ➤ Jockey Pump head. ➤ Standby Pump output. ➤ Standby Pump head. ➤ Auto Starting/Manual Stopping. ➤ Pump house access 	2280 LPM 60 m One 180 LPM 60 m 2280 LPM 60 m Required Required	Provided Provided Provided Provided Provided Provided Provided Provided Provided	MR MR MR MR MR MR MR MR MR
	• Terrace Level			
	<ul style="list-style-type: none"> ➤ Discharge of pump. ➤ Head of pump. ➤ Power supply. ➤ Auto starting of pump. 	900 LPM 40 m Required Required	Provided Provided Provided Provided	MR MR MR MR
14.	Captive water storage for firefighting.			
	<ul style="list-style-type: none"> Underground tank capacity. <ul style="list-style-type: none"> ➤ Draw-off connection. ➤ Fire Service Inlet. ➤ Access to tank. Overhead tank capacity. 	75,000 ltrs Required Required Required 20,000 ltrs	Provided Provided Provided Provided 20,000 ltrs	MR MR MR MR MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. 	-NA- -NA- Required Required	-NA- -NA- Provided Provided	-NA- -NA- MR MR

- N/24 -

	• Lift signage.	Required	Provided	MR
17	Standby Power Supply	Required	Provided	MR
18.	Refuge Area			
	• Total area	-NA-	-NA-	-NA-
	• Location	-NA-	-NA-	-NA-
19.	Fire Control Room.			
	• Detector System Panel.	-NA-	-NA-	-NA-
	• Flow Switch Panel.	-NA-	-NA-	-NA-
	• PA system Panel.	-NA-	-NA-	-NA-
	• Battery backup	-NA-	-NA-	-NA-
	• Building floor plan	-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.	Manually operated CO ₂ protection system	Provided with CO ₂ & ABC (2 nos each extinguisher)	MR(old case)

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards of fire prevention and fire safety measures as required under the rules of NOC issued vide letter no. F.6/DFS/MS/Industrial/SZ/2018/239 dated 12/02/2018, renewal under rule 37 of the Delhi Fire Service rule 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

Avtar Singh
29/01/2021

Signature of the Inspecting Officer

Name : Avtar Singh

Designation: ADO (M.RD)

DO (SD)

DO (SD)
29/01

F. F. P. Case

DO (SD)

DO (SD)
30/1

ADO (M.RD)

PT letter is put up for sign pl y

DO (SD)

Avtar Singh
30/01/2021

M.S. Cell