

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001


No F 6 / DFS / MS / School/2021 / 100

Dated: 4/2/21

FIRE SAFETY CERTIFICATE

Certified that the **Govt. Co-Ed. Sr. Sec. School** located at **Holambi kalan, Delhi-110082** comprised of **Two Blocks, Ground +three upper floors** owned/occupied by **Govt. Co-Ed. Sr. Sec. School** was granted FSC by this department vide letter no. **No.F6/DFS/MS/2017/School/WZ/1165** dated **04.08.2017**. The building was re-inspected by the officer concerned of this department on **19.01.2021** in presence of **Sh. Ashish Kumar, Vice Principal** and observed that all the fire safety arrangements as provided in the premise/building found in good working condition and the building/ premises is fit for occupancy **Group B (Educational)** with effect from **4/2/21** for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on **4/2/21** at New Delhi


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
West Zone

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi – 54.
2. The Principal, Govt. Co-Ed. Sr. Sec. School, Holambi Kalan, Delhi-110082.

Conditions for the validity of Fire Safety Certificate:

2. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
3. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Govt. Co-Ed. Sr. Sec. School, Holambi Kalan, Delhi-110082.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Building Comprised : Two Blocks (Ground + Three upper floors)
5. Details of previous NOC : F6/DFS/MS/2017/School/WZ/1165 dated: 04/08/2017
6. Fire Safety directives letter No : Director of Education Circular dated 01.03.2011/NBC Part-IV
7. Date of inspection : 19/01/2021
8. Name of the Inspecting Officers : ADO (BW)
9. Name and designation of officers
from the building side : Sh. Ashish Kumar (Vice Principal)
9. Year of Construction : 2016-2017
10. Applicant's letter No. : Email ID Dated: 11/01/2021

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part-IV & Dir. Of education requirements	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6m	6m	MR
	• Gate width	4.5m	4.5m	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	Blk-1=2	Provided	MR
	• Basements	Blk-II=2	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50 m	Blk-1=2×1.76 m Blk-II=2×1.76 m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	2m	2m	MR
	e. Width of Corridor	NA	1.52m	NA
f. Door Size	1 m double door	1.15 m Double Door	MR	

(Signature)

3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural Ventilated	MR
5	Fire Extinguishers			
	• Total numbers	One @ 300 sq m	33 33	MR
	• Types	ABC/Co2	ABC Co2	MR
	• ISI marking	ISI Marked	Yes	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	Blk-I=02 Blk-II=02	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA			
9	Public Address System.			
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA

De


12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access			
	• Terrace level			
	➤ Discharge of pump	2× 450 lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power Supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	2× 10,000 ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A

Dr

18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, is recommended for renewal of Fire Safety Certificate issued vide this department letter no. F6/DFS/MS2017/School/WZ/1165, under rule 37 of the Delhi Fire Service Rules 2010.


 Signature of the Inspecting Officer
 Name: - Rajeev Kumar Sinha
 Designation: - ADO/BW

DO (WZ)
 Dy Chd (WZ)
 ADO/BW
 D Chd (WZ)
 MS/CLL

AS approved F-T letter is put up for signature
 29/01/2021
 27/1/2021
 3/2/2021
 27/1/2021