

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI**

No: F6/DFS/MS/2021/WZ/Hospital/92

Dated: 04/02/2021

FIRE SAFETY CERTIFICATE

Certified that the **Maharaja Agrasen Hospital**, located at **Punjabi Bagh, New Delhi – 110026** comprised of Basement + Ground +06 Upper Floors owned/occupied by **Maharaja Agrasen Hospital** was issued NOC vide Letter no. F6/DFS/MS/Hospital/2018/WZ/205 dated 02/02/2018. The premises was re inspected by the officers concerned of this department on 08/01/2021 in the presence of Mr Rakesh Ghera (Administrative head) and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have therefore, deemed complied with the requirements under rule 33 of the Delhi Fire Service Rule 2010 and the building/premises is fit for **Class-C (Institutional)** occupancy with effect...04/02/2021... for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ..04/02/2021.. at New Delhi.

(Atul Garg)
Director
Delhi Fire Service

Copy to:-

1. The Medical Director,
Maharaja Agrasen Hospital Bagh, New Delhi – 110026 Following

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
9. The ventilation system in basement & upper floors shall be upgraded within 06 months from the date of issuance of this letter with the risk & responsibility of the hospital management.

1. Name & address of the building: **Maharaja Agrasen Hospital, Located at Punjabi Bagh, New delhi-110026**
2. Type of Occupancy : Institutional
3. Type of Case : Renewal
4. Details of previous NOC. F6/DFS/MS/Hospital/2018/WZ/205 dated 02-02-2018
5. Fire Safety directives Letter No: F6/DFS/MS/Hospital/91/2182/ dated 31-12-91
6. Date of inspection : 08-01-2021
7. Name of the Inspecting Officer : Sarabjeet Singh, ADO (MN)
8. Name and designation of Officer
from the building side : Mr.Rakesh Ghera(Administrative head)
9. Year of Construction : 1991-92
10. Applicant's letter No. : E-mail dated 07-01-2021

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC-IV Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	12Mtr 5 Mtr 6 Mtr	Provided Provided Provided	MR MR MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper floors Basements 	2 3 & 1 ramp	Provided Provided	MR MR
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper floors Basements 	2Mtr 1.5Mtr	1.78cm, 175cm 142cm, 152cm, 120cm & one ramp	MR(Being old case) MR(Being old case)
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	Required NR	Provided NR	MR NR
	d. No of continuous staircase to terrace	03	03	MR
	e. Width Of Corridor	2.4Mtr	2.2Mtr	MR(Being old case)
	f. Door Size	1.5Mtr	1.5Mtr	MR(Being old case)
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	Required Required Required NR Required	Provided Provided Provided NR Provided	MR MR MR NR MR
4.	Smoke managements System			
	<ul style="list-style-type: none"> Basements Upper floors 	30 a/c per hour 12 a/c per hour	Provided Provided	MR MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	50Nos.required DCP,ABC,CO2, WCO2 ISI marked	Provided Provided Provided	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose 	03 30 m required	Provided Provided	MR MR

7. Automatic fire detection and alarming system		Smoke & Heat	Provided	MR
<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	G.floor	Provided	MR	
	Required	Provided	MR	
	Required	Provided	MR	
	Required	Provided	MR	
	Required	Provided	MR	
8. MOEFA	Required	Provided	MR	
9. Public Address System	Required	Provided	MR	
10. Automatic Sprinkler System		Required	Provided	MR
<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	NA(as per DFS guideline)	NA	NA	
	NA	NA	NA	
11. Internal Hydrants		150 mm	Provided	MR
<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	03	Provided	MR	
	03	Provided	MR	
12. Yard Hydrants		05	Provided	MR
<ul style="list-style-type: none"> Total number of hydrants Hose Box 	05	Provided	MR	
13. Pumping Arrangements				
<ul style="list-style-type: none"> Ground Level Discharge of main pump <ul style="list-style-type: none"> Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Staring/Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power supply Auto starting of pump 	2400 LPM	2400 LPM	MR	
	80 mtrs	80 mtrs	MR	
	02	02	MR	
	180 LPM	Provided	MR	
	80 mtr	80 mtr	MR	
	2400 LPM	2400 LPM	MR	
	80 mtr	80 mtr	MR	
	Required	Provided	MR	
	Required	Provided	MR	
	Not Required	NR	NR	
	Not Required	NR	NR	
	Not Required	NR	NR	
	Not Required	NR	NR	
14. Captive water Storage for fire fighting		2,00,000 litres	2,00,000 litres	MR
<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw of connection Fire service inlet Access to tank Overhead Tank capacity 	Required	Provided	MR	
	Required	Provided	MR	
	Required	Provided	MR	
	Required	Provided	MR	
	50, 000 litres	50, 000 litres	MR	
15. Exit Signage	Required	Provided	MR	
16. Provision of Lifts		Required	Provided	MR
<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of lift lobby 	NR	NR	NR	

	<ul style="list-style-type: none"> ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> ➤ Total area ➤ Location 	Required	Provided	MR
		3 rd & 4 th floor (As per previous NOC)	Provided	MR
19.	Fire control room			
	<ul style="list-style-type: none"> ➤ Detector system panel ➤ Flow Switch Panel ➤ PA System Panel ➤ Battery backup ➤ Building Floor Plans 	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	Co ₂ flooding system installed in LT panel	MR

The fire Protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of Fire prevention and Fire Safety measure as required under the rules the NOC issued VIDE letter no. F6/DFS/MS/Hospital/1997/955/ dated 07.08.1997, F6/DFS/Hospital/2010/3079/ dated 01/12/2010 & F6/DFS/MS/Hospital/2018/WZ/205/ dated 02/12/2018 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

[Handwritten Signature]

Signature of the Inspecting Officer
Name: - Sarabjeet Singh
Designation: - ADO (MN)

[Handwritten Signature]
Do (west)

D.O. (WEST) 25
DATED 29/01/21


[Handwritten Signature]
29/1/2021

[Handwritten Signature]
Do (WZ)

[Handwritten Note]
Body Composition & Shouting
Matter ~~at~~ letter No 177

[Handwritten Signature]
Do West

[Handwritten Signature]
02/02/2021



[Handwritten Signature]
ADO (MN)

The Hospital building comprised of Basement plus Ground & Six upper floors. resubmitted *[initials]*.
Ventilation system shall be upgraded within 06 months in basement upper floor which is mentioned in the FSC.

[Handwritten Signature]
Do (west)

[Handwritten Signature]
02/02/2021

[Handwritten Signature]
02/02/2021

[Handwritten Signature]