

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/School/NDZ/2021/102

Dated:- 05/02/2021

**FIRE SAFETY CERTIFICATE**

Certified that the **New Oxford Public** located at **D-Block, Preet Vihar, Delhi-91** comprised of **Ground + 03 Upper floor, third floor closed(undertaking enclosed)** was granted FSC by this department vide letter No. **F6/DFS/MS/School/2017/NDZ/326** dated **06/09/2017** for **ground + 02 upper floors**. The premises was re-inspected by the officer concerned of this department on 28/01/2021 in the presence of the Mr. Rohit (Manager) and found that the said school building (Gr.+02 upper floors) have deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules 2010 and that the premises is fit for occupancy class **“B” ‘Educational Building’** Ground + 02 upper floors with effect from 05/02/2021 for a period of **three** years, subject to conditions, printed below.

Issued on 05/02/2021 at New Delhi by

  
4/2/21

**(Dr. S.K Tomar)**  
Dy. Chief Fire Officer  
Delhi Fire Service

Copy to:-

1. The Dy. Director of Education,  
D-Block, Anand Vihar, Delhi-92.
2. The Principal,  
New Oxford Public, D-Block, Preet Vihar, Delhi-91.

**Condition for the validity of fire safety certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form ‘K’ provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.

N/19 -

**INSPECTION REPORT**

1. Name & address of the building:- New Oxford Public, D-Block, Preet Vihar, Delhi-91.
2. Type of occupancy:- Educational Group Gr.+02 Upper Floor
3. Type of case:- Renewal
4. Details of previous NOC:- F6/DFS/MS/School/2017/NDZ/326 dated 06/09/2017
5. Fire safety directives No.- N/A
6. Date of inspection:- 28/01/2021
7. Name of the inspecting officer:- Sh. Manoj Kumar Sharma (ADO/LN)
8. Name & designation of officer  
From the building side:- Mr. Rohit (Manager)
9. Year of construction:- 2008,2014 & 2018.
10. Applicant's letter No:- Email dated 22/01/2021.

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Exiting	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06 mtr.	06 mtr.	MR
	2) Gate width	NA	NA	NA
	3) Width of internal road	NA	NA	NA
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02	02	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.5 mtr	1.5 m & 1.25 m	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01	01	MR
	E. Width of corridor	1.5 mtr.	1.5 mtr.	MR
	F. Door size	1 mtr.	1 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	1) Total numbers	20 Nos.	20 Nos.	MR
	2) Types	ABC & CO2	ABC, CO2	MR
	3) ISI marking	Required	Provided	MR

*mm*

6.	First-Aid Hose Reel			
	1) Total number of each floor	01	01	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	N/A	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	450 LPM	MR
	b) Head of pump	40 mtr.	40 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A

Mw

	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	10,000 ltr.	10,000 ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection system provided in the school building were tested, checked at random and found functional at the time of inspection.

Shortcomings communicated vide letter No. F6/DFS/MS/School/2020/NDZ/635 dated 16/09/2020 have been rectified.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F6/DFS/MS/School/2017/NDZ/326 dated 06/09/2017, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended.

Signature of the Inspecting Officer

*M.K. Sharma*  
28/11/21

Name :- M.K. Sharma  
Designation :- ADO (LN)

DO(ED)

*[Signature]*  
28/11

DO. C/O MD-4

Pl. speak about 3rd floor & rectification of shortcomings issued vide letter dt. 16/9/2020.

DO(ED) *[Signature]*

*[Signature]*  
1/2/21