

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**



No. F6/DFS/MS/WZ/2021/ 91

Dated: 03/02/2021

**FIRE SAFETY CERTIFICATE**

Certified that **The Delhi radhasoami Satsang Association (Dayal Bagh, Agra)** located at **Saiyed Nangloi, Delhi- 110087**, comprised of ground and first floor. The premises was inspected by the officer concerned of this department on 15.01.2021 in presence of Sh. H.L. Chawla and found that the owner have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class assembly at **ground and first floor** with effect from 03/02/2021 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed overleaf.

Issued on 03/02/2021 at New Delhi by.

  
(Atul Garg)  
Director  
Delhi Fire Service  


Copy to:-

1. The Joint Commissioner of Police (Lic), 1st Floor, Police Station Defence Colony, New Delhi.
2. The Authorized Signatory, The Delhi radhasoami Satsang Association (Dayal Bagh, Agra) located at Saiyed Nangloi, Delhi- 110087.

## CONDITIONS

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional of fire safety measures shall be at the risk & responsibility of the management.
3. The trained firefighting staffs should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. All the means of escapes /exits shall not be locked/bolted/blocked at any time for safe evacuation of the occupants in case of any emergency.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [ sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

1. Name & address of the building : OCF POCKET, VILLAGE SAIYAD NANGLOI, New Delhi-110087.
2. Type of Occupancy : Assembly (Plot Area – 401.1m<sup>2</sup>)
3. Type of Case : New (Covered Area – 141.368m<sup>2</sup>)
4. Details of previous NOC : Nil {Ground & One Upper Floor only}
5. Fire Safety directives letter No : NBC (Part-IV)
6. Date of inspection : 16.01.2021
7. Name of the Inspecting Officers : Aman Kumar Lathar, Asst. Divisional Officer (Jwalapuri)
8. Name and designation of officers from the building side : Hazari Lal Chawla, Joint Secretary
9. Year of Construction : 2020
10. Applicant's letter No. : Email – [hazarilalchawla@rediffmail.com](mailto:hazarilalchawla@rediffmail.com) Dated-07.01.2020

The building is comprised of ground and first floor only.

S. No	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	06 mts	Provided	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	-----	-----	-----
	• Upper Floors	02 Nos. each block	Provided	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases	-----	-----	-----
	• Upper Floors	2.00 mtr & 1.5mtr	Provided	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits	-----	-----	-----
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	2.00 mtr & 1.5mtr	Provided	MR
3	<b>Compartmentation.</b>			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	<b>Smoke Management System.</b>			
	• Basements	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5	<b>Fire Extinguishers</b>			
	• Total numbers	4 nos.	6	MR
	• Types	ABC, CO <sub>2</sub> type	Provided	MR
	• IS marking	ISI marked	Provided	MR



5	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.	Not Applicable		
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested / checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service rules 2010.

**Note: 15000 ltr capacity is connected to 20000 ltr capacity underground tank with boosting arrangement. If agreed case may be considered.**

DFA is put up for approval & signature please

*(Handwritten signature)*  
25/01/21

Aman Kumar Lathar  
Asst. Divisional Officer (Jwp)

D.O. (W2)  
D.O. (WEST) 28  
DATED 25/01/21  
D.O. (WEST)  
DCFO (W2)

*(Handwritten initials)*

*(Handwritten signature)*  
29/1

*(Handwritten initials)*  
AT PL 1

