

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/School/2021/NDZ/ 106

Dated: 9/2/21

FIRE SAFETY CERTIFICATE

Certified that the EDMC Primary School at Raghupura, Delhi-31 comprised of ground plus one upper floor owned/occupied by EDMC Primary School was issued FSC vide letter No. F.6/DFS/MS/2016/1241 dated 05/08/2016. The school building have complied with the fire prevention and fire safety requirements in accordance with circular No-F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated-01/03/11 issued by the Director of Education and verified by the officers concerned of this department on dated 03/02/2021 in the presence of Mr. Aashish Dahiya, Primary Teacher of the school and found that the school building is fit for occupancy class "B" 'Educational Building' for ground plus one floor with effect from ...9/2/21..... for a period of three years, in accordance and further subject with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on.....9/2/21.....at New Delhi by

(Signature)
8/2/21

(Dr. S. K. Tomar)
Dy. Chief Fire Officer

(Signature)

To,
The Principal,
EDMC Primary School,
Raghupura, Delhi-31

Copy:-
The Director of Education, EDMC,
Udyog Sadan, Plot No. 419, FIE,
Patparganj Industrial Area, Delhi-92

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : EDMC Primary School, Raghubarpura, Delhi
2. Building is comprised of : Ground Plus one upper floor
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC letter : F6/DFS/MS/2016/1241 dated 05/08/2016
6. Fire Safety direction letter No. : F16/Estate/CC/Fire Safety/2011/3298 to 3398 dated- 01/03/11
7. Date of Inspection : 03/02/2021
8. Name of the Inspecting officers : ADO Nagender Singh
9. Name and designation of Officer from the building side : Mr. Aashish Dahiya, Primary Teacher
10. Year of Construction : 2013
11. Applicant's letter No. : Nil dated 20/1/2021

| Sr. No. | Minimum Standards on Fire Prevention and Fire Safety U/R33 | Circular Requirement | Provided at Site | Remarks MR/NMR |
|---------|--|----------------------|----------------------|--|
| 01 | Access to Building | | | |
| | <ul style="list-style-type: none"> • Road width | 06m | 3.5m | Through one length hose (Accepted Earlier) |
| | <ul style="list-style-type: none"> • Gate width | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> • Width of internal road | N/A | N/A | N/A |
| 02 | Number, Width, Type and Arrangement of Exits | | | |
| | a. Number of Staircases | | | |
| | <ul style="list-style-type: none"> • Upper floor | 02 nos. | 02 nos. | MR |
| | <ul style="list-style-type: none"> • Basement | N/A | N/A | N/A |
| | B. Width of Staircases | | | |
| | <ul style="list-style-type: none"> • Upper floor | 1.50m | 1.60m each | MR |
| | <ul style="list-style-type: none"> • Basement | N/A | N/A | N/A |
| | c. Protection of Exits | | | |
| | <ul style="list-style-type: none"> • Fire check door | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> • Pressurization | N/A | N/A | N/A |
| | d. No. of Continuous Staircases to Terrace | 01 no. | 01 no. | MR |
| | e. Width of Corridor | 1.50m | 2.04m | MR |
| | f. Door Size | 01m | 01m | MR |
| 03 | Compartmentation. | | | |
| | <ul style="list-style-type: none"> • Fire check door | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> • Sealing of electrical shafts | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> • Fire rating of shaft door | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> • Water curtain | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> • Fire dampers | N/A | N/A | N/A |
| 04 | Smoke Management System. | | | |
| | <ul style="list-style-type: none"> • Basement | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> • Upper floor | N/A | N/A | N/A |
| 05. | Fire Extinguishers | | | |
| | <ul style="list-style-type: none"> • Total numbers | 04 nos. | 06 nos. | MR |
| | <ul style="list-style-type: none"> • Types | ABC/CO ₂ | ABC/ CO ₂ | MR |
| | <ul style="list-style-type: none"> • IS marking | ISI marked | ISI marked | MR |


| | | | | |
|----|---|-----|----------|-----|
| 06 | First-Aid-Hose Reels. | | | |
| | Total numbers on each floor | N/A | N/A | N/A |
| | • Length of hose reel hose | N/A | N/A | N/A |
| | • Nozzle diameter | N/A | | N/A |
| 07 | Automatic Fire Detection and Alarming System. | | | |
| | • Type of detectors | N/A | N/A | N/A |
| | • Location of main panel | N/A | N/A | N/A |
| | • Location of repeater panel | N/A | N/A | N/A |
| | • Alternate source of power | N/A | N/A | N/A |
| | • Hooter | N/A | N/A | N/A |
| 08 | MOEFA | N/A | Provided | MR |
| 09 | Public Address System. | N/A | Provided | MR |
| 10 | Automatic Sprinkler System. | | | |
| | • Basement | N/A | N/A | N/A |
| | • upper floor | N/A | N/A | N/A |
| | • sprinkler above false ceiling | N/A | N/A | N/A |
| 11 | Internal Hydrants | | | |
| | • size of riser/down-comer | N/A | N/A | N/A |
| | • Number of hydrants per floor | N/A | N/A | N/A |
| | • Hose box | N/A | N/A | N/A |
| 12 | Yard Hydrants. | | | |
| | • Total number of hydrants | N/A | N/A | N/A |
| | • Hose box | N/A | N/A | N/A |
| 13 | Pumping Arrangements. | | | |
| | ➤ Ground Level | | | |
| | • Discharge of main pump | N/A | N/A | N/A |
| | • Head of main pump | N/A | N/A | N/A |
| | • Number of main pumps | N/A | N/A | N/A |
| | • Jockey pump out put | N/A | N/A | N/A |
| | • Jockey pump head | N/A | N/A | N/A |
| | • Standby pump out put | N/A | N/A | N/A |
| | • Standby pump head | N/A | N/A | N/A |
| | • Auto starting /manual stopping | N/A | N/A | N/A |
| | • Pump house access | N/A | N/A | N/A |
| | ➤ Terrace Level | | | |
| | • Discharge of pump | N/A | N/A | N/A |
| | • Head of the pump | N/A | N/A | N/A |
| | • Power supply | N/A | N/A | N/A |
| | • Auto starting of pump | N/A | N/A | N/A |
| 14 | Captive Water Storage for Fire Fighting. | | | |
| | • Underground tank capacity | N/A | N/A | N/A |
| | • Draw-off connection | N/A | N/A | N/A |
| | • Fire service inlet | N/A | N/A | N/A |
| | • Access to tank | N/A | N/A | N/A |
| | • Overhead tank capacity | N/A | N/A | N/A |
| 15 | Exit Signage. | | | |
| | | N/A | N/A | N/A |


N/13


| | | | | |
|----|--|-----|-----|-----|
| 16 | Provision of Lifts. | | | |
| | • Pressurization of lift shaft | N/A | N/A | N/A |
| | • Pressurization of lift lobby | N/A | N/A | N/A |
| | • Communication in lift car | N/A | N/A | N/A |
| | • Firemen's grounding switch | N/A | N/A | N/A |
| | • Lift signage | N/A | N/A | N/A |
| 17 | Standby Power Supply | N/A | N/A | N/A |
| 18 | Refuge Area. | | | |
| | • Total area | N/A | N/A | N/A |
| | • Location | N/A | N/A | N/A |
| 19 | Fire Control Room | | | |
| | • Detector system panel | N/A | N/A | N/A |
| | • Flow switch panel | N/A | N/A | N/A |
| | • PA system panel | N/A | N/A | N/A |
| | • Battery backup | N/A | N/A | N/A |
| | • Building floor plans | N/A | N/A | N/A |
| 20 | Special Fire Protection Systems for Protection of Special Risks, if Any: | N/A | N/A | N/A |

The Fire protection systems provided in the building were Tested/Checked and found functional, at the time of inspection.


Keeping in view of the compliance of the minimum standards of fire prevention and fire safety measures required as per circular No.F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated-01/03/11 issued by Director of Education, it is recommended to renew FSC under rule 37 of the Delhi Fire Service Rule 2010



 (Nagender Singh)
 ADO(Shahdara)

~~DO(ED)~~ 
 4/12

DY. CFO (MSZ) F.S. pl.

 4/12/21

~~A DO (Shah)~~ FT is submitted for signatures please

Dy CFO (MSZ)

 8/2/21


 8/2/21