

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6/DFS/MS/School/SZ/2021/ 113

Dated: 11/2/21

**FIRE SAFETY CERTIFICATE**

Certified that **Salwan Boys Sr. Sec. School located at Old Rajinder Nagar, New Delhi-110060**, comprised of ground plus one upper floors owned/occupied by Salwan Boys Sr. Sec. School was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2018/SZ/165 dated 24.01.2018. The school building was re-inspected by the officer concerned of this department on 04.02.2021 in presence of Smt. Saroj Achra (Principal) and found that the said School building have deemed complied with the fire prevention and fire safety requirements in accordance with circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the school building is fit for occupancy class "Educational" with effect from the date of issue of this certificate for a period of three years subject to compliance of the conditions printed as under.

Issued on 11/2/21 at New Delhi by.

(Sunil Chaudhary)  
Dy. Chief Fire Officer

Copy to: -

1. The Principal, Salwan Boys Sr. Sec. School, Old Rajinder Nagar, New Delhi- 110060.
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi- 110054.

**Conditions for the Validity of Fire Safety Certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional of fire safety measures shall be at the risk & responsibility of the management.
3. The trained firefighting staffs should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. Basement used only for storage purpose as per BBL.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [ sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
9. All the means of escapes /exits shall not be locked/blocked at any time for safe evacuation of the occupants in case of emergency.

1. Name & address of the building : Salwan Boys Sr. Sec. School, Old Rajinder Nagar, New Delhi- 110060.
  2. Type of Occupancy : Educational
  3. Type of Case : Renewal
  4. Details of previous NOC : F.6/DFS/MS/School/2018/SZ/165 dated 24.01.2018
  5. Fire Safety directives letter No : D.o.E Cir. No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.20177
  6. Date of inspection : 04.02.2021
  7. Name of the Inspecting Officers : P.V. Rathee, ADO(Shankar Road)
  8. Name and designation of officers from the building side : Smt. Saroj Achra (Principal)
  9. Year of Construction : Before 2007
  10. Applicant's letter No. : Email ID [principal.sbs@salwanschools.com](mailto:principal.sbs@salwanschools.com) dated 20.01.2021
- School building is comprised of ground plus one upper floors.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per circular of DoE dt. 01.03.2011	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	06 mts	Provided	MR
	• Gate width	4.5 mtrs	Directly accessible from road	MR
	• Width of internal road	N/A	N/A	N/A
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	-----	-----	-----
	• Upper Floors	02 Nos.	Provided	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases	-----	-----	-----
	• Upper Floors	1.5 mts additional staircase of 0.75 mts if less than 1.50 mts	1.50, 1.40 mts.	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits	-----	-----	-----
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	01	01	MR
	g. Width of Corridor	1.50 mts	2.40 mts	MR
	h. Door Size	1.0 mt.	1.04 mts	MR
3	<b>Compartmentation.</b>			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	<b>Smoke Management System.</b>			
	• Basements	30 a/c per hour	N/A	N/A
	• Upper floors	12 a/c per hour	Natural Vent.	MR
5	<b>Fire Extinguishers</b>			
	• Total numbers	06 nos.	Provided	MR
	• Types	ABC, CO <sub>2</sub> type	Provided	MR
	• IS marking	ISI marked	Provided	MR

B



16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	<b>Standby power supply</b>	N/A	N/A	N/A
18	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested / checked and found functional at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No F.6/DFS/MS/School/2018/SZ/165 dated 24.01.2018, renewal under Rule 35 of Delhi Fire Service Rules 2010 & The Directorate of Education circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01-03-2011 is recommended.

Accordingly, DFA is put up for approval & signature please.



(P.V. Rathee)  
Asstt. Div. Officer (SRD)

D.O (SW)

by  
05/02/2021

by cfo (S2)

F. T. P. beal  
8/2

ADD (SRD)