

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No. F.6/DFS/MS/BNQT/2021/SZ/ 116

Dated: 12/02/2021

FIRE SAFETY CERTIFICATE

Certified that **Shyama Banquets (A unit of Shyama Infotech Pvt. Ltd.)** located at RZ-1738/37, Tugalakabad Extension, New Delhi comprised Ground + 01 Upper floor. The premises was inspected by officer concerned of this department on 18/01/2021 in the presence of Mr. Umesh Singh (Manager) of the banquet hall and observed that said banquet hall have complied with the fire safety and fire prevention requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class A "Banquet Hall" with effect from 12/02/2021..... for a period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued 12/02/2021 at New Delhi by


(Atul Garg)
Director
Delhi Fire Service

Copy to: -

1. The Executive Engineer (Bldg), SDMC, Jal Vihar, Lajpat Nagar, New Delhi-110024
2. Sh. Ranjit Singh (Director), Shyama Banquets, RZ-1738/37, GF & FF, Tughlakabad Extn. New Delhi-110019.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

1	Name & Address of the Building	Shyama Banquets (A unit of Shyama Infotech Pvt. Ltd.) at Ground and First floor at RZ- 1738/37, Tughlakabad Extension, New Delhi		
2	Type of Occupancy	Group-D, Assembly Building		
3	Building Comprised of	Ground + 01 upper floor		
4	Type of Case	New		
5	Details of Previous NOC	Nil		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	18/01/2021		
8	Name of the Inspecting Officers	ADO Avtar Singh		
9	Name & Designation of Officers from the building side	Mr. Umesh Singh (Manager)		
10	Year of construction	2019		
11	Applicant letter No.	Application no. 2020101907854 dated 17/12/2020		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	BBL/NBC Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	<ul style="list-style-type: none"> Road width 	6 m	7 m	MR
	<ul style="list-style-type: none"> Gate width 	4.5 m	4.5 m (02 nos)	MR
	<ul style="list-style-type: none"> Width of internal road 	-N/A-	-N/A-	-N/A-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	<ul style="list-style-type: none"> Upper floors 	02	02	MR
	<ul style="list-style-type: none"> Basement 	-N/A-	-N/A-	-N/A-
	b) Width of Staircase			
	<ul style="list-style-type: none"> Upper floors 	1.50 m & 2.0 m	1.50 m & 2.0 m	MR
	<ul style="list-style-type: none"> Basement 	-N/A-	-N/A-	-N/A-
	c) Protection of exits			
	<ul style="list-style-type: none"> Fire check door 	Required	Provided	MR
	<ul style="list-style-type: none"> Pressurization 	-N/A-	-N/A-	-N/A-
	d) No. of continuous staircase to terrace	Two	Two	MR
	e) Width of corridor	-N/A-	-N/A-	-N/A-
	f) Door size	02 nos of 02 m	02 nos of 02 m	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door. 	Required	Provided	MR
	<ul style="list-style-type: none"> Sealing of electrical shafts. 	Required	Provided	MR
	<ul style="list-style-type: none"> Fire rating of shaft door. 	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> Water curtain 	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> Fire dampers. 	-N/A-	-N/A-	-N/A-
4.	Smoke Management system.			
	<ul style="list-style-type: none"> Basement 	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> Upper floors 	12 ACPH	Provided	MR
5.	Fire Extinguishers.			
	<ul style="list-style-type: none"> Total numbers 	10 nos	10 nos	MR
	<ul style="list-style-type: none"> Types 	ABC & CO ₂	ABC, & Co ₂	MR
	<ul style="list-style-type: none"> ISI Marking 	ISI marked	Provided	MR
6.	First Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor 	01	Provided	MR
	<ul style="list-style-type: none"> Length of hose-reel hose. 	30 m	Provided	MR

	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
8.	MOEFA	Required	Provided	MR
9.	Public Address System	-N/A-	-N/A-	-N/A-
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement. Upper floors Sprinkler above false ceiling 	-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser / Down-comer Number of Hydrant per floor Hose box. 	100 mm	Provided	MR
		Required	Provided 01 no	MR
		Required	Provided 01 no	MR
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
13.	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level 			
	Discharge of main pump.	-N/A-	-N/A-	-N/A-
	➤ Head of main pump.	-N/A-	-N/A-	-N/A-
	➤ Number of main pumps.	-N/A-	-N/A-	-N/A-
	➤ Jockey Pump output.	-N/A-	-N/A-	-N/A-
	➤ Jockey Pump head.	-N/A-	-N/A-	-N/A-
	➤ Standby Pump output.	-N/A-	-N/A-	-N/A-
	➤ Standby Pump head.	-N/A-	-N/A-	-N/A-
	➤ Auto Starting/Manual stopping.	-N/A-	-N/A-	-N/A-
	➤ Pump house access.	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> Terrace Level 			
	➤ Discharge of pump.	900 LPM	900 LPM	MR
	➤ Head of pump.	35 m	35 m	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14.	Captive water storage for firefighting.			
	<ul style="list-style-type: none"> Underground tank capacity. ➤ Draw-off connection. ➤ Fire Service Inlet. ➤ Access to tank. Overhead tank capacity. 	-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		20,000 ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
17	Standby Power Supply	Required	Provided	MR
18.	Refuge Area			

	• Lift signage.	-N/A-	-N/A-	-N/A-
17	Standby Power Supply	Required	Provided	MR
18.	Refuge Area			
	• Total area	-N/A-	-N/A-	-N/A-
	• Location	-N/A-	-N/A-	-N/A-
19.	Fire Control Room.			
	• Detector System Panel.	-N/A-	-N/A-	-N/A-
	• Flow Switch Panel.	-N/A-	-N/A-	-N/A-
	• PA system Panel.	-N/A-	-N/A-	-N/A-
	• Battery backup	-N/A-	-N/A-	-N/A-
	• Building floor plan	-N/A-	-N/A-	-N/A-
20.	Special Fire Protection System for the Protection of special Risk, if any.	Required	Provided 02 ABC type fire extinguishers near elect. Panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 37 of the Delhi Fire Service Rules 2010.

Accordingly DFA is put up for approval and signature please.



(Signature)
18/01/2021

Signature of the Inspecting Officer
Name : Avtar Singh
Designation: ADO (MR)

DO (SD)

On CHL + D/15/66

DUF (S/P)

(Signature)
19/11

C.F.O.

(Signature)
2/11

P/S S/P

(Signature)

(Signature)
21/1/20

DUF/S2