

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE

[See sub-rule (1) of rule 35]

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**

**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/EH/2021/SZ/ **33**

Dated: **17/2/21**

**FIRE SAFETY CERTIFICATE**

Certified that the Eating House located at India Islamic Cultural Centre, 87-88, Lodhi Estate, New Delhi-110003, comprised of Lower Ground Floor, Ground Floor & 1<sup>st</sup> Floor (**Eating House at Ground Floor Only**) owned / occupied by India Islamic Cultural Centre has already been issued Fire Safety Certificate Vide letter No. F6/DFS/MS/EH/2018/SZ/367 dated 06/03/2018. The premises was re-inspected by the officer concerned of Fire Service on 05.02.2021 in the presence of Sh. Arif Siddique and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of the Delhi Fire Service rules, 2010 and that the building / premises is fit for occupancy class Assembly / Restaurant (Eating House) (Group-D) with effect from 17/2/2021 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on .....**17/2/21**..... at New Delhi.



(SUNIL CHAWDHARY)

DY. CHIEF FIRE OFFICER (S.Z.).

Copy to :-

1. Sh. Arif Siddique, M/s India Islamic Cultural Centre, 87-88, Lodhi Estate, New Delhi-03.
2. Joint Commissioner of Police (Licensing), 1<sup>st</sup> Floor, P.S. Defence Colony, New Delhi-49s.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)

## INSPECTION REPORT

1. Name & address of the building : **M/s India Islamic Cultural Centre, 87-88, Lodhi Estate, New Delhi-110003.**
2. Type of Occupancy : **Assembly (Restaurant at Ground Floor)**
3. Building Comprised of : **Lower Ground Floor, Ground Floor, 1<sup>st</sup> Floor**
4. Type of Case : **Renewal**
5. Details of previous NOC No. : **F6/DFS/MS/EH/2018/SZ/367 dated 06/03/2018**
6. Fire Safety directives Letter No. : **Nil**
7. Date of inspection : **05/02/2021**
8. Name of the Inspecting Officer : **A.D.O. (S.J.)**
9. Name and designation of Officer from the building side : **Sh. Arif Siddique**
10. Year of Construction : **2006**
11. Applicant's letter No. : **MHA Portal ID-20210109563 dated 18/01/2021**

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirements as Circular No. F6/DFS/EH/2005/718 dated 4/4/05	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 mtr	18 mtr ✓	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	b. Width of staircases	N/A		
	• Upper floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	c. Protection of exits	N/A		
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	1	2	MR
	e. Width Of Corridor	2 m	2 m ✓	MR
	f. Door Size	Required	1.00 m x 4, 1.70 m x 1 & 1.30 m x 1 ✓	MR (Old Case)
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	N/A	N/A	N/A
	• Ground Floor	12 a/c per hour	Exhaust Fan	MR
5.	Fire Extinguishers			
	• Total numbers	6	10 ✓	MR
	• Types	ABC/CO <sub>2</sub>	Provided	MR
	• ISI marking	Required	Provided	MR

	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> </ul>	1	1	MR
	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> </ul>	30 Mtr.	30 Mtr.	MR
	<ul style="list-style-type: none"> <li>Nozzle diameter</li> </ul>	5 mm	5 mm	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>Type of detector</li> </ul>	Heat & Smoke	Heat & Smoke	MR
	<ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>	Reception	Reception at Ground Floor	MR
	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Hooters' Location</li> </ul>	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>Basements</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Upper Floor</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	N/A	N/A	N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> </ul>	100mm	100mm	MR
	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	1	1	MR
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	1	1	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	N/A	N/A	N/A
13.	Pumping Arrangements (Fire Fighting system is common for entire building)			
	<ul style="list-style-type: none"> <li>Ground Level</li> </ul>			
	➤ Discharge of main pump	2800 LPM	2800 LPM	MR
	➤ Head of main pump	40 MH	70 MH	MR
	➤ Number of main pumps	1	1	MR
	➤ Jockey pump out put	180 LPM	180 LPM	MR
	➤ Jockey pump head	40 MH	70 MH	MR
	➤ Standby Pump out put	2800 LPM	2800 LPM	MR
	➤ Standby Pump Head	40 MH	70 MH	MR
	➤ Auto Starting/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Terrace level</li> </ul>			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto starting of pump	N/A	N/A	N/A
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> </ul>	1,00,000 ltrs	1,00,000 ltrs	MR
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	N/A	Provided	MR
	➤ Access to tank	N/A	N/A	N/A

H/37

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Batter backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found non-functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. **F6/DFS/MS/EH/2018/SZ/367 dated 06/03/2018** renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

*[Signature]*  
8/2/2021

Signature of the Inspecting Officer  
Name : Ashok Kumar Jaiswal  
Designation : A.D.O. (S.J.)

*DO (SD)*

*DO*  
10/02/21

*DO (S)*

*F.T. please*

*ADD (S.J)*

*F.T. is put up for sign. pl.*