

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/WZ/2021/ BNOT/ 126

Dated: 17/02/2021

FIRE SAFETY CERTIFICATE

Certified that the **Maharaja Banquet** located at A-1/20-A, Main Rohtak Road, Paschim Vihar, Delhi-110063 is **running on Ground floor only** in a building comprised of Basement + Ground + Three upper floors only owned / occupied by **Maharaja Banquet** was issued fire safety certificate by this department vide letter F.6/DFS/MS/Banquets/2018/WZ/280 dated 22/02/2018. The premises was re-inspected by the officer concerned of this department on 02/02/2021 in the presence of Mr. Manoj Kumar Goel (Owner) and found that the owner have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building / premises is fit for occupancy class **Assembly (Group – D)** with effect from 17/02/2021 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of conditions, under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on 17/02/2021 at New Delhi.

  
(DHARAMPAL BHARDWAJ)  
Dy. CHIEF FIRE OFFICER  
West Zone

Copy to: -

1. Mr. Manoj Kumar Goel (Owner), Maharaja Banquet located at A-1/20-A, Main Rohtak Road, Paschim Vihar, Delhi-10063
2. The Joint Commissioner of Police, Licensing Unit, 1<sup>st</sup> Floor, Police Station Defence Colony, New Delhi.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. “The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form ‘J’ [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry”.
8. The owner / occupier shall submit a declaration every year in form “K” provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.Delhigovt.nic.in](http://www.dfs.Delhigovt.nic.in).

## INSPECTION REPORT

1	Name & Address of the Building	Maharaja Banquets, located at A-1/20-A, Main Rohtak Road, Paschim Vihar, Delhi-110063		
2	Type of Occupancy	Group-D, Assembly Building		
3	Building Comprised of	Basement + Ground + Three Upper floors ( <b>Banquet running on Ground floor only</b> )		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/Banquets/2018/WZ/280 dated 22/02/2018		
6	Fire Safety Directives Letter No	F6/DFS/MS/BP/2017/BNQT/3443 dated 20/12/2017		
7	Date of Inspection	02/02/2021		
8	Name of the Inspecting Officers	ADO Aman Kumar Lather		
9	Name & Designation of Officers from the building side	Mr. Manoj Kumar Goel (Owner)		
10	Year of construction	2012		
11	Applicant letter No.	Email dated 11/01/2021		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	NBC part-IV Requirement	Provided at Site	Remarks MR/NMR
<b>1</b>	<b>Access to Building.</b>			
0.	• Road width	18 m	Provided	MR
	• Gate width	4.5 m	On main road	MR
	• Width of internal road	-N/A-	-N/A-	-N/A-
<b>2</b>	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a) Number of Staircase</b>			
	➤ Upper floors	-N/A-	-N/A-	-N/A-
	➤ Basement	-N/A-	-N/A-	-N/A-
	<b>b) Width of Staircase</b>			
	➤ Upper floors	-N/A-	-N/A-	-N/A-
	➤ Basement	-N/A-	-N/A-	-N/A-
	<b>c) Protection of exits</b>			
	➤ Fire check door	Required	Provided	MR
	➤ Pressurization	-N/A-	-N/A-	-N/A-
	<b>d) No. of continuous staircase to terrace</b>	-N/A-	-N/A-	-N/A-
	<b>e) Width of corridor</b>	-N/A-	-N/A-	-N/A-
	<b>f) Door size</b>	2.0 m	2.0 m × 1 1.0 m × 1	MR
<b>3</b>	<b>Compartmentation.</b>			
	• Fire check door.	Required	Provided	MR
	• Sealing of electrical shafts.	Required	Provided	MR
	• Fire rating of shaft door.	-N/A-	-N/A-	-N/A-
	• Water curtain	-N/A-	-N/A-	-N/A-
	• Fire dampers.	-N/A-	-N/A-	-N/A-
<b>4.</b>	<b>Smoke Management system.</b>			
	• Basement	-N/A-	-N/A-	-N/A-
	• Upper floors	Required	Provided	MR
<b>5.</b>	<b>Fire Extinguishers.</b>			
	• Total numbers	02 nos	05 nos	MR
	• Types	ABC & CO <sub>2</sub>	Provided	MR
	• ISI Marking	ISI marked	Provided	MR
<b>6.</b>	<b>First Aid Hose Reels.</b>			

		01(at ground floor only)	02 nos	MR (Banquet is only at G.F)
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> </ul>			
	<ul style="list-style-type: none"> <li>Length of hose-reel hose.</li> </ul>	30 m	30 m	MR
	<ul style="list-style-type: none"> <li>Nozzle Diameter</li> </ul>	5 mm	5 mm	MR
<b>7</b>	<b>Automatic fire detection &amp; alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> </ul>	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> <li>Hooter's location</li> </ul>	-N/A-	-N/A-	-N/A-
<b>8.</b>	<b>MOEFA</b>	Required	Provided	MR
<b>9.</b>	<b>Public Address System</b>	Required	Provided	MR
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>Basement.</li> </ul>	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> <li>Upper floors</li> </ul>	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	-N/A-	-N/A-	-N/A-
<b>11.</b>	<b>Internal Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Size of Riser / Down-comer</li> </ul>	150 mm	150 mm	MR
	<ul style="list-style-type: none"> <li>Number of Hydrant per floor</li> </ul>	One	Two	MR
	<ul style="list-style-type: none"> <li>Hose box.</li> </ul>	One	Two	MR
<b>12.</b>	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants.</li> </ul>	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> <li>Hose box.</li> </ul>	-N/A-	-N/A-	-N/A-
<b>13.</b>	<b>Pumping arrangements.</b>			
	<ul style="list-style-type: none"> <li><b>Ground Level</b></li> </ul>			
	<ul style="list-style-type: none"> <li>➤ Discharge of main pump.</li> </ul>	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> <li>➤ Head of main pump.</li> </ul>	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> <li>➤ Number of main pumps.</li> </ul>	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> <li>➤ Jockey Pump output.</li> </ul>	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> <li>➤ Jockey Pump head.</li> </ul>	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> <li>➤ Standby Pump output.</li> </ul>	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> <li>➤ Standby Pump head.</li> </ul>	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> <li>➤ Auto Starting/Manual stopping.</li> </ul>	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> <li>➤ Pump house access.</li> </ul>	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> <li><b>Terrace Level</b></li> </ul>			
	<ul style="list-style-type: none"> <li>➤ Discharge of pump.</li> </ul>	900 LPM	900 LPM	MR
	<ul style="list-style-type: none"> <li>➤ Head of pump.</li> </ul>	40 m	40 m	MR
	<ul style="list-style-type: none"> <li>➤ Power supply.</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Auto starting of pump.</li> </ul>	Required	Provided	MR
<b>14.</b>	<b>Captive water storage for firefighting.</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity.</li> </ul>	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> <li>➤ Draw-off connection.</li> </ul>	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> <li>➤ Fire Service Inlet.</li> </ul>	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> <li>➤ Access to tank.</li> </ul>	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> <li>Overhead tank capacity.</li> </ul>	25,000 ltrs	25,000 ltrs	MR
<b>15.</b>	<b>Exit Signage.</b>	Required	Provided	MR
<b>16.</b>	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>Pressurization of lift shaft.</li> </ul>	-N/A-	-N/A-	-N/A-

	<ul style="list-style-type: none"> <li>• Communication in lift car.</li> <li>• Fireman's switch.</li> <li>• Lift signage.</li> </ul>	-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
17	<b>Standby Power Supply</b>	Required	Provided	MR
18.	<b>Refuge Area</b>			
	<ul style="list-style-type: none"> <li>• Total area</li> <li>• Location</li> </ul>	-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
19.	<b>Fire Control Room.</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel.</li> <li>• Flow Switch Panel.</li> <li>• PA system Panel.</li> <li>• Battery backup</li> <li>• Building floor plan</li> </ul>	-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
20.	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>	Required	02 fire extinguishers provided near elect. panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards of fire prevention and fire safety measures as required under the rules of NOC issued vide letter no. F.6/DFS/MS/Banquets/2018/WZ/280 dated 22/02/2018, renewal under rule 37 of the Delhi Fire Service rule 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

*Signature*  
11/02/21

Signature of the Inspecting Officer  
Name : Aman Kumar Lather  
Designation: ADO (JWP)

~~DO (WD)~~

*Signature*  
12/02/2021

~~DCFO (WZ)~~

*Signature*  
15/02/2021

~~ADO (JWP)~~

F.T. letter is put-up for signature pl.

~~DCFO (WZ)~~

*Signature*  
17/2/2021

*ms cell*

*Signature*  
17/02/21  
AMD (JWP)