

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE

[See sub-rule (1) of rule 35]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/WZ/2021/ *Motel/127*

Dated: *18/02/2021*

FIRE SAFETY CERTIFICATE

Certified that the M/s. **Murti Hospitality Pvt. Ltd.** (Motel City Park Resort) at K.N. 86/10, 86/11, 86/20, 78/21, 86/1 & 85/15/2 Ghevra, Delhi, comprised of Basement, Ground Floor (one restaurant Café 24 & 04 Banquet hall namely- Banquet Hall No.- 01 Crystal Ball, Banquet Hall No.- 02 Royal Ball, Banquet Hall No.- 03 Grand Ball, Banquet Hall No.- 04 Elite Ball) and First Floor (30 rooms), owned / occupied by M/s Murti Hospitality Pvt. Ltd., was issued fire safety certificate by this department vide letter F6/DFS/MS/BP/2018/Motel/41 dated 04.01.2018. The premises was re-inspected by the officer concerned of this department on 05/02/2021 in the presence of Sh. Manish (Manager) and found that the owner have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building / premises is fit for occupancy class **Assembly (Group – D)** with effect from *18/02/2021* for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on*18/02/2021*..... at New Delhi.

[Signature]
(DHARAMPAL BHARDWAJ)
Dy. CHIEF FIRE OFFICER
West Zone

Copy to: -

1. The Director, M/s Murti Hospitality Pvt. Ltd. at K.N. 86/10, 86/11, 86/20, 78/21, 86/1 & 85/15/2 Ghevra, Delhi.
2. The Joint Commissioner of Police, Licensing Unit, 1st Floor, Police Station Defence Colony, New Delhi.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. “The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form ‘J’ [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry”.
8. The owner / occupier shall submit a declaration every year in form “K” provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.Delhigovt.nic.in.

1. Name & address of the building: Murti Hospitality Pvt. Ltd. K.N. 86/10, 86/11, 86/20, 78/21, 86/1 & 85/15/2 Ghevra, Delhi.
2. Type of Occupancy : Assembly (Group D)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/BP/2018/Motel/41 dated 04/01/2018
5. Fire Safety directives Letter No. : F-6/DFS/MS/BP/2006/1984 dated 09/08/2006 & F6/DFS/MS/BP/GH/2006/3629 dated 13/12/2006
6. Date of inspection : 05/02/2021
7. Name of the Inspecting Officer : Aman Kumar Lathar A.D.O. (JWP)
8. Name and designation of Officer from the building side : Sh. Manish(Manager)
9. Year of Construction : 2006-2007
10. Applicant's letter No. : - Email – hotelcitypark.tvagi@gmail.com
Dated 05/01/2021

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	9 mts	60 mts	MR
	• Gate width	5mtr	6 mtr	MR
	• Width of internal road	6mtr	6mtr	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	5 nos	MR
	• Basements	2	5 nos	MR
	b. Width of staircases			
	• Upper floors	5 feet	5feet	MR
	• Basements	5 feet	5feet	MR
	Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	c. No of continuous staircase to terrace	2	5	MR
	d. Width Of Corridor	1.5 mts	Provided	MR
	e. Door Size	1 mtr	Provided	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Sealed	MR
	• Fire Rating of shaft door	4 hrs	4 hrs	MR
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	Required	Provided	MR
4.	Smoke managements System			
	• Basements	Required	Provided	MR
	• Upper floors	NR	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	20	36	M/R
	• Types	DCP/WCO ² /CO ₂	Provided	M/R
	• IS marking	Required	Provided	M/R

	• Total numbers on each floor	03	Provided	MR
	• Length of hose reel hose	30 mtr	36 mtr	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	Required	Smoke Detector Provided	MR
	• Location of Main Panel	Required	G. Floor	MR
	• Location of Repeater Panel	Required	F. Floor	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false c.eiling	Required	Provided	MR
11.	Internal Hydrants			
	• Size of riser/down- comer	150 mm	150 mm	MR
	• Number of hydrants per floor	03	3 Nos	MR
	• Hose Box	3 Per Floor	3 Nos Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	Required	Provided	MR
	• Hose Box	Required	Provided	MR
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	1620 LPM	1620 LPM	MR
	➤ Head of main pump	45 mtr	90mtr	MR
	➤ Number of main pumps	1	1	MR
	➤ Jockey pump out put	180 LPM	180 LPM	MR
	➤ Jockey pump head	45 mtr	60 mtr	MR
	➤ Standby Pump out put	1620 LPM	1620 LPM	MR
	➤ Standby Pump Head	45 mtr	90mtr	MR
	➤ Auto Staring/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	900 LPM	900 LPM	MR
	➤ Head of the pump	45mtr	45 mtr	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	1,00,000 ltr	1,50,000 ltr	MR
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR

M224

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NR	NR	MR
	➤ Pressurization of lift lobby	Not Required	Not Provided	MR
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	NR	D.G. Set 62 K.V.A.	MR
18.	Refuge Area			
	➤ Total area	Not Required	Not Required	Not Required
	➤ Location	NR	NR	MR
19.	Fire control room			
	➤ Detector system panel	NR.	Provided	MR
	➤ Flow Switch Panel	NR	Provided	MR
	➤ PA System Panel	Required	Provided	MR
	➤ Batter backup	NR	Provided	MR
	➤ Building Floor Plans	Required	available	MR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F6/DFS/MS/BP/2018/Motel/41 dated 04/01/2018, renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

DFA is put up for approval & signature please.

D.O. (WEST) 27
DATED 10/02/2021

~~AO (W)~~

~~AO~~
10/02/2021

~~DCFO (W2)~~

~~ADP/AMP~~

~~DCFO (W2)~~

F.I. letter is put-up for signature of.

~~Signature of the Inspecting Officer~~
Name : Aman Kumar Lathar
Designation: A.D.O. (Jwp)

~~Signature of the Inspecting Officer~~
17/02/21
ADP (JWP)