

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2021 / *School / WZ / 129*

Dated: *17/2/2021*

FIRE SAFETY CERTIFICATE

Certified that the **Sarvodaya Vidyalaya** located at **New Police Line, Kingsway Camp, Delhi-110009** comprised of **Ground + 03 upper floors** owned/ occupied by **Sarvodaya Vidyalaya** was issued Fire Safety Certificated vide this office letter no. **F-6/DFS/MS/2017/School/WZ/145** dated **03.02.2017** the premise was re-inspected by the officer concerned of this department on **12.02.2021** in the presence of **Sh. D.C. Mehar (Principal)** and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition. The premise have therefore deemed complied with the requirements under rule 33 of the Delhi Fire Service Rules, 2010 and the building premise is fit for occupancy under **Educational "Group B"** with effect from **...17/2/21...** for a period of **three years** in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

Issued on **...17/2/21...** at New Delhi by

(Signature)
(Dharampal Bhardwaj)
Dy.Chief Fire Officer
Ph:-011-25156707
etc/p

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Principal, Sarvodaya Vidyalaya, New Police Line, Kingsway Camp, Delhi-110009.

Conditions for the validity of Fire Safety Certificate:

- 1 All the means of escape/entry/exit shall be kept free from any obstruction.
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
- 3 All the staff members must know the correct method of operation of firefighting system.
- 4 The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doi/fire/FIRE/Home/Forms>.
- 5 This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
- 6 "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

1. Name & address of the building : Sarvodaya Vidyalaya, New Police Line, Kingsway Camp, Delhi-110009.
 2. Type of Occupancy : Educational
 3. Type of Case : Renewal (Ground + 03 upper floor)
 4. Details of previous NOC : F6/DFS/MS/2017/School/WZ/145 Dated: 03.02.2017
 5. Fire Safety directives letter No : NBC Part-4
 6. Date of inspection : 12.02.2021
 7. Name of the Inspecting Officers : ADO (RN)
 8. Name and designation of officers from the building side : Sh. D.C. Mehar (Principal)
 9. Year of Construction : 1982
 10. Applicant's letter No. : Online E-Mail I.D dated: 01.02.2021

Plot area-5540Sqyds

Covered area-4742Sqyds

No's of student-1950nos

Class rooms-37nos


	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	09	18m	MR
	• Gate width	4.5m	5.05m	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	02	02	MR
	• Upper Floors	NA	NA	NA
	• Basements			
	b. Width of staircases			
	• Upper Floors	1.50m	1.42m each	MR(old case)
	• Basements	NA	NA	NA
	c. Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization	01	01	MR
	d. No. of continuous staircases to terrace	1.5m	1.5m	MR
	e. Width of Corridor	1 m	1m	MR
	f. Door Size			
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural Ventilated	MR
5	Fire Extinguishers			
	• Total numbers	16nos	16nos	MR
	• Types	ABC/Co2	ABC-10 Co2-4	MR

6	First-Aid Hose Reels.(New Block-III & IV)			
	• Total numbers on each floor	02	02	MR
	• Length of hose reel hose	30 m	30m	MR
	• Nozzle diameter	5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA			
9	Public Address System.			
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	100mm	Provided	MR
	• Number of hydrants per floor	02	Provided	MR
	• Hose Box	02	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450lpm	450lpm	MR
	➤ Head of the pump	40m	40m	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA

	• Overhead Tank capacity	10,000 ltr	10,000 ltr.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in good working condition, at the time of inspection. The management has complied all the shortcomings issued and communicated by this department vide letter of even no. 579 dated 20.08.2020.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in NBC Part-4, the FSC issued vide letter of even no 145 dated 03.07.2017 renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended


 Signature of the Inspecting Officer
 Name :-C.L. Meena
 Designation:- ADO/RN

DO(N/W)

15/02/2021

15/02/2021

15/02/2021

ADO/R.N.

As approved, F.T. letter is put up for your signature pls

DO(N/W)

17/02/2021