

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**


No.F.6 DFS/MS/School/2021/SZ/ 125

Dated: 17 / 2 / 2021

FIRE SAFETY CERTIFICATE

Certified that the **Sarvodaya Co-ed Vidyalaya, Masjid Moth South-II, New Delhi- 110049** (ID- 1925246) comprised of ground plus three upper floors was granted Fire Safety Certificate by this department vide letter No F6/DFS/MS/School/2018/SZ/928 Dt. 04/05/2018. The said premises was re-inspected by officer concerned of this department on 15/01/2021 in presence of Dr. Santhosh Kumar (Principal) of the school and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class "**Educational Building Group – B**" with effect from 17 / 2 / 2021 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 17 / 2 2021 at New Delhi by



(Sunil Chawdhary)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service



Copy to: -

1. The Principal, Sarvodaya Co-ed Vidyalaya, Masjid Moth South-II, New Delhi- 110049
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.


Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This certificate cannot be treated as regularization of unauthorized construction, if any.
5. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

20-4

INSPECTION REPORT

1	Name & Address of the Building	Sarvodaya Co-ed Vidyalaya Masjid Moth, South Ex-II, New Delhi 110049 (ID-1925246)		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	Ground + three upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/School/2018/SZ/928 Dt. 04/05/2018		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	15/01/2021		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Dr. Santhosh Kumar (Vice-Principal)		
10	Year of construction	1985		
11	Applicant letter No.	Gmail Dated 13/01/2021		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	As Per Old NOC	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	Required	6 mtr ✓	MR
	• Gate width	-NA-	-NA-	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	02 No's	Provided ✓	MR
	➤ Basement floor.	-NA-	-NA-	-NA-
	b) Width of Staircase			
	➤ Upper floors	1.50 m	1.40 mtr each ✓	MR
	➤ Basement floor	-NA-	-NA-	-NA-
	c) Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	Required	Provided ✓	MR
	e) Width of corridor	1.50 mtr	Provided ✓	MR
	f) Door size	1 mtr	1 mtr ✓	MR
3	Compartmentation.			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	• Basement	-NA-	-NA-	-NA-
	• Upper floors	-NA-	-NA-	-NA-
5.	Fire Extinguishers.			
	• Total numbers	16 no's	17 Nos ✓	MR
	• Types	ABC / co2	ABC & co2 Type	MR
	• ISI Marking	ISI mark	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	02 No's	Provided ✓	MR
	• Length of hose-reel hose.	30 m	Provided ✓	MR
	• Nozzle Diameter	5 mm	Provided ✓	MR
7	Automatic fire detection & alarming system.			
	• Type of detectors	-NA-	-NA-	-NA-
	• Location of Main Panel	-NA-	-NA-	-NA-
	• Location of Repeater Panel	-NA-	-NA-	-NA-

20.	Special Fire Protection System for the Protection of special Risk, if any.	-NA-	-NA-	-NA-
<p>The fire protection systems provided in the building were tested/ checked randomly and found some observations at the time of inspection.</p> <p>Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/School/2018/SZ/928 Dt. 04/05/2018, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.</p> <p>Accordingly, DFA is put up for approval and signature please.</p> <div style="text-align: right;">  Signature of the Inspecting Officer Name: Sh. Rajesh Kumar Design: ADO (BCP) </div>				

20/5/18

10/02

Df6/12

11/2

F. f. please

ADO BCP

As approved, F.T. letter is put up for your signature pl

11/4
16/2

24/6/18

M.S. 