

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No.F6/DFS/MS/SZ/2021/ 125

Dated: 17/02/2021

FIRE SAFETY CERTIFICATE

Certified that the building Sh. Mool Chand Dua Memorial Society, Plot No.1, Dwarka, New Delhi.comprised of ground plus one upper floor owned/ occupied by Sh. Mool Chand Dua Memorial Society was granted Fire Safety Certificate vide this office letter no F.6/DFS/MS/2017/SZ/1755 Dated 07/12/2017. The said building was re-inspected by the officer concerned of this department on 06/02/2021 in presence Sh Sanjay Gupta (representative) and found that the premises have deemed complied fire prevention & fire safety requirements in accordance with rule 33 of the Delhi Fire Service and that the building is fit for occupancy class D "Assembly building" (Temple) with effect from 17/02/2021 for a period of three years, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 as printed below.

Issued on ...17/02/2021... at New Delhi by.


(Sunil Chaudhary)
Dy. Chief Fire Officer,
Delhi Fire Service.

Copy to:

1. Sh Sanjay Gupta. Mool Chand Dua Memorial Society, Plot No.1 Dwarka, New Delhi-110075
2. The Jt. Director (L&I) Bldg. DDA Building Section INA Vikas Sadan, New Delhi.

Following fire safety directives must be adhered to:-

- 1 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 2 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 3 The trained staff should be available round the clock.
- 4 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 5 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 6 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
- 7 Basement shall be used strictly as per building bye laws.
- 8 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

Re inspection to see the compliance of shortcomings communicated vide letter no. F6/DFS/MS/SZ/2020/3057 dated 15/12/2020 are complied

INSPECTION REPORT

1. Name & address of the building: Sh. Mool Chand Dua Memorial Society, Located at Plot No.1, Dwarka, New Delhi.
2. Type of Occupancy : Assembly Building (Ground + 01 Upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/2017/SZ/1755 Dated 07/12/2017
5. Fire Safety directives Letter No. : F6/DFS/MS/BP/2010/1180 dated 23-04-10
6. Date of inspection : 06-02-2021
7. Name of the Inspecting Officer : Udai vir singh, ADO (DWK)
8. Name and designation of Officer
from the building side : Sh Sanjay Gupta
9. Year of Construction : 2013
10. Applicant's letter No. : Email dated 01-02-2021

No. of Students= 100
No. of rooms = Two Halls
Plot area=361.11Sq.m²
Covered area=138sqm²

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	9 m	9 m	MR
	• Gate width	5 m	5 m	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2 Nos.	2 Nos.	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 m, 1.25m	1.5 m, 1m(Iron)	MR(old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2 m	Old case	MR(Being Old case)

3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door 	NA	NA	NA
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	NA	NA	NA
	<ul style="list-style-type: none"> • Water Curtain 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Dampers 	NA	NA	NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements 	NA	NA	NA
	<ul style="list-style-type: none"> • Upper floors 	12 a/c per hour	Natural Ventilation	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	6 nos.	Provided	MR
	<ul style="list-style-type: none"> • Types 	CO ₂ &ABC	ABC	MR
	<ul style="list-style-type: none"> • IS marking 	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor 	Required	Provided	MR
	<ul style="list-style-type: none"> • Length of hose reel 	36 m	36 m	MR
	<ul style="list-style-type: none"> • hose 	5 mm	5 mm	MR
	<ul style="list-style-type: none"> • Nozzle diameter 			
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors 	NA	NA	NA
	<ul style="list-style-type: none"> • Location of Main Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Alternate source of power 	NA	NA	NA
	<ul style="list-style-type: none"> • Hooters' Location 	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basements 	NA	NA	NA
	<ul style="list-style-type: none"> • Upper Floor 	NA	NA	NA
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	NA	NA	NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down- comer 	100 mm	Provided	MR
	<ul style="list-style-type: none"> • Number of hydrants per floor 	One	One	MR
	<ul style="list-style-type: none"> • Hose Box 	Required	Required	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> • Hose Box 	NA	NA	NA

13.	Pumping Arrangements			
	<ul style="list-style-type: none"> • Ground Level • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		450 lpm,180lpm	Provided	MR
		35 m	35 m	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw of connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		10,000 litres	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply	Required	DG Set 62 KVA	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> ➤ Total area ➤ Location 	NA	NA	NA
		NA	NA	NA
19.	Fire control room			
	<ul style="list-style-type: none"> ➤ Detector system panel ➤ Flow Switch Panel ➤ PA System Panel ➤ Battery backup ➤ Building Floor Plans 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA

20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	CO2 Fire extinguisher provided near electric panel	MR
-----	--	----	--	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F.6/DFS/MS/2017/SZ/1755 Dated 07/12/2017 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

Name

Designation

10/12/2021
Uday Vir Singh
ADD/DCW

10/12/21

10/12/2021

Dy CFO (S2)

F. F. - please
ADD/DCW

Sir RT letter is put up for signature

Dy CFO (S2)

10/12/21

~~*ADD/DCW*~~ *M.S. cel*