

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001**

No.F6/DFS/MS/School/NDZ/2021

1145

Dated: 19/2/21

**FIRE SAFETY CERTIFICATE**

Certified that the **M.C.P. CO-ED School, 1095, Paiwalan, Jama Masjid Delhi-06**, comprised of **ground plus + 1 upper floor** (School is running at ground floor only), was granted Fire Safety Certificate by this department vide Letter No- F6/DFS/MS/School/2017/NDZ/1839 dated 20.12.2017. The school building was re-inspected by Assistant Divisional Officer (SPM) from this department on 16.02.2021 in the presence of Mrs. Uzma Aziz, Incharge and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the circular No. F.16/Estate/CC/Fire safety/2011/3298 to 3398 dated 01.03.11 issued by the Director of Education and the building (**Ground floor only**) is fit for occupancy of Group B "Educational Building" with effect from 19/2/21 renewed for a period of three years, subject to conditions printed below.

Issued on 19/2/21 at New Delhi by

  
18/2/21


(Dr. S.K. Tomar)

Dy. Chief Fire Officer

Tel: 011-23412025

**Copy to:-**

1. The Principal  
M.C.P. CO-ED School, 1095, Paiwalan, Jama Masjid Delhi-06
2. The Director of Education,  
North Delhi Municipal Corporation, City S.P. Zone, Old Hindu College, Kashmiri Gate, Delhi

etc   
17/2/21

**Condition for the validity of fire safety certificate**

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)



~ / 8

### INSPECTION REPORT

1	Name & address of the building	M.C.P. CO-ED School, 1095, Paiwalan, Jama Masjid Delhi-06		
2	Building is comprised of	Ground + 1 upper floor ( School is running at ground floor only)		
3	Type of Occupancy	Group B –Educational Building		
4	Type of Case	Renewal		
5	Details of Previous FSC	F6/DFS/MS/School/2017/NDZ/1839 dated 20.12.2017		
6	Fire Safety direction letter No	NA		
7	Date of Inspection	16.02.2021		
8	Name of the Inspecting Officers	Rajesh Kumar Shukla ADO (SPM)		
9	Name of the designation of Officer from the building side	Mrs. Uzma Aziz, Incharge		
10	Year of Construction	1950		
11	Applicant's letter No	Email dated 12.02.2021		
S.No	Minimum Standards on fire safety requirements as per circular no. 3298 to 3398 Dated. 01.03.11	Requirement	Provided at Site	Remarks MR/NMR
1	<b>Access to building</b>			
	Road width	06 m	06 m	MR
	Gate width	NA	NA	NA
	Width of internal road	NA	NA	NA
2	<b>Number, Width, Type and Arrangement of Exits</b>			
	<b>A. Number of Staircases</b>			
	Upper Floor	NA	01 no.	MR
	Basement	NA	NA	NA
	<b>B. Width of Staircases</b>			
	Upper Floor	NA	0.65 m	MR (School is running at ground floor only)
	Basement	NA	NA	NA
	<b>C. Protection of exits</b>			
	Fire check door	NA	NA	NA
	Pressurization	NA	NA	NA
	D. No. of continuous staircases to terrace	01 no.	01 no.	MR
	E. Width of Corridor	NA	NA	NA
	G. Door size	1 m	1 m	MR
3	<b>Compartmentation</b>			
	Fire check door	NA	NA	NA
	Sealing of electrical shafts	NA	NA	NA
	Fire rating of shaft door	NA	NA	NA
	Water curtain	NA	NA	NA
	Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	Basement	30a/c per hour	NA	NA
	Upper floor	12 a/c per hour	NA	NA

*Da.*




<b>5.</b>	<b>Fire Extinguisher</b>			
	Total numbers	02 no.	03 no.	<b>MR</b>
	types	CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC	<b>MR</b>
	IS marking	ISI marked	ISI marked	<b>MR</b>
<b>6</b>	<b>First-aid-Hose Reels.</b>			
	Total numbers of each floor	NA	NA	NA
	Length of hose reel hose	NA	NA	NA
	Nozzle diameter	NA	NA	NA
<b>7</b>	<b>Automatic fire detection and alarming system.</b>			
	Type of detectors	NA	NA	NA
	Location of main panel	NA	NA	NA
	Location of repeater panel	NA	NA	NA
	Alternate source of power	NA	NA	NA
	Hooters	NA	NA	NA
<b>8</b>	<b>MOEFA</b>	NA	NA	NA
<b>9</b>	<b>Public address System.</b>	NA	NA	NA
<b>10</b>	<b>Automatic Sprinkler System.</b>			
	basement	NA	NA	NA
	upper floor	NA	NA	NA
	Sprinkler above false ceiling	NA	NA	NA
<b>11</b>	<b>Internal Hydrants</b>			
	size of riser/down-comer	NA	NA	NA
	Number of hydrants per floor	NA	NA	NA
	Hose Box	NA	NA	NA
<b>12</b>	<b>Yard Hydrants.</b>			
	Total number of hydrants	NA	NA	NA
	Hose Box	NA	NA	NA
<b>13</b>	<b>Pumping Arrangements.</b>			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main Pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby pump out put	NA	NA	NA
	➤ Standby pump Head	NA	NA	NA
	➤ Auto Starting /Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace Level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the Pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA

N/10

<b>14</b>	<b>Captive Water Storage for Fire Fighting.</b>			
	Underground tank capacity	NA	NA	NA
	Draw-off connection	NA	NA	NA
	Fire service inlet	NA	NA	NA
	Access to tank	NA	NA	NA
	Overhead Tank capacity	NA	NA	NA
<b>15</b>	<b>Exit Signage.</b>	NA	NA	NA
<b>16</b>	<b>Provision of Lifts.</b>			
	Pressurization of Lift Shaft	NA	NA	NA
	Pressurization of Lift lobby	NA	NA	NA
	Communication in lift car	NA	NA	NA
	Firemen's grounding switch	NA	NA	NA
	Lift Signage	NA	NA	NA
<b>17</b>	<b>Standby power supply</b>	NA	NA	NA
<b>18</b>	<b>Refuge Area.</b>			
	Total area	N.A	N.A	N.A
	Location	N.A	N.A	N.A
<b>19</b>	<b>Fire Control Room</b>			
	Detector system panel	NA	NA	NA
	Flow switch panel	NA	NA	NA
	PA system panel	NA	NA	NA
	Batter backup	NA	NA	NA
	Building Floor Plans	NA	NA	NA
<b>20</b>	<b>Special Fire Protection systems for protection of special Risks, if any:</b>		NA	NA

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter No. F6/DFS/MS/School/2017/NDZ/1839 dated 20.12.2017 is recommended to be renewed under Rule 35 of the Delhi Fire Service Rules 2010.

  
17/12/21


Signature of the Inspecting Officer


Name Rajesh Kumar Shukla

Designation ADO (SPM)

DO (CD)

  
18/12



  
18/12/21

M.S.CEU