

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE

[See sub-rule (1) of rule 35]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/SH/2021/SZ/ *Audi/129*

Dated *18/02/2021*

FIRE SAFETY CERTIFICATE

Certified that the M/s Sirifort Auditorium Complex (Auditorium 1, 2, 3 & 4) located at August Kranti Marg, New Delhi-110049 comprised of Basement, Ground & 1st Floor only, owned and occupied by Directorate of Film Festivals, has already been issued fire safety certificate vide letter No. F6/DFS/MS/2017/Audi/956 dated 04/07/2017. The premises was re-inspected by the officer concerned of Fire Service on dated 09.02.2021 in the presence of Sh. Om Parkash (Electrical Engineer) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the fire prevention and fire safety in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the building / premises is fit for occupancy Class "Assembly" (Group-D) (Auditorium) with effect from *18 / 02 / 2021* for a period of **three years**, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on *18/02/2021* at New Delhi.



(SUNIL CHAWDHARY)

DY. CHIEF FIRE OFFICER (S.Z.).

Copy to :-

1. Authorized Signatory, M/s Sirifort Auditorium Complex (Auditorium 1, 2, 3 & 4) located at August Kranti Marg, New Delhi-110049.
2. Joint Commissioner of Police (Lic.), PS Defence Colony, New Delhi-110024.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

- 1, 2, 3 & 4) located at August Kranti Marg, New Delhi-110049.
2. Type of Occupancy : Assembly
 3. Building Comprised of : Basement (Storage & Services), ground plus one upper floor. (Auditorium-1 having 1865 seats at ground and first floor balcony only, Auditorium -2 having 72 seats at ground floor only). Audi-1, 3 & 4 are in same interconnected block and Audi-2 is in separate block. Both blocks are having basement but non interconnected.
 4. Type of Case : Renewal
 5. Details of previous NOC : F6/DFS/MS/2017/Audi/956 dated 04/07/2017
 6. Fire Safety directives Letter No. : Nil
 7. Date of inspection : 09/02/2021
 8. Name of the Inspecting Officer : A.D.O. (S.J.)
 9. Name and designation of Officer from the building side : Sh. Omparkash (Electrical Engineer)
 10. Year of Construction : 1982
 11. Applicant's letter No. : 69/21/2012-FFD (SF) dated 03/02/2021

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirements / Existing Fire Protection System	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	9m	15m	MR
	• Gate width	5m	5m	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	8	8	MR
	• Basements	6	6	MR
	b. Width of staircases			
	• Upper floors	1.5m	1.5m	MR
	• Basements	1.5m	1.5m	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	2	2	MR
	e. Width Of Corridor	N/A	N/A	N/A
	f. Door Size	Required	Audi-I=7 at GF & 8 at balcony level, Audi-II=4 at GF, Audi-III=2at GF & 2 at balcony level, Audi-IV=2 at GF level (Each exit door is 1.35m wide)	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	30 a/c per hour	Mechanical Ventilation provided & functional	MR
	• Upper floors	12 a/c per hour	Exhaust Fans Provided	MR
5.	Fire Extinguishers			
	• Total numbers	200	200	MR
	• Types	ABC / CO2	Provided	MR

6.	First – Aid Hose Reels			
	• Total numbers on each floor	2 at basement, 9 at GF & 4 at 1 st Floor	2 at basement, 9 at GF & 4 at 1 st Floor	MR
	• Length of hose reel hose	30 m	30 m	MR
	• Nozzle diameter	5 mm	5 mm	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	Smoke, Heat & Beam	N/A	N/A
	• Location of Main Panel	Ground Floor	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	All Areas	All Areas	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	Required	Provided	MR
11.	Internal Hydrants			
	• Size of riser/down-comer	150 mm	Provided	MR
	• Number of hydrants per floor	2 at basement, 9 at GF & 4 at 1 st Floor	2 at basement, 9 at GF & 4 at 1 st Floor	MR
	• Hose Box	2 at basement, 9 at GF & 4 at 1 st Floor	2 at basement, 9 at GF & 4 at 1 st Floor	MR
12.	Yard Hydrants			
	• Total number of hydrants	10	10	MR
	• Hose Box	10	10	MR
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	2280 LPM	Provided	MR
	➤ Head of main pump	55m	Provided	MR
	➤ Number of main pumps	2	Provided	MR
	➤ Jockey pump out put	225 LPM	Provided	MR
	➤ Jockey pump head	55m	Provided	MR
	➤ Standby Pump out put	2280 LPM	Provided	MR
	➤ Standby Pump Head	55m	Provided	MR
	➤ Auto Starting/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto starting of pump	N/A	N/A	N/A
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	1,00,000 ltr	Provided	MR
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	CO2 flooding system	Provided	MR

Note:- Shortcomings issued by this department vide letter No. F6/DFS/MS/2020/SZ/Audi/3039 dated 14/12/2020 have been complied.

The fire protection systems provided in the building were test checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. **F6/DFS/MS/2017/Audi/956 dated 04/07/2017** renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Ashok
11/02/2021

Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : A.D.O. (S.J.)

DO (S.D.) *K.V.*
15/02

DUFO (S.J.)

F.T. please
[Signature]

F.T. is added please.