

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001


No F 6 / DFS / MS / 2021 / WZ/EN/39

Dated: 22/02/2021

FIRE SAFETY CERTIFICATE

Certified that the M/s B Lounge and Bar located at First Floor, Plot No.11, Block-02, Roop Nagar, Delhi-110007 in the building comprised of basement + stilt + upper ground and 03 upper floors owned/occupied by B Lounge have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 18.02.2021 in the presence of Sh. Luv (Manager) and that the building/ premise is fit for occupancy Class Assembly restaurant at first floor only with effect from 22/02/2021 for a period of 03 (Three) years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 22/02/2021 at New Delhi by


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. M/s B Lounge and Bar at Plot No 11, Block- 02, FF, Roop Nagar, Delhi-110007.
2. The Dy. Commissioner, (Civil Line Zone) North Delhi Municipal Corporation, 16, Rajpura Road, New Delhi-110054.
3. The Joint Commissioner of Police (Lic.), First Floor, P.S. Defence Colony, New Delhi-110049.

Conditions for the validity of Fire Safety Certificate:

- 1 All the means of escape/entry/exit shall be kept free from any obstruction.
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
- 3 All the staff members must know the correct method of operation of firefighting system.
- 4 The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doi/fire/FIRE/Home/Forms>.
- 5 This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
- 6 "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

- | | | |
|---|--|--------------------------------|
| 1. Name & address of the building | : M/s B Lounge at Plot No 11, Block- 02, FF, Roop Nagar, Delhi-110007. | |
| 2. Type of Occupancy | : Assembly (B + Stilt + G+ 03 upper floors) | |
| 3. Type of Case | : New case | Basement – Vacant |
| 4. Details of previous NOC | : Nil | Stilt - Parking |
| 5. Fire Safety directives letter No | : NBC Part –IV | Upper Ground- Vacant |
| 6. Date of inspection | : 18.02.2021 | First floor- Restaurant |
| 7. Name of the Inspecting Officers | : ADO (RN) | Second floor- Other Property |
| 8. Name and designation of officers
from the building side | : Sh. Luv (Manager) | Third floor- Other Property |
| 9. Year of Construction | : 2009 | |
| 10. Applicant's letter No. | : Online Email I D Dated: 11.02.2021 | |

	Minimum Standards on fire prevention and fire safety U/R 33	BBL / NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6m	06m	MR
	• Gate width	4.5	Directly Accessible	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	03	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	02m & 1.5m	02m & 1.50m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	02m & 1.50m	02m & 1.50m	MR
3	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	12 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Exhaust Fan	MR
5	Fire Extinguishers			
	• Total numbers	06nos	08 nos	MR
	• Types	ABC & Co2	ABC- 08	MR
	• ISI marking	Yes	Yes	MR
6	Fire Alarm			

	<ul style="list-style-type: none"> Total numbers on each floor 	01	Provided	MR
	<ul style="list-style-type: none"> Length of hose reel hose 	30m	30m	MR
	<ul style="list-style-type: none"> Nozzle diameter 	5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	Required	Provided	MR
	<ul style="list-style-type: none"> Location of Main Panel 	Required	Provided	MR
	<ul style="list-style-type: none"> Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Alternate source of power 	Required	Provided	MR
	<ul style="list-style-type: none"> Hooters' Location 	Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement 	NA	NA	NA
	<ul style="list-style-type: none"> Upper Floor 	NA	Provided	NA
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	Required,01	Provided	MR
	<ul style="list-style-type: none"> Number of hydrants per floor 	01	01	MR
	<ul style="list-style-type: none"> Hose Box 	01	01	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access 	N/A	N/A	N/A
		N/A	N/A	N/A
		NA	NA	NA
		NA	NA	NA
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	<ul style="list-style-type: none"> Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	450lpm	450lpm	MR
		40m	40m	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity 	NA	NA	NA
	<ul style="list-style-type: none"> Draw-off connection 	NA	NA	NA
	<ul style="list-style-type: none"> Fire service inlet 	Required	Provided	MR
	<ul style="list-style-type: none"> Access to tank 	Required	Provided	MR
	<ul style="list-style-type: none"> Overhead Tank capacity 	20,000 ltr	20,000 ltr.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			

	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	Required	D G Set 62kva	MR
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested/ checked and found some in working order at the time of inspection. The observations/ shortcomings issued and communicated vide this department letter of even no.62 dated.29.01.2021 have been compiled by the management.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

DO (F/W)

18/02/2021

19/2/21

19/2/21

19/2

22/02/2021

FPS

ADU n n
letter to put up for sign

22/2/2021

(Signature)

Signature of the Inspecting Officer
Name :- C.L. Meena
Designation:- ADO/RN

