

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2021 / School / WZ / 162


Dated: 26/2/21

FIRE SAFETY CERTIFICATE

Certified that the **Bhagatji Memorial Model Sec. School** located at **34/8/1, Yamuna Road, Palla, Delhi-110036** comprised of Ground and two upper floors owned/occupied by **Bhagatji Memorial Model Sec. School** was issued FSC by this department vide letter No **F-6/DFS/MS/2018/School/WZ/744** dated 20.04.2018. The building was inspected by the officer concerned of this department on 11.02.2021 in the presence of Sh Jai Prakash (Vice Principal), and observed that all the fire prevention and fire safety arrangements as provided in the building found in good working condition. The premises have deemed complied with the requirements under rule 33 of the Delhi Fire Service Rules, 2010 and the building/ premise is fit for occupancy **Group B Educational** with effect from **26/2/21**..... for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on **26/2/21**..... at New Delhi

Yours faithfully


Dharampal Bhardwaj
Dy. CHIEF FIRE OFFICER
WEST ZONE

Copy to : -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi-54.
2. The Vice Principal, Bhagatji Memorial Model Sec. School, 34/8/1, Yamuna Road, Palla, Delhi-36.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Bhagatji Memorial Model Sec. School, 34/8/1, Yamuna Road, Palla, Delhi-110036
2. Type of Occupancy : Educational
3. Building Comprised : Ground + Two upper floors
4. Type of Case : Renewal
5. Details of Previous NOC : Letter No. F.6/DFS/MS/2018/SCHOOL/WZ/744 Dated-20/04/2018
6. Fire Safety directives letter No : NBC Part-IV
7. Date of inspection : 11/02/2021
8. Name of Inspecting Officer : ADO (BW)
9. Name and designation of officers
From the building side : Sh. Jai Prakash (Vice Principal)
10. Year of Construction : 2001
11. Applicant's letter No. : E Mail id , Dated-01/02/2021

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	6.0 m	6.0 m	MR
	• Gate width	4.5 m	4.5 m	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	NA	NA	NA
	• Upper Floors	02	02	MR
	• Basements(small basement)	NA	NA	NA
	b. Width of staircases	NA	NA	NA
	• Upper Floor	1.50 m	1.77 & 1.27 m	MR(old case)
	• Basements	NA	NA	NA
	c. Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	01	MR
	e. Width of Corridor	1.50m	Provided	MR
	f. Door Size	1.00 m	1.00 m double door	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	30 a/c per hour	NA	NA

Dk

	<ul style="list-style-type: none"> Upper floors 	12 a/c per hour	Natural Ventilated	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers 	08 nos	18 nos	MR
	<ul style="list-style-type: none"> Types 	ABC	ABC	MR
	<ul style="list-style-type: none"> IS marking 	Yes	Yes	MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor 	01	01	MR
	<ul style="list-style-type: none"> Length of hose reel hose 	30 m	Provided	MR
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors 	NA	NA	NA
	<ul style="list-style-type: none"> Location of Main Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Alternate source of power 	NA	NA	NA
	<ul style="list-style-type: none"> Hooters' Location 	NA	NA	NA
8.	MOEFA			
		NA	NA	NA
9.	Public Address System			
		NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement 	NA	NA	NA
	<ul style="list-style-type: none"> Ground Floor 	NA	NA	NA
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	NA	NA	NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	100 mm	Provided	MR
	<ul style="list-style-type: none"> Number of hydrants per floor 	01	Provided	MR
	<ul style="list-style-type: none"> Hose Box 	01	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> ➤ Discharge of main Pump 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Head of Main pump 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Number of main pumps 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Jockey Pump out put 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Jockey pump head 	180 lpm	180 lpm	MR
	<ul style="list-style-type: none"> ➤ Standby Pump out put 	40 m	40 m	MR
	<ul style="list-style-type: none"> ➤ Standby Pump Head 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Auto Starting/Manual Stopping 	NA	NA	NA
		NA	NA	NA

DN

	➤ Pump House Access	NA	NA	NA
	• Terrace level	450 lpm	450 lpm	MR
	➤ Discharge of pump	40 m	40 m	MR
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	-	-	-
	➤ Auto Starting of pump	NA	NA	NA
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	5000 ltrs	7000 ltrs	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

--	--	--	--	--

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the above deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules is recommended for renewal of Fire Safety Certificate issued vide letter no.F6/DFS/MS/2018/School/WZ/744 , under rule 37 of the Delhi Fire Service Rules 2010.

Do (N/W)

P1. Spear

18/02/2021

Ado (B.W.) Spear

19/2/2021

Do (N/W)

24/02/2021

Dy C/O, WZ

24/2/2021

Ado (B.W.)

As approved F-T letter is pending two signatures

Always

26/2/2021

Defo (WZ)

26/2/2021

17/2/2021

Signature of Inspecting Officer

Name : Rajeev Kumar Sinha

Designation : ADO/B.W.