

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/2021/School/WZ 1160

Dated: 25/2/21

FIRE SAFETY CERTIFICATE

Certified that the Building situated at Rajkiya Pratibha Vidhyalaya, Sec-11, Rohini, Delhi, comprised of Ground and 03 upper floors & Auditorium (Hall without seats) owned/occupied by Rajkiya Pratibha Vidhyalaya has already been issued FSC by this department vide letter No. F.6/DFS/MS/2017/School/WZ/1256 dated 22.08.2017. The premises was re-inspected by the officer concerned of this department on 02.02.2021 in the presence of Sh. Shiv Narayan Kaushik (Estate Manager) and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition. The premise have therefore deemed complied with the requirements under Rule 33 of the Delhi Fire Service Rules, 2010 and the building premises is fit for occupancy under Educational "Group B" with effect from 25/2/21 for a period of **03 years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 25/2/21..... at New Delhi by


(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel;-01123414250

Copy to :-

1. The Principal, Rajkiya Pratibha Vidhyalaya, Sec-11, Rohini, Delhi.
2. The Director of Education, GNCT of Delhi Old Secretariat, Delhi-110054.

Conditions for the validity of fire safety certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration **every year** in **Form 'K'**[sub rule (2) of Rule 38] provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on http://delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction (Clause 2.9.2 of UBBL-2016) or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of Rule 37] along with a copy of this Certificate, **six months** prior to its expiry."

INSPECTION REPORT

Single block Gr.+ three upper floor

1. Name & address of the building : Rajkiya Pratibha Vidhyalaya, Sec-11, Rohini, Delhi
2. Type of Occupancy : Educational
3. Type of Case : Renewal (Gr. + Three upper floors & one hall without seats)
4. Details of previous NOC : F6/DFS/MS/2017/School/WZ/1256 dated 22.08.2017
5. Fire Safety directives letter No : Dir of Education Circular dated 01.03.2011/NBC Part-IV
6. Date of inspection : 02.02.2021
7. Name of the Inspecting Officers : ADO (Rohini)
8. Name and designation of officers
from the building side : Sh. Shiv Narayan Kaushik (Estate Manager)
9. Year of Construction : 1999 + 2012 (Hall Construction)
10. Applicant's letter No. : Online mail id dated 02.11.2020

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part IV	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	12 mtr	M/R
	• Gate width	Accessible	5 mtr	M/R
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	N/A	N/A	N/A
	• Upper Floors	03	03	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper Floors	1.50 mtr	1.50 m each	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits	N/A	N/A	N/A
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	02	01	MR (Old case)
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	2.0 mtr Hall -5 exits	1.15 mtr & Hall Exits-2.40m	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basements	30 a/c per hour	N/A	N/A
	• Upper floors	12 a/c per hour	Natural ventilated	MR

	➤ Head of the pump	Required	Provided	MR
	➤ Power Supply	Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000 ltr	10,000 ltr	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F6/DFS/MS/2017/School/WZ/1256 dated 22.08.2017 is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

Ajay Kumar Sharma
19/2/21

Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO(Rohini)

DO (NW)

Ajay Kumar Sharma
19/2/2021