

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI


No: F.6/DFS/MS/SCHOOL/2021/ w2/169

Dated: / 02/03/2021

FIRE SAFETY CERTIFICATE

Certified that the building of **Kendriya Vidyalaya**, located at **Tagore Garden, New Delhi – 110027** comprised of **Ground plus two upper floors**, was issued FSC vide Letter No:- F6/DFS/MS/SCHOOL/2017/513 Dated 05/04/2017. The premises was re-inspected by the officer concerned of this department on 12/02/2021 in the presence of Sh. Mukesh Kumar (Principal) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No.F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 and that the premises is fit for occupancy class “Educational” Group B with effect from 02/03/2021 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 02/03/2021 at New Delhi by.


(Dharampal Bhardwaj)
Dy.Chief Fire Officer
Delhi Fire Service

o/c 

Copy to:-

1. The Principal,
Kendriya Vidyalaya, Tagore Garden, New Delhi - 110027.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good Working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per building bye laws.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form ‘K’ provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building : **Kendriya Vidyalaya, located at Tagore Garden, New Delhi – 110027.**
2. Type of Occupancy : Educational (Ground + 2 Upper Floor, 2 Blocks)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/SCHOOL/2017/513 Dated- 05/04/2017
5. Fire Safety directives Letter No. : DOE 3298-3398 dated 01/03/11
6. Date of inspection : 12/02/2021
7. Name of the Inspecting Officer : Sarabjeet Singh, ADO (MN)
8. Name and designation of Officer
from the building side : Sh. Mukesh Kumar (Principal)
9. Year of Construction : 1969
10. Applicant's letter No. : Email dated 27/01/2021

Total area = 32172 Sqm
Covered area = 5856Sqm
Class rooms = 60

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE 3298-3398 dated 01/03/11	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	Provided (12m)	MR
	• Gate width	Accessible	Provided (05m)	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02 at each block	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	2x1.5m (Each Block)	Block A-1x176 to 218cm, 1x150 cm & Block B-2x145 cm	MR (old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	01 at each block	Provided	MR
	e. Width Of Corridor	1.5m	Provided (235 cm)	MR
	f. Door Size	1 mtr	Provided	MR



3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	NA	NA	NA
		NA	NA	NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	31 nos. ABC & CO ₂ ISI marked	Provided,45	MR
			Provided	MR
			Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	2 on each floor	Provided	MR
		30m	Provided	MR
		5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8.	MOEFA	NR	Provided	NR
9.	Public Address System	NR	Provided	NR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basements • Upper Floor • Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> • Size of riser/down- comer • Number of hydrants per floor • Hose Box 	NR	Provided Down Comer	NR
		NR	Provided 2 on each floor	NR
		NR	Provided	NR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	NA	NA	NA
		NA	NA	NA


13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> • Ground Level • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		2x450 lpm	Provided	MR
		40Mtr	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		2x10,000Ltrs	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	<ul style="list-style-type: none"> ➤ Total area ➤ Location 	NA	NA	NA
		NA	NA	NA
19.	Fire control room			
	<ul style="list-style-type: none"> ➤ Detector system panel ➤ Flow Switch Panel ➤ PA System Panel ➤ Battery backup ➤ Building Floor Plans 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

Handwritten signature

N/19

The fire protection systems provided in the building were test checked and found functional at the time of inspection.


In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no.F6/DFS/MS/SCHOOL/2017/513, Dated-05/04/2017 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended


22/02/2021

Signature of the Inspecting Officer
Name: Sarabjeet Singh
Designation: ADOMN)

~~DO (west)~~

DO. (WEST) 67
DATED. 22/2/2021


22/02/2021

~~DCS (W2)~~



24/2/2021

~~ADP M.N~~

Sir, F.T letter is put up for your signature pl.

~~Dy CFS (W2)~~


27/2/2021


26/02/2021

~~MS/ all~~