

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/GH/NDZ/2021/ 127

Dated: 8/3/21

FIRE SAFETY CERTIFICATE

Certified that the **Baba Inn Guest House** located at **7768-69(1-B) , Ram Nagar, Pahar Ganj, New Delhi** comprised of Ground + 04 Upper floors, Ground floor (Reception + lobby + 03 guest rooms), 1st floor to 3rd floor (06 guest rooms at each floor), 4th floor -05 guest room & teraace -DG & Lift room and total 26 guest rooms owned/occupied by Baba Dx. Guest House was granted FSC by this department vide letter No.F6/DFS/MS/EH/2017/NDZ/574 dated 21/04/17. The premise was re-inspected by the officer concerned of this department on **01/03/21** in the presence of Sh. Mahesh and found that the said guest house building having **Ground floor- (Reception + lobby + 03 guest rooms), 1st floor to 3rd floor (06 guest rooms at each floor) total 21 guest room and 4th floor not in use as per affidavit dated 27.10. 2019** has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Residential, Sub Division-A-1 Ground floor- (Reception + lobby + 03 guest rooms), 1st floor to 3rd floor (06 guest rooms at each floor total 21 guest rooms only** with effect from ~~8/3/21~~ for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued ~~8/3/21~~ at New Delhi by.


5/3/21

(Dr. S. K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Addl. Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi. ID NO. 2020012401920 dated 05/11/2020
2. The Manager,
Baba Inn Guest House located at 7768-69(1-B) , Ram Nagar , Pahar Ganj, New Delhi

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
9. The owner shall not use any floor above third floor for any purpose and same shall remain closed/locked.

INSPECTION REPORT

1. Name & address of the building Baba Inn. Guest House at 7768-6918(1-B) ,
Ram Nagar Pahar Ganj, New Delhi
2. Type of occupancy:- Residential, Sub Division-A-1
Gr. + 04 Upper floors (total 21 Guest rooms)
Ground floor (Reception + lobby + 03 guest rooms),
1st floor to 3rd floor (06 guest rooms)
and 4th floor not in use as per affidavit dated
27.10.2019
3. Type of case: - Renewal
4. Details of previous FSC:- No. F6/DFS/MS/GH/2017/NDZ/574 dated
21/04/17.
5. Fire safety directives No.- N/A
6. Date of inspection:- 01/03/21
7. Name of the inspecting officer:- Sh. Ravinder Singh (ADO/CC)
Sh. Rajinder Atwal (DO /CD)
8. Name & designation of officer
From the building side:- Sh. Mahesh (Manager)
9. Year of construction:-
10. Applicant's letter No:- ID 2020012401920 dated 05/11/2020.

Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/ Existing fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	N/A	03 mtr.	N/A
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	01 Nos.	01 Nos.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	.80mtr.	1.25 mtr.	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	N/A	01	N/A
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	01 mtr.	01 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 ACPH	N/A	N/A
	2) Upper floors	12 ACPH	Natural/exhaust fan	MR
5.	Fire Extinguishers			
	1) Total numbers	10 Nos.	10 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR

K

4/15

6.	First-Aid Hose Reel		01	01	MR
	1) Total number of each floor		01		MR
	2) Length of hose reel hose	30 mtr.	30 mtr.		MR
	3) Nozzle diameter	05 mm	05 mm		MR
7.	Automatic Fire Detection & Alarming System				MR
	1) Type of detectors CO type	Required	Provided		N/A
	2) Location of main panel	N/A	N/A		N/A
	3) Location of repeater panel	N/A	N/A		N/A
	4) Alternate source of power	N/A	N/A		N/A
	5) Hooter's Location	N/A	N/A		N/A
8.	MOEFA		Required	Provided	MR
9.	Public Address System		N/A	N/A	N/A
10.	Automatic Sprinkler System				N/A
	1) Basement	N/A	N/A		N/A
	2) Upper floors	N/A	N/A		N/A
	3) Sprinkler above false ceiling	N/A	N/A		N/A
11.	Internal Hydrants				N/A
	1) Size of riser/down-comer	N/A	N/A		N/A
	2) Number of hydrants per floor	N/A	N/A		N/A
	3) Hose box	N/A	N/A		N/A
12.	Yard Hydrants				N/A
	1) Total number of hydrants	N/A	N/A		N/A
	2) Hose box	N/A	N/A		N/A
13.	Pumping Arrangement				N/A
	1) Ground level	N/A	N/A		N/A
	a) Discharge of main pump	N/A	N/A		N/A
	b) Head of main pump	N/A	N/A		N/A
	c) Number of main pump	N/A	N/A		N/A
	d) Jockey pump out put	N/A	N/A		N/A
	e) Jockey pump head	N/A	N/A		N/A
	f) Stand by pump output	N/A	N/A		N/A
	g) Stand by pump head	N/A	N/A		N/A
	h) Auto starting/Manual stopping	N/A	N/A		N/A
	2) Terrace level				
	a) Discharge of pump	450 LPM	450 LPM		MR
	b) Head of pump	30 mtr.	30 mtr.		MR
	c) Power supply	Required	Provided		MR
	d) Auto starting of pump	Required	Provided		MR
14.	Captive Water Storage for Fire Fighting				N/A
	1) Under ground tank capacity	N/A	N/A		N/A
	a) Draw-off connection	N/A	N/A		N/A
	b) Fire service inlet	N/A	N/A		N/A
	c) Access to tank	N/A	N/A		N/A
	d) Over head tank capacity	5,000 ltr.	5,000 ltr.		MR

W

15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. F6/DFS/MS/GH/2017/NDZ/574 dated 21/04/17, renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended up to third floor only.

Signature of the inspecting officer

Signature of the Inspecting Officer

[Handwritten Signature]

[Handwritten Signature]

Name: - Rajinder Atwal
Designation: - DO (CD)

Name : Ravinder Singh
Designation: ADO (CC)

Dy. CFS CMD 21

Pl. speak about Point no. 1.

[Handwritten Signature]
4/3/21

DO/CCO 1. spoken on 4/3/21. It is an existing old case.
2. Resubmitted pl.

Dy. CFS CMD 21

F.I. pl.

[Handwritten Signature]
4/3

