

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/EH/NDZ/2021/57

Dated: 05/03/2021

**FIRE SAFETY CERTIFICATE**

Certified that the **M/s Barshala ( a unit of Indosprit Bars Pvt Ltd.)**, located at Shop No 4,5&6 Ground floor, Metro express line, Bhavbhuti Marg, Ajmeri Gate, New Delhi. comprises of 03 Basement, Ground + 09 upper floors **but Restaurant running at Ground floor only** . The premises was inspected by officers concerned of this department on 13.02.2021 & 17/02/2021 in the presence of Mr. Lalit Sharma and found that the said premises has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Assembly Building Group D, Barshala( Restaurant) at ground floor only** with effect from 05/03/2021 ---for period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 05/03/2021 at New Delhi by.

  
(Atul Garg)

Director

Delhi Fire Service

Copy to:-

1. The Dy. Commissioner of Police(Lic.), Ist floor, PS Defence Colony, New Delhi,  
**Online ID no. 2020102808095 dated 18.01.2021**
2. The Sr. DGM /Property Business , DMRC , Barakhamba Lane , Connaught place , New Delhi
3. The Manager,  
M/s Barshala ( a unit of Indosprit Bars Pvt ltd), located at Shop No 4,5&6 Ground floor,  
Metro express line, Bhavbhuti Marg, Ajmeri Gate, New Delhi.

**Condition for the validity of fire safety certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
9. Any flammable material for interior decoration is strictly prohibited.



176  
INSPECTION REPORT

1. Name & address of the building M/s Barshala (a unit of Indospit Bars Pvt Ltd.), located at Shop No 4,5&6 Ground floor, Metro express line Bhavbhuti Marg, New Delhi. ( 03B+ Gr. + 9 upper floor )
2. Type of occupancy:- Assembly Building Group-D,  
**Barshala is running Ground floor only.**
3. Type of case:- New case
4. Details of previous FSC:- N/A
5. Fire safety directives No.- N/A
6. Date of inspection:- 13/02/2021 & 17/02/2021
7. Name of the inspecting officer:- Sh. Rajinder Atwal (DO/CD)  
Sh. Ravinder Singh (ADO/CC)
8. Name & designation of officer  
From the building side:- Mr. Lalit Sharma
9. Year of construction:- 2011-12
10. Applicant's letter No:- Online ID no- 2020102808095 dated 18.01.2021

| S.No.     | Minimum Standards on fire Prevention and fire safety U/R 33 | Requirement Existing | Provided at site | Remarks MR/NMR |
|-----------|---|----------------------|------------------|----------------|
| <b>1.</b> | <b>Access to Building</b>                                   |                      |                  |                |
|           | 1) Road width   | 06                   | 20 mtr.          | MR             |
|           | 2) Gate width   | N/A                  | N/A              | N/A            |
|           | 3) Width of internal road                                   | N/A                  | N/A              | N/A            |
| <b>2.</b> | <b>Number, Width Type &amp; Arrangement of Exits</b>        |                      |                  |                |
|           | A. Number of staircases                                     |                      |                  |                |
|           | 1. Upper floors   | N/A                  | N/A              | N/A            |
|           | 2. Basements  | N/A                  | N/A              | N/A            |
|           | B. Width of staircase                                       |                      |                  |                |
|           | 1. Upper floors   | N/A                  | N/A              | N/A            |
|           | 2. Basements  | N/A                  | N/A              | N/A            |
|           | C. Protection of exits                                      |                      |                  |                |
|           | 1. Fire check door  | N/A                  | N/A              | N/A            |
|           | 2. Pressurization   | N/A                  | N/A              | N/A            |
|           | D. No. of continuous staircase to terrace                   |                      |                  |                |
|           | E. Width of corridor  | N/A                  | N/A              | N/A            |
|           | F. Door size  | 2.0 & 1.5 mtr        | 2.0 & 1.5 mtr    | MR             |
| <b>3.</b> | <b>Compartmentation</b>                                     |                      |                  |                |
|           | 1) Fire check door  | N/A                  | N/A              | N/A            |
|           | 2) Sealing of electrical shafts                             | N/A                  | N/A              | N/A            |
|           | 3) Fire rating of shaft door                                | N/A                  | N/A              | N/A            |
|           | 4) Water curtain  | N/A                  | N/A              | N/A            |
|           | 5) Fire Dampers   | N/A                  | N/A              | N/A            |
| <b>4.</b> | <b>Smoke Management System</b>                              |                      |                  |                |
|           | 1) Basements  | 30 ACPH              | N/A              | N/A            |
|           | 2) Upper floors   | 12 a/c per hour      | Natural          | MR             |
| <b>5.</b> | <b>Fire Extinguishers</b>                                   |                      |                  |                |
|           | 1) Total numbers  | 04Nos.               | 04Nos.           | MR             |
|           | 2) Types  | ABC & CO2            | ABC & CO2        | MR             |
|           | 3) ISI marking  | Required             | Provided         | MR             |
| <b>6.</b> | <b>First-Aid Hose Reel</b>                                  |                      |                  |                |
|           | 1) Total number at gr. floor                                | 01                   | 01               | MR             |



|            |   |   |             |     |
|------------|---|---|-------------|-----|
|            | 2) Length of hose reel hose                           | 30 mtr.                                       | 30 mtr.     | MR  |
|            | 3) Nozzle diameter                                    | 05 mm   | 05 mm       | MR  |
| <b>7.</b>  | <b>Automatic Fire Detection &amp; Alarming System</b> |   |             |     |
|            | 1) Type of detectors                                  | Required                                      | Provided    | MR  |
|            | 2) Location of main panel                             | Ground floor                                  | Provided    | MR  |
|            | 3) Location of repeater panel                         | N/A   | N/A         | N/A |
|            | 4) Alternate source of power                          | Required                                      | Provided    | MR  |
|            | 5) Hooter's Location                                  | Ground floor                                  | Provided    | MR  |
| <b>8.</b>  | <b>MOEFA</b>  | Required                                      | Provided    | MR  |
| <b>9.</b>  | <b>Public Address System</b>                          | Required                                      | Provided    | MR  |
| <b>10.</b> | <b>Automatic Sprinkler System</b>                     |   |             |     |
|            | 1) Basement   | N/A   | N/A         | N/A |
|            | 2) Upper floors                                       | Required                                      | Provided    | MR  |
|            | 3) Sprinkler above false ceiling                      | N/A   | N/A         | N/A |
| <b>11.</b> | <b>Internal Hydrants</b>                              |   |             |     |
|            | 1) Size of riser/down-comer                           | 150mm   | 150mm       | MR  |
|            | 2) Number of hydrants at ground floor                 | 01  | 01          | MR  |
|            | 3) Hose box   | 01  | 01          | MR  |
| <b>12.</b> | <b>Yard Hydrants</b>                                  |   |             |     |
|            | 1) Total number of hydrants                           | N/A   | Provided    | N/A |
|            | 2) Hose box   | N/A   | N/A         | N/A |
| <b>13.</b> | <b>Pumping Arrangement</b>                            | <b>Combined arrangements of metro station</b> |             |     |
|            | 1) Ground level                                       |   |             |     |
|            | a) Discharge of main pump                             | 2280 LPM                                      | 2280LPM     | MR  |
|            | b) Head of main pump                                  | 120 m   | 120m        | MR  |
|            | c) Number of main pump                                | 02  | 02          | MR  |
|            | d) Jockey pump out put                                | 180 LPM                                       | 180 LPM     | MR  |
|            | e) Jockey pump head                                   | 120 mtr                                       | 120 mtr     | MR  |
|            | f) Stand by pump output                               | 2280 LPM                                      | 2280 LPM    | MR  |
|            | g) Stand by pump head                                 | 120 Mtr                                       | 120 mtr     | MR  |
|            | h) Auto starting/Manual stopping                      | Required                                      | Provided    | MR  |
|            | 2) Terrace level                                      |   |             |     |
|            | a) Discharge of pump                                  | N/A   | N/A         | N/A |
|            | b) Head of pump                                       | N/A   | N/A         | N/A |
|            | c) Power supply                                       | N/A   | N/A         | N/A |
|            | d) Auto starting of pump                              | N/A   | N/A         | N/A |
| <b>14.</b> | <b>Captive Water Storage for Fire Fighting</b>        |   |             |     |
|            | 1) Under ground tank capacity                         | 1,50,000ltr                                   | 1,50,000ltr | MR  |
|            | a) Draw-off connection                                | Required                                      | Provided    | MR  |
|            | b) Fire service inlet                                 | Required                                      | Provided    | MR  |
|            | c) Access to tank                                     | Required                                      | Provided    | MR  |
|            | d) Over head tank capacity                            | 20,000 lit.                                   | 20,000 lit. | MR  |
| <b>15.</b> | <b>Exit Signage.</b>                                  | Required                                      | Provided    | MR  |
| <b>16.</b> | <b>Provision of Lifts.</b>                            |   |             |     |
|            | a) Pressurization of lift shaft                       | N/A   | N/A         | N/A |

|     |   |          |          |     |
|-----|---|----------|----------|-----|
|     | b) Pressurization of lift lobby   | N/A      | N/A      | N/A |
|     | c) Communication in lift car  | N/A      | N/A      | N/A |
|     | d) Fireman's switch   | N/A      | N/A      | N/A |
|     | e) Lift signage   | N/A      | N/A      | N/A |
| 17. | <b>Stand by Power Supply</b>  | Required | Provided | MR  |
| 18. | <b>Refuge Area</b>  | N/A      | N/A      | N/A |
|     | Total area location   | N/A      | N/A      | N/A |
| 19. | <b>Fire Control Room</b>  | N/A      | N/A      | N/A |
|     | a) Detector system panel  | N/A      | N/A      | N/A |
|     | b) Flow switch panel  | N/A      | N/A      | N/A |
|     | c) PA system panel  | N/A      | N/A      | N/A |
|     | d) Battery backup   | N/A      | N/A      | N/A |
|     | e) Building floor plan  | N/A      | N/A      | N/A |
| 20. | <b>Special Fire Protection System for Protection of special Risk, if any:</b> |          |          | N/A |


Barshala is running at ground floor only and pumping arrangements installed for restaurant are connected with fire arrangements of Delhi Metro station.

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, if agreed, the Fire Safety Certificate under rule 35 of Delhi Fire Service Rules-2010 is recommended to be issued .

Signature of the Inspecting Officer


Signature of the Inspecting Officer





Name :- Rajinder Atwal  
Designation :- DO (CD)




Name :- Ravinder Singh  
Designation :- ADO (CC)



Pl. speak about point No. 7 .

1. spoken on 23/2
2. Pl check for detectors and sprinklers.



Detection & sprinklers are not provided for restaurant. However, same are provided in guidelines of metro station (P.D. area).