

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/EH/2021/NDZ/ 58

Dated: 05/03/2021

FIRE SAFETY CERTIFICATE

Certified that the M/s Bikanervala Food Pvt. running on ground floor of the building is comprised on basement, ground plus two upper floors only, owned/occupied by Bikanervala was issued FSC vide letter no. F6/DFS/MS/EH/NDZ/2018/EH/256 dated 15/02/18. The premises was re-inspected by the officer concerned of this department in the presence of Sh. Puspender, Manager and found that the restaurant have complied with the fire prevention and fire safety requirements in accordance with rules 33 of the Delhi Fire Service Rules, 2010 and observed that restaurant is fit for occupancy Group D "Assembly Building" for ground floor only with effect from 05/03/2021 for a period of **three** years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 05/03/2021 at New Delhi by



(Dr. S. K. Tomar)
Dy. Chief Fire officer

e/c

To,

M/s Bikanervala Food Pvt.
ZB-9,10 & 11/487, G.T. Road Dilshad Garden,
Delhi 110095,

Copy To:-

The Dy. Heath Officer
Shahdara (South Zone), East Delhi Municipal Corporation,
Karkardooma, Shahdara, Delhi 110032

ID No. 2021010509398

Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

1. Name & address of the building : Bikanervala Food Pvt. ,
ZB-9,10 & 11/487, G.T. Road Dilshad Garden,
Delhi110095
2. Building is comprised of : Basement, Ground plus two upper floors only
(Restaurant is running on ground floor of the building)
3. Type of Occupancy : Assembly building (Restaurant)
4. Type of Case : Renewal
5. Details of Previous NOC letter : F6/DFS/MS/EH/NDZ/2018/EH/256 dt 15/02/18
6. Fire Safety directive letter No : NBC Part IV
7. Date of Inspection : 19/02/2021
8. Name of the Inspecting officers : D.O. Francis Brown
9. Name and designation of Officer
from the building side : Mr. Puspender (Manager)
10. Year of Construction : 2005
11. Applicant's letter No : online 2021010509398 Dated 06/01/2021

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	NBC Part IV Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building			
	• Road width	06 mtr.	36 mtr (120 Ft)	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper floor	02 nos.	02 nos.	MR
	• Basement	02 nos.	01 + 01 door open on main door	MR
	B. Width of Staircases			
	• Upper floor	N/A	N/A	N/A
	• Basement	02 mtr	1.25 mtr + 04 mtr gate open on main road	MR
	c. Protection of Exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	01 no.	01 no.	MR
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	02 mtr.	02 nos. of 2.0 mtr & 01 no. of 1.50 mtr	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	Required	Sealed	MR
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
05.	Fire Extinguishers			
	• Total numbers	06 nos.	08 nos.	MR
	• Types	ABC /CO ₂	ABC /CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR

06	First-Aid-Hose Reels.			
	Total numbers on each floor	01 nos	01 nos	MR
	• Length of hose reel hose	30 mtr	30 mtr	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	Heat & Smoke	Smoke	MR
	• Location of main panel	G. Floor	G. Floor	MR
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	Battery & DG Set	Provided	MR
	• Hooter	N/A	N/A	N/A
08	MOEFA	Required	Provided	MR
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants common with the Mall			
	• size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	01 no.	01 no.	MR
	• Hose box	01 no.	01 no.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump head	N/A	N/A	N/A
	• Auto starting /manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	900 Lpm	900 Lpm	MR
	• Head of the pump	40 mtr	40 mtr	MR
	• Power supply	Required	Provided	MR
	• Auto starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	Required	Provided	MR
	• Overhead tank capacity	25,000 ltr	25,000 ltrs	MR
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if Any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the NBC Part IV, it is recommended to renew Fire Safety Certificate..

[Handwritten signature]
19/2

Signature of the Inspecting Officer
Name - Francis Brown
Designation - D.O (ED)

Dy. CFO (NDZ) *F.G. pl.*

OK/omr
24/2/24

DO (ED) F.E. letter is prepared and put up for
signature pls.

[Handwritten signature]
2/3/24

DC EO/NDZ

OK/omr
4/3/24

m.s/cen