

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO.F6/DFS/MS/2021/CNG | 151

Dated: 05/03/2021

FIRE SAFETY CERTIFICATE

Certified that the CNG Station at Rohini Bus Depot, Phase-I, Rajiv Gandhi Cancer Institute & Research Centre, Sir Chotu Ram Marg, Rohini Institutional Area, Sec-5, Rohini, Delhi comprised of Single Story Building owned / occupied by Indraprastha Gas Limited. The premises was inspected by officer concerned of this department on 29.12.2020 in the presence of Mr. Prashant Kumar (AM) and found that the premises have complied with fire prevention & fire safety requirement in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and the building/ premises fit for occupancy CNG Filling Station Group 'J' with effect from 05/03/2021 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rule, 2010 subject to conditions printed below.

Issued on 05/03/2021 at New Delhi by


(Atul Garg)
DIRECTOR

Ph; 011-23414000

g/c
ny

Copy to:

1. Chief General Manager (project), Indraprastha Gas Limited, IGL Bhawan, Plot no-4, Community Center, R.K. Puram, Sector-9, New Delhi-110022.
2. The Addl. Commissioner of Police (Lic), 1st Floor, Police Station, Defense Colony, Delhi

Conditions for the validity of Fire Safety Certificate:

- 1 All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
- 2 Any loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5 This certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use for land if any.
- 6 The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The is available on http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rule+s/ http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

INSPECTION REPORT**Gr. floor Only**

1. Name & address of the building : CNG Station at Rohini Bus Depot, Phase-I, Rajiv Gandhi Cancer Institute & Research Centre, Sir Chotu Ram Marg, Rohini Institutional Area, Sec-5, Rohini, Delhi.
2. Type of Occupancy : CNG Filling Station **Group "J"/ Business**
3. Type of Case : New Case (**Gr. Floor only**)
4. Details of Previous NOC : Nil
5. Fire Safety directives letter No : F.6/DFS/MS/CNG/2019/626 dated 31.01.2019
6. Date of inspection : 29.12.2020
7. Name of Inspecting Officer : A.K. Sharma (ADO Rohini)
8. Name and designation of officers
From the building side : Mr. Prashant Kumar (AM)
9. Year of Construction :
10. Applicant's letter No. : Online mail Dated 01.12.2020

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	OISD/ Directive Requirement	Provided at site	Remarks MR/NMR
1.	Access to building[
	• Road width	Required	30 mtr	M/R
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	NA	NA	NA
	• Basement	NA	NA	NA
	c. Protection of exits			
	• Fire check door	N/A	NA	NA
	• Pressurization	N/A	NA	NA
	d. No. of continuous staircases to terrace	N/A	NA	NA
	e. Width of Corridor	N/A	NA	NA
	f. Door Size	1.0 mtr	1.0 mtr	MR
3.	Compartmentation			
	• Fire check door	N/A	NA	NA
	• Sealing of electrical shafts	N/A	NA	NA
	• Fire Rating of shaft door	N/A	NA	NA
	• Water Curtain	N/A	NA	NA
	• Fire Dampers	N/A	NA	NA
4.	Smoke Management System			
	• Basements	30 a/c per hour	N/A	NA
	• Upper floors	12 a/c per hour	N/A	NA
5.	Fire Extinguishers			
	• Total numbers	75 KG – 2 DCP	Provided	MR
	• Types	10 KG – 8 DCP	DCP/co2 type	MR
	• IS marking	4.5 Kg – 04 CO2	Yes	MR
		ISI marked		

6.	First-Aid Hose Reels			
	• Total numbers on each floor	N/A	N/A	NA
	• Length of hose reel hose	N/A	N/A	NA
	• Nozzle diameter	N/A	N/A	NA
7.	Automatic fire detection and alarming system			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basement	N/A	N/A	N/A
	• Ground Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual Stopping	NA	NA	NA
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14.	Captive Water Storage for firefighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15.	Exit Signage.	NA	NA	NA
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA

