

C-27

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/School/WZ/2021/ 209



Dated: 11 / 3 / 2021

FIRE SAFETY CERTIFICATE

Certified that the **Govt. Girls Senior Sec. School**, Located at **Anandwas, Shakurpur, Delhi-110034**, comprised of **(One Block = Ground + 01 Upper Floors)** was issued FSC by this department Vide Letter No. F6/DFS/MS/SCHOOL/2018/WZ/85 Dated 12.01.2018. The said premise was re-inspected by the officer concerned of this department on 22.02.2021 in the presence of Ms. Bimple Arya (PGT) & Sh. Ravinder (Estate Manager) and found that the premises / building have deemed complied with the fire prevention and fire safety requirements in accordance **D.O.E., GNCT of Delhi, Circular no.3298-3398 dated 01-03-2011** and that the premises/building is fit for occupancy class "Educational Building" Group B with effect from 11/03/2021 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on 11/03/2021 at New Delhi by.


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
(West Zone)


11/03/2021


Copy to: -

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi - 110054.
2. The Principal, Govt. Girls Senior Sec. School, Anandwas, Shakurpur, Delhi-110034.

c/25

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

1. Name and address of the building:- **Govt. Girls Sr Sec. School** Located at **Anandvas , Shakurpur, Delhi -110034**
2. Type of Occupancy : Educational (One Block=G+1 Upper Floor only)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/SCHOOL/2018/WZ/85 Date 12.01.2018
5. Fire Safety directives Letter No. : **D.O.E Circular no.3298-3398 dated 01-03-2011**
6. Date of inspection : 22.02.2021
7. Name of the Inspecting Officer : S.P. Bhardwaj, ADO (WP)
8. Name and designation of Officer
from the building side : Ms. Bimple Ariya (PGT) & Sh. Ravinder (Estate Manager)
9. Year of Construction : 1975
10. Applicant's letter No. : email dated 16.02.2021

S No	Minimum standards on fire prevention and fire safety U/R 33	D.O.E. Circular No. 3298-3398 Dated 01.03.2011		Provided at site	Remarks MR/NMR
1.	Access of building				
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<ul style="list-style-type: none"> Accessible Accessible NA 	<ul style="list-style-type: none"> Accessible Provided NA 		<ul style="list-style-type: none"> MR MR NA
2.	Number, width, Type & Arrangements of exits				
	a. Number of staircases				
	<ul style="list-style-type: none"> • Upper floors • Basements 	<ul style="list-style-type: none"> 2 NA 	<ul style="list-style-type: none"> Provided NA 		<ul style="list-style-type: none"> MR NA
	b. Width of staircases				
	<ul style="list-style-type: none"> • Upper floors • Basements 	<ul style="list-style-type: none"> 150cm NA 	<ul style="list-style-type: none"> 1x141cm, 1x144cm NA 		<ul style="list-style-type: none"> MR(Old Case) NA
	c. Protection of exits				
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA 		<ul style="list-style-type: none"> NA NA
	d. No of continuous staircase to terrace	NA	NA		MR
	e. Width Of Corridor	1.5m	175cm Provided		MR
	f. Door Size	100cms	105cm		MR
3.	Compartmentation		NA		
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	<ul style="list-style-type: none"> NA NA NA NA NA 	<ul style="list-style-type: none"> NA NA NA NA NA 		<ul style="list-style-type: none"> NA NA NA NA NA
4.	Smoke managements System				
	<ul style="list-style-type: none"> • Basements • Upper floors 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA 		<ul style="list-style-type: none"> NA NA
5.	Fire Extinguishers				
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	<ul style="list-style-type: none"> 5 nos. ABC & CO₂ ISI marked 	<ul style="list-style-type: none"> 19 Provided Provided Provided 		<ul style="list-style-type: none"> MR MR MR

N/16

19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

Fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety requirements as per D.O.E. Circular no. 3298-3398 dated 01.03.2011, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/SCHOOL/2018/WZ/85 Dated 12.01.2018 is recommended under rules 37 of the Delhi Fire Service Rules 2010 & DFS Act 2007.

S.P. Bhardwaj
(ADO (WP))

~~Do/went~~

~~02/03/2021~~

~~Defo (WZ)~~

~~31/8/2021~~

D.O. (WEST)/...92
DATED.. 2/3/2021

~~ADo/went~~

FT for Storage plume

~~Defo/wz~~

~~10/8/2021~~

~~5/3/21~~

~~MS/ell~~