

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No.F.6/DFS/MS/School/2021/SZ/ 204

Dated: 10/3/21

FIRE SAFETY CERTIFICATE

Certified that the Inder Public School, Plot No. 2 Kh. No- 9/14 Shiv Vihar (Near Gali No-16, S Block) Block A , Vikas Nagar, Uttam Nagar, New Delhi-110059, comprised of ground plus three upper floors, owned/occupied by Gyan Ganga Samajik Avom Shikshak Sanstha have complied with the fire prevention and fire safety requirements in accordance with the rule 33 of Delhi Fire Service Rules 2010 and verified by the officer concerned of this department on 22/02/2021 in the presence of Sh. Akshay Lakra (Manager) and found that the building is fit for occupancy "Educational Building" with effect from 10/3/21..... for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on.....10/3/21.....at New Delhi by



(Atul Garg)

Director

Delhi Fire Service



Copy to:-

1. The Manager,
Inder Public School, Plot No. 2 Kh. No- 9/14 Shiv Vihar
(Near Gali No-16, S Block) Block A , Vikas Nagar,
Uttam Nagar, New Delhi-110059
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : Inder Public School, Plot No. 2 Kh. No- 9/14 Shiv Vihar (Near Gali No-16, S Block)Block A , Vikas Nagar, Uttam Nagar, New Delhi-110059
2. Building comprised of : ground plus three upper floors (10 class rooms at each floor)
3. Type of Occupancy : Educational
4. Type of Case : New
5. Details of Previous NOC : Nil
6. Fire Safety directives letter No : N/A
7. Date of inspection : 22/02/2021
8. Name of Inspecting Officer : A.D.O. R.K.Yadav
9. Name and designation of officers
From the building side : Sh. Akshay Lakra (Manager)
10. Year of Construction : 2019-2021
11. Applicant's letter No. : Nil dated 11/02/2021

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	06 mtrs 4.5 mtrs N/A	06 mtrs 4.5 m N/A	MR MR N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	02 No.'s N/A	02 No.'s+ ramp N/A	MR N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	1.50 m each N/A	1.80 m each & 1.90 m ramp N/A	MR N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace			
		2 no.	2 no.	MR
	e. Width of Corridor	1.50 m	3.0 m	MR
	f. Door Size	1.20 m	1.20 m	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Upper floors 	Required	Natural ventilation provided	M/R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types 	12 no's ABC/CO ₂ type ISI marked	Provided Provided	MR MR

6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor 	01 no.	01 no.	MR
	<ul style="list-style-type: none"> Length of hose reel hose 	30 m	30 m	MR
	<ul style="list-style-type: none"> Nozzle diameter 	05 mm	05 mm	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location of Main Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location of Repeater Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Alternate source of power 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hooters' Location 	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Ground Floor 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	N/A	N/A	N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	100 mm	100 mm	MR
	<ul style="list-style-type: none"> Number of hydrants per floor 	One	One	MR
	<ul style="list-style-type: none"> Hose Box 	One	One	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hose Box 	N/A	N/A	N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	N/A	N/A	N/A
	<ul style="list-style-type: none"> <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Pump House Access 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Terrace level 			
	<ul style="list-style-type: none"> Discharge of pump 	450 LPM	450x2 LPM	MR
	<ul style="list-style-type: none"> Head of the pump 	40 m	40 m	MR
	<ul style="list-style-type: none"> Power Supply 	Required	Provided	MR
	<ul style="list-style-type: none"> Auto Starting of pump 	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity 	N/A	N/A	N/A
	<ul style="list-style-type: none"> <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Overhead Tank capacity 	N/A	N/A	N/A
		10,000 ltrs	15,000 ltrs	MR
15.	Exit Signage.	Required	Provided	MR

N/3

16.	Provision of Lifts.	No Lift		
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection
 Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

R.K. Yadav
 Signature of Inspecting Officer | 3 | 2021

Name:- R.K. Yadav
 Designation:- Asstt. Divisional Officer

Divisional Officer (South West)
[Signature]
 02/03/2021



dy cfo / SW
[Signature]
 2/3
 C.A.O.
[Signature]