

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001


No. F.6/DFS/MS/2021/ W2/School/195

Dated: 08/03/2021

FIRE SAFETY CERTIFICATE

Certified that the **Rajkiya Sarvodaya Vidyalaya No-4 (I.D-1207013)** located at **Roop Nagar, Delhi-110007** comprised of **04 blocks (Three blocks G+01 & One blocks G+03upper Floor)** owned/ occupied by **Rajkiya Sarvodaya Vidyalaya No-4** was issued Fire Safety Certificated vide this office letter no. **F-6/DFS/MS/School/2016/WZ/1794** dated **16.12.2016** the premise was re-inspected by the officer concerned of this department on **03.03.2021** in the presence of **Sh. Satish Gupta (Estate Manager)** and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition. The premise have therefore deemed complied with the requirements under rule 33 of the Delhi Fire Service Rules, 2010 and the building premise is fit for occupancy under **Educational "Group B"** with effect from 08/03/2021 for a period of **three years** in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

Issued on 08/03/2021 at New Delhi by


(Dharampal Bhardwaj)
Dy.Chief Fire Officer
Ph:-011-25156707
08/03/2021
o/c

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Principal, Rajkiya Sarvodaya Vidyalaya No-4, Roop Nagar, Delhi-110007.

Conditions for the validity of Fire Safety Certificate:

- 1 All the means of escape/entry/exit shall be kept free from any obstruction.
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
- 3 All the staff members must know the correct method of operation of firefighting system.
- 4 The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on http://delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms.
- 5 This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
- 6 "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

1. Name & address of the building : Rajkiya Sai Vaidya Vidyalaya No-4, Kooop Nagar, Dehra Dun-248001 (U.P.)
2. Type of Occupancy : Educational
3. Type of Case : Renewal 04 Blocks (Three blocks G+01 & One blocks G + 03upper Floor)
4. Details of previous NOC : F-6/DFS/MS/School/2016/WZ/1794 dated 16.12.2016
5. Fire Safety directives letter No : NBC Part-4
6. Date of inspection : 03.03.2021
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers
from the building side : Sh. Satish Gupta (Estate Manager)
9. Year of Construction : 1986 & 2011
10. Applicant's letter No. : Nil Diary No-11241 dated 17.02.2021

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06m	06m	MR
	• Gate width	4.5m	4.9m	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	04	04	M/R
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper Floors	1.50m	G+3 -1.80m each G+1- 1.60m each	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	Required	1	M/R
	e. Width of Corridor	Required	1.78m	M/R
f. Door Size	1 m	1.03m double door	M/R	
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basements	12 a/c per hour	N/A	N/A
	• Upper floors	12 a/c per hour	N/A	N/A
5	Fire Extinguishers			
	• Total numbers	16	16	M/R
	• Types	ABC/Co2	ABC/CO2	M/R
	• ISI marking	ISI Marked	Yes	M/R
6	First-Aid Hose Reels.			

	<ul style="list-style-type: none"> Total numbers on each floor 	01	01	MR
	<ul style="list-style-type: none"> Length of hose reel hose 	30m	30m	M/R
	<ul style="list-style-type: none"> Nozzle diameter 	5mm	5mm	M/R
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location of Main Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location of Repeater Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Alternate source of power 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hooters' Location 	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Upper Floor 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	N/A	N/A	N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	100mm	100mm	M/R
	<ul style="list-style-type: none"> Number of hydrants per floor 	01	01	M/R
	<ul style="list-style-type: none"> Hose Box 	01	01	M/R
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		NA	NA	NA
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		450lpm	450 X 2	MR
		40m	40m	M/R
		N/A	N/A	N/A
		Required	Provided	M/R
14	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Draw-off connection 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Fire service inlet 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Access to tank 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Overhead Tank capacity 	10,000 ltrs	10,000ltr	MR
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.				
	• Pressurization of Lift Shaft	N/A	N/A	N/A	
	• Pressurization of Lift lobby	N/A	N/A	N/A	
	• Communication In lift Car	N/A	N/A	N/A	
	• Fireman's Grounding Switch	N/A	N/A	N/A	
	• Lift Signage	N/A	N/A	N/A	
17	Standby power supply		N/A	N/A	N/A
18	Refuge Area.				
	➤ Total Area	N/A	N/A	N/A	
	➤ Location	N/A	N/A	N/A	
19	Fire Control Room				
	• Detector System Panel	N/A	N/A	N/A	
	• Flow Switch Panel	N/A	N/A	N/A	
	• PA System Panel	N/A	N/A	N/A	
	• Batter backup	N/A	N/A	N/A	
	• Building Floor Plans	N/A	N/A	N/A	
20	Special Fire Protection Systems for Protection of special Risks, if any:		N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in good working condition, at the time of inspection. The management has complied all the shortcomings issued and communicated by this department vide letter of even no. 167 dated 05.03.2020.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in NBC Part-4, the FSC issued vide letter of even no.1794 dated 16.12.2016 renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended

DO (W2)

By CFO (W2)
03/03/2021

By CFO (W2)

4/8/2021


ADO/R-N


As approved, F.I. letter is put up for your

Signature Pl.

By CFO (W2)

4/8/2021


Signature of the Inspecting Officer
03/03/2021
Name :- C.L. Meena
Designation:- ADO/RN


05/03/2021